AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Lifting equipment and machinery
APM Object	CT.WORK.LIFTING
APM Description	Lifting equipment and machinery, including those designed to lift goods only and those which involve lifting of people.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where mobile or stationary lifting equipment and machinery is used to lift and transport goods and materials over short distances. This Compliance Standard includes the minimum and additional maintenance and inspection requirements for forklift trucks, pallet trucks, reach trucks, PUPS and pallet lifts. Refer also to Amazon safety standards

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of equipment (visual damage, topping-up liquids, cleaning, replacement of parts, etc.).	Competent person.	APM Record			CT					
All	2	If used to lift ONLY goods/materials - at least every 12 months. More frequent inspections might be required based on risk assessment (use and environmental conditions). If involves lifting people as well as goods and materials - at least	Thorough inspection of safety-critical to ensure safe use. This includes lifting and non-lifting parts. If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement - do Not use. Report issue.	Competent person.	Inspection records, report or certificate Risk assessment					CT*	CT*		
DE	4	Before commissioning (Inbetriebenahme) /re-commissioning (Außerbetriebenahme).	Initial inspection according to Section 2.10 DGUV Regel 100-500 for lifting platforms.	No additional requirements	No additional requirements								As Needed CT
FR	3	Inspection frequency is 6 months for goods lifting equipment.	Inspection as per [2].	No additional requirements	No additional requirements					(CT)			
IT	9	Preliminary inspection if the equipment has not been used for more than 3 months (PUPS).	No additional requirements	No additional requirements	CE Declaration of conformity. Records to be kept for 3 years.				*CT				

PL	5	No additional requirements	Inspection as per [2] for PUPS.	Government Authority for the Technical Inspection.	If the equipment passes the test, mark with sticker.					(CT)			
ROI	6	No additional requirements	No additional requirements	No additional requirements	Register of lifting equipment. All records need to be kept for at least 5 years.								NAR
SK	7	Electrical and lifting inspections every 3 months, and professional examination every 3 years.	Inspection as per [2].	No additional requirements	No additional requirements				CT*				3Yr CT
UK	8	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme								

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 Government Regulation No. 378/2001 Coll., EN 81-1, EN 81-2, EN 81 - 80 ČSN 274007 – ČSN 274002 EN 81 - 80	Competent person, best practice to outsource to specialist company.	Checks carried out every 6 months. Testing is carried out every 6 years.
DE	BetrSichV, §3, Annex 1 TRBS 1201 DGUV Regel 100-500, Section 2.10 DGUV Vorschrift 68 - Flurförderzeuge	Competent person (befähigte Person)	Daily visual inspection. Routine inspections at least every 12 months. For lifting platforms inspection prior first use, after significant changes and recurrent every 12 months.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines. UNE EN 280:2014 Standard. Mobile elevating work platforms - Design calculations - Stability criteria - Construction - Safety - Examinations and tests UNE 58921: 2017 Standard. Instructions for installation, handling, maintenance, revisions and examinations of mobile elevating work platforms. UNE EN 13155 Standard. Removable Load Lifting Equipment Standard	Competent person.	Maintenance follow manufacturer's instructions. Pallet trucks, PUPS and forklift trucks - regular inspections and checks when required. Pallet lifts - inspections at least every 3 years.
FR	1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified) https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000439029/ Labour Code Art. R. 4323-22 à R. 4323-28 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489757/#LEGISCTA000018531487	Qualified person.	Inspections every 6 months.
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81 UNI EN ISO 3691:2020 (Safety requirements and test) UNI ISO 5053:2020 (Classifications) UNI EN 16037:2020 (Supplementary safety requirements) UNI EN 1459:2020 (Safety requirements) UNI EN 16203:2014 (Lateral stability tests) UNI ISO 5057:2000 (Fork arms repair) UNI ISO 13562:2012 (Stability test) UNI ISO 15000:2009 (Safety specifications for loading operations)	Competent person.	Maintenance in accordance with manufacturer's instructions. Pallet lifts and trucks and forklift trucks – Periodic inspection at least every 12 months. Lifting components inspection every 3 months. PUPS - inspections every 12 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical supervision in the field of operation, repair and modernization of handling equipment. (Journal of Laws 2018, item 2176) Regulation of Minister of Labour and Social Policy of 26 September 1997 on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Development and Finance of 15 December 2017 on health and safety at work with the use of motorized industrial trucks (Journal of Laws 2020, item 852)	Competent person or qualified person. Government Authority to conduct PUPS inspections.	Forklifts and PUPS - full periodic verification every 12 months. Pallet trucks and lifts - inspections in accordance with manufacturer's recommendations.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Regular maintenance in accordance with manufacturer's recommendations. Forklift trucks and pallet lifts - inspections at least every 12 months, or every 6 months if it involves lifting people. Pallet trucks - Inspection based on risk assessment.

SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment	Competent person, best practice to outsource to specialist company.	Pallet lifts and trucks - inspections at least every 12 months. PUPS - Professional inspections every 3 months and testing every 3 years. Forklift trucks - technical inspection at least every 2 years.
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) The Lifting Operations and Lifting Equipment Regulations 1998 (legislation.gov.uk) Rider-operated lift trucks: Operator training and safe use. Approved Code of Practice and guidance L117 (hse.gov.uk) l113.pdf (hse.gov.uk) Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 (legislation.gov.uk) Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent person, best practice to outsource to specialist company.	Maintenance in accordance with manufacturer's recommendations. Thorough inspections at least every 12 months for all equipment and every 6 months if it involves lifting people. Pallet trucks - Inspection based on risk assessment.