AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Storage Structures
APM Object	CT.WORK.STORAGE
APM Description	Storage structures
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	STOR.HRACK - STOR.SHELV	**Related CT Areas:**	Not Specified		

Scope

Any site where materials and goods are stored in tiered structures, such as pallet racking, pick towers, rebin walls and shelves.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Regular maintenance.	In accordance with manufacturer's instructions and recommendations.	Competent person	Maintenance logbook CE Declaration of Conformity (at purchase)	PM					EVID		
All	2	Thorough inspection of safety-critical to ensure safe use (e.g. stability, structural damage, distribution of load's weight, etc.). If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement -	At least every 12 months. More frequent inspections might be required based on risk assessment (use and environment).	Competent person	Inspection records, report or certificate Risk assessment	(PM)					(EVID)		
All	3	Condition inspection – check for signs of damage from collision, collapse, buckling, over stocking etc.	In line with risk assessment but at least monthly.	Competent person	Inspection records	(PM)					(EVID)		
DE	5	Based on risk assessment, but at least weekly.	Visual inspections	Competent person	No additional requirements	(PM)					(EVID)		
FR	4	Inspections to be conducted every 6 months for lifting equipment only.	Inspections as per [2].	No additional requirements	No additional requirements					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll. ČSN EN ISO 3691-5	Qualified technician or H&S specialist. Accredited.	Inspections carried out every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) DGUV Regel 108-007 - Lagereinrichtungen und -geräte DGUV 208-043 – Sicherheit von Regalen DIN EN 15635 - Ortsfeste Regalsysteme aus Stahl - Anwendung und Wartung von Lagereinrichtungen	Competent person (befähigte Person) according to BetrSichV	Before first use, weekly visual inspections, expert inspections at least once a year. Regular shelf-inspection based on risk assessment.
ES	RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines. RD 486/1997. Minimum prevention measures in working places. RD2267/2004, of December 3, which approve fire safety regulation in industrial premises. Section 8.1 – appendix II: fire resistance in steel static storage systems. UNE-EN 15635: 2010. Steel static storage systems - Application and maintenance of storage equipment UNE 58011: 2004. Steel static storage systems. Classification. Definitions. Terminology	Competent person.	Maintenance in accordance with manufacturer's recommendations. Inspections at regular intervals based on risk assessment.
FR	Arrêté du 1 mars 2004 relatif aux vérifications des appareils et accessoires de levage - Légifrance (legifrance.gouv.fr) Best practice : standard NF EN 15635	Qualified person.	Inspections every 6 months (lifting equipment only) Pick towers – inspections annually.
IT	Directive 2006/42/CE on machinery (Annex II A) (Automated storage structures) Legislative Decree 9.04.2008 n° 81 UNI EN 15878:2010 (Terms and definitions) UNI EN 15512:2021 (Design principles) UNI EN 15620:2009 (Tolerances, deformations and interspaces) UNI EN 15635:2009 (Use and maintenance) UNI EN 15629:2009 (Specifications) UNI 11636:2016 (Validation) UNI 11262:2017 (Metal storage structures) UNI EN 15095:2009 (Safety requirements for automated storage structures)	Competent person.	Maintenance in accordance with manufacturer's instructions. Inspection at least every 12 months.
PL	Regulation of Minister of Labour and Social Policy of 26 September 1997 on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596)	Competent or qualified person (if required by manufacturer)	Inspection frequency based on manufacturer's recommendations or internal procedures.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Regular maintenance in accordance with manufacturer's recommendations. Initial inspection after installation and at regular intervals based on risk assessment.
SK	No. 59/1982 Coll. laying down the basic requirements to ensure the safety of work and technical equipment STN 26 9030: Storage. Principles of security in the materials handling	Competent person.	Inspections to be carried out at least every 12 months as defined by STN EN 26 9030.
UK	The Provision and Use of Work Equipment Regulations 1998 SEMA | Codes of Practice | Publications | Codes of Practice | Publications Warehousing and storage: Keep it safe INDG412 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Approved Rack Inspector or other technically competent person.	Thorough examination by Approved Rack Inspector at least every 12 months. Safety inspections conducted monthly.