amazon rme

AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

Task Title	FIRE LIFE SAFETY SYSTEM, FIRE SLIDING DOORS - 10
APM Object	FIRE.FLS.FIRESLD
APM EC	AMZ.FIRE.SLD
BBM Handbook Title	Fire Sliding Door
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed. To suggest improvements please raise a SIM SIM - Link to SIM template

Last Update: (Version)	Jun-24	**Geo Applied:**	Intl APM Instance	**F-Gas**	Not Identified	**Activies may be covered by No-Go restrictions:**	TBC	**Special Certificaion Required:**	TBC	**Delivered By:**	TBC	**OCB:**	BBM
Evidence for CT:	TBC	**Pricing template Position:**	10	**Related CT Areas:**	CT.FIRE.SHUTTERS			**Assets included in this PM:**	FIRE SLIDING DOOR	**Schedule With:**	-		

Description of System / Technology (According to BBM Handbook)

Fire Sliding Doors, also known as Rolling Steel Fire Doors, are allocated in walls where people or vehicles pass from different building areas. Shutters would close in case of a fire to isolate the areas.
NOTE: Smaller window style fire shutters for conveyors are listedn in FIRE SUPPRESSION SYSTEMS.

Additional Information

All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.

Task Index	Component	Tasks	Tasks Nested for frequencies > weekly									
			Daily	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	36 Monthly	48 Monthly	60 Monthly
1	Documentation	Is the documentation of installed doors available & complete						PM				
2	Safety	Check pinch protection for damage and correct function						PM				
3	Safety	Check for correct function of safety switches						PM				
4	Door	Is the door and frame free from damage and corrosion						PM				
5	Door	Are rollers and guides free from obstruction, debris and clean						PM				
6	Door	Are all door sealing ok						PM				
7	Door	Does the door move smoothly without resistance and doesn`t drag, bang against door frame, or stick at the rail in case of sliding doors						PM				
8	Door	Does the door close properly and stay close						PM				
9	Electrical components	Check for correct operation of drive mechanism Lubricate and adjust as necessary						PM				
10	Electrical components	Check motor overload for correct function						PM				
11	Electrical components	Check condition and correct function of limit switches Adjust if necessary						PM				
12	Electrical components	Check the control elements for damage and correct function						PM				
13	Electrical components	Check if cables are properly routed and free from damage						PM				
14	Electrical components	Ensure all cable terminations are secure						PM				
15	Final Check	Check the O&M manual and carry out additional required tasks						PM				

Change Log

July 2023 - First issue in new format. Simplification of task scope, alignment with CT.
June 2024 - New PM for FIRE.FLS.FIRESLD.