amazon rme

AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

Task Title	FIRE SUPPRESSION SYSTEM, EQUIPMENT, EXTINGUISHERS - 10
APM Object	FIRE.SUP.EQP.EXT
APM EC	AMZ.FIRE.EXT
BBM Handbook Title	Fire Extinguishers (Powder, CO2, Foam and Water)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed. To suggest improvements please raise a SIM SIM - Link to SIM template

Last Update: (Version)	Dec-23	**Geo Applied:**	Intl APM Instance	**F-Gas**	Not Identified	**Activies may be covered by No-Go restrictions:**	TBC	**Special Certificaion Required:**	TBC	**Delivered By:**	Carried out by trained on site technician	**OCB:**	BBM
Evidence for CT:	YES	**Pricing template Position:**	10	**Related CT Areas:**	CT.FIRE.FIGHTINGEQUIP CT.HVAC.ODS	**Assets included in this PM:**	EXTINGUISHERS	**Schedule With:**	FIRE.SUP.EQP				

Description of System / Technology (According to BBM Handbook)

Fire Extinguishers (Powder, CO2, Foam and Water)
Extinguishers are active fire protection device. Each type is suitable for different fire classes.

Additional Information

All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.

Task Index	Component	Tasks	Tasks Nested for frequencies > weekly									
			Daily	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	36 Monthly	48 Monthly	60 Monthly
1	Extinguisher check	Check if all (the correct) fire extinguishers are available at the required location, free from damage/corrosion & fixed properly						SC				
2	Extinguisher check	Check the maintenance label for overdues and plan action accordingly						SC				
3	Extinguisher check	Check if the operating instructions are available and easy to read on the fire extinguisher						SC				
4	Extinguisher check	Check if the pressure indicator on the fire extinguisher is in the green area & is leak-free						SC				
5	Extinguisher check	Check whether the security bolt or seal is undamaged						SC				
6	Extinguisher check	Check the trigger mechanism of the fire extinguisher without triggering it (don`t remove the pin)						SC				
7	Extinguisher check	Ensure that all required regulatory PMs for the specific fire extinguisher type will be forecasted on time						SC				
8	Equipment check	Check if all additional firefighting equipment (e.g. fire blanketis) available at the correct location, sealed & free from damage						SC				
9	Final Check	Check the O&M manual & local requirements (e.g. fire protection concept & building permit) and carry out additional required tasks						SC				

Change Log

Error - Entry for specified object not found on change log