Base Building Compliance Standards

Issued April 2024

Document owned and updated by:
Rob Gisby (EWARTGXR)
Benito Sanchez Sanchez de Puerta (BPPUERTA)
Leonardo Vitale (LEOVITAL)
Lara Leal Pino (LALEAL)

Important Compliance Standards information:

It`s the BBM vendor`s obligation to identify compliance gaps in all Compliance Standards to allocate maintenance & compliance costs correctly and to keep the serviced site safe.
The Compliance Standards are just a guide and not an exhaustive list of regulatory requirements.

© Amazon.com. Not for use or disclosure outside Amazon without written permission.

Last Review Date	Release Notes	Document Author
Dic-2022	First publication of document.	ewartgxr / leovital
Sept-2023	Changed the document to the new format.	ewartgxr / leovital
Apr-2024	1. Changed the frequency of the PM EVID from 3M/6M to 12M. 2. Added missing systems in the previous version: CT.AIR.INDOOR, CT.ELEC.EMERGENCYAC, CT.REFR.FGAS. 3. Added missing regional statutes to the system, CT.WORK.GOODSMOVE. 4. CT.WATER.LEGIONELLA legislation was updated for Spain.	leovital / laleal

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Enclosed Space
APM Object	CT.AIR.ENCSPACE
APM Description	Cark parks, workshops and other enclosed spaces.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 6M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.BMS HVAC.AHU	**Related CT Areas:**	Not Specified		

Scope

All sites where ventilation systems are used as mechanical means of ventilation for enclosed areas, such as car parks, workshops or basements. Note designated “confined spaces” should be managed via site specific controls and are not covered by this standard.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer’s instructions and recommendations.	Maintenance of all ventilation systems (including fans, control systems, sensors, filters, vents, ducting, mounts etc)	Competent person	Inspection and examination records, reports or certificates. Risk assessment.	PM					EVID		
All		At least every 12 months. More frequent inspections might be required based on risk assessment and environmental setting/ usage.	Thorough inspection of all mechanical ventilation systems and infrastructure to ensure safe and correct operation, including hygienic and ventilation properties.	Competent person, normally outsourced	Inspection and examination records, reports or certificates. Risk assessment.	PM					EVID		
All		Based on risk assessment, but at least every 12 months.	Monitoring of key air quality parameters to ensure compliance with maximum exposure limits if necessary (i.e. max concentration of CO of 30ppm averaged over an 8-hour period).	Competent person	Inspection and examination records, reports or certificates. Risk assessment.	(PM)					EVID		
All		In accordance with manufacturer’s instructions and recommendations but at least every: * 12 months (non-flammable/explosive atmosphere) * 6 months (explosive	If installed, calibration of air quality sensors to correct fume/gas (e.g. CO sensor) to ensure correct operation.	Competent person, normally outsourced	Inspection and examination records, reports or certificates. Risk assessment.	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Act. No. 22/1997 Coll. ČSN 331600 Government Regulation No 378/2001 Coll.	Competent person, Review technician.	Inspections of equipment Revision of electrical components.
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung MPrüfVO - Muster-Prüfverordnung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln)	Competent person (befähigte Person).	Inspections must be carried out before first use, after modifications subject to mandatory testing. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment.
ES	Building Technical Code (CTE). Health Standards Basic Document (DB HS3 – Air Quality). Applicable on vehicle parking. RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections.	Competent person.	Regular maintenance in accordance with manufacturer's instructions.
FR	Arrêté du 8 octobre 1987 relatif au contrôle périodique des installations d'aération et d'assainissement des locaux de travail - Légifrance (legifrance.gouv.fr) Arrêté du 9 octobre 1987 relatif au contrôle de l'aération et de l'assainissement des locaux de travail pouvant être prescrit par l'agent de contrôle de l'inspection du travail mentionné à l'article L. 8112-1 du code du travail - Légifrance (legifrance.gouv.fr)	Competent and qualified person.	Every 12 months where recycled and non-recycled air is circulated. Every 6 months when only recycled air is circulated.
IT	Legislative Decree 9/04/2008 n.81 Decree 22/01/2008 n.37 UNI EN 16798-3:2018 (Functional requirements for ventilation systems) UNI 10339:1995 (Areaulic installations) UNI EN 15780:2011 (Pipework cleaning) UNI EN ISO 16890-1:2017 (Filters for ventilation systems)	Competent person.	Regular maintenance in accordance with manufacturer's instructions. The buyer is obliged to assign the work of installation, transformation, extension and ordinary and extraordinary maintenance of the systems to qualified companies. Filter's maintenance usually every 3 months, installation maintenance every 24 months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Regulation of the Minister of Labor and Social Policy on General health and safety regulations (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of the Minister of Interior and Administration of June 7, 2010 on fire protection of buildings, other construction facilities and areas (Journal of Laws 2010, number 109, item 719)	Competent or qualified person.	Inspections every 12 months. If within a potentially explosive atmosphere, every 6 months
ROI	Safety, Health and Welfare at Work Act 2005 S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 S.I. No. 78/2001 - Safety, Health and Welfare At Work (Carcinogens) Regulations, 2001. S.I. No. 619/2001 - Safety, Health and Welfare At Work (Chemical Agents) Regulations, 2001	Competent person, best practice to outsource to specialist.	Inspections of all ventilation systems to be conducted at least every 14 months.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 355/2007 Coll. on the protection, promotion and development of public health Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Ordinance No. 25/1984 Coll. on ensuring work-safety in low-pressure boiler rooms Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment.
UK	The Control of Substances Hazardous to Health Regulations 2002 The Workplace (Health, Safety and Welfare) Regulations 1992 EH40/2005 Workplace exposure limits Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993	Competent person, best practice to outsource to specialist	Thorough Examination of ventilation systems to be conducted at least every 14 months unless part of fire system when 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Indoor air quality
APM Object	CT.AIR.INDOOR
APM Description	Indoor air quality and associated air handling plant e.g. HVAC, ducting, control panels etc
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Air Roof Top Units Air Conditioning Units Air Conditioning	**Related CT Areas:**	Not Specified		

Scope

Any site where mechanical ventilation systems are installed to maintain workplaces adequately ventilated with sufficient quantity of fresh or purified air (not the removal of hazardous emissions). This includes air conditioning systems, humidifiers and mechanical fresh air ventilation systems, as well as the associated infrastructure (e.g. air ducts, grills, filters, etc.).
This standard excludes legionella, and extraction of hazardous air

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but minimum of every 6 months. Air intake and filters may need more frequent cleaning/replacement – particularly due to COVID 19	Ongoing regular maintenance and cleaning of all mechanical ventilation systems e.g. vents, filters, ducting, HVAC, fan motors, extraction and circulation systems	Competent person	Maintenance logbook	PM					EVID		
All	2	Based on risk assessment, but at least every 12 months.	Inspection of HVAC equipment to ensure correct and safe operation, and adequate air exchange. To include associated infrastructure after first installation and thereafter at regular intervals.	Competent person	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	3	Based on risk assessment and in the event of a change of use, conversion or renovation, or in the event of a complaint/grievance or failure of statutory threshold.	Undertake air quality monitoring (if necessary) of key parameters as identified by risk assessment (e.g. microbiological inspection, particulate matter, CO, bacteria and fungi, temperature, etc.).	Competent person	Inspection records, report or certificate. Risk assessment								3Y CT
ES	4	Every 12 months.	Indoor Air Quality Inspections according to UNE 100012 and UNE 171330 standards in buildings.	No additional requirements	No additional requirements						CT		
IT	5	Best practice is to conduct inspections at least every 6 months.	Maintenance of adiabatic humidification systems or humid climate.		Inspection records, report or certificate.	PM					EVID		

PL	6	Where operates all year test at least twice a year, once in the winter season (October-March) and once in the summer season (April-September).	Monitoring for a source that requires a permit to introduce gases or dust into the air	No additional requirements	Inspection records, report or certificate.					CT			

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Government Regulation No 378/2001	Manufacturer or person authorized by the manufacturer	Inspection of the device once every 12 months, keeping the workspace healthy and safe
DE	Betriebsicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln) DGUV Regel 109-002 – Arbeitsplatzlüftung – Lufttechnische Maßnahmen	Inspection and maintenance: competent person (befähigte Person) according to BetrSichV	Inspections must be carried out before first use, after modifications subject to mandatory testing. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2103 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. UNE 171330 standards in buildings. Indoor air quality (part 1, 2, 3). UNE 100012: 2005 Standard. Cleaning of ventilation and air conditioning systems.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years.
FR	Arrêté du 8 octobre 1987 relatif au contrôle périodique des installations d'aération et d'assainissement des locaux de travail - Légifrance (legifrance.gouv.fr) Arrêté du 9 octobre 1987 relatif au contrôle de l'aération et de l'assainissement des locaux de travail pouvant être prescrit par l'agent de contrôle de l'inspection du travail mentionné à l'article L. 8112-1 du code du travail - Légifrance (legifrance.gouv.fr)	Qualified person	Inspection conducted at least every 12 months.
IT	D.P.R. 16/04/2013, n. 74 Legislative Decree 13/08/2010 n.155 (Adoption of Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Legislative Decree 24/12/2012 n.250 (Changes and integrations to Legislative Decree no. 155 of August 13, 2010, implementing Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Legislative Decree 9/98/2008 n.81 Decree 10/02/2014 Decree 22/01/2008 n.37 (regulation on the reorganization of the provisions on the installation of systems inside buildings.)	Competent, qualified person	Periodic cleaning and maintenance in accordance with manufacturer's recommendations. Regular and periodic inspections. Filter's maintenance usually every 3 months, installation maintenance every 24 months.
PL	Regulation of the Minister of Labor and Social Policy of 26 September 1997 on general health and safety at work regulations (Journal of Laws 2003, number 169, item 1650) Regulation of the Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333) Regulation of the Minister of Health of 22 April 2005 on harmful biological agents for health in the work environment and protection of the health of workers professionally exposed to these factors (Journal of Laws 2005, number 81, item 716)	Qualified or competent person.	Initial test of the ventilation system after installation. Inspections and maintenance in accordance with manufacturer's recommendations.
ROI	Safety, Health and Welfare at Work Act 2005 S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007	Competent person, best practice to outsource to specialist.	Inspections of all ventilation systems to be conducted at least every 14 months.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 355/2007 Coll. on the protection, promotion and development of public health Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Qualified and certifiedperson, best practice to outsource to specialist.	Periodic maintenance every 5 years for AC with installed power of 70kW and more. Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment . Minimum safety and health requirements for the workplace.
UK	The Workplace (Health, Safety and Welfare) Regulations 1992 The Provision and Use of Work Equipment Regulations 1998 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource to specialist.	Periodic maintenance of equipment in accordance with manufacturer's recommendations. Inspection frequency based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Local exhaust ventilation
APM Object	CT.AIR.LEV
APM Description	Local Exhaust Ventilation systems.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

All sites where Local Exhaust Ventilation systems are used as individual mechanical means of ventilation for activities, processes or areas that are likely to produce fumes, smoke, gas or air emissions which may be toxic or harmful if inhaled/exposed, including those mounted to machinery, mobile units and fixed units.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Maintenance of all LEV systems	Competent person	Maintenance logbook	PM					EVID		
All	2	At least every 12 months. More frequent inspections might be required based on risk assessment.	Inspection of all Local Exhaust Ventilation systems to ensure safe and correct operation, including hygienic and ventilation properties.	Competent person, normally outsourced	Inspection and examination records, reports or certificate. Risk assessment.	PM					EVID		
PL	3	At least every 6 months.	Inspections of LEV systems if it is within a potentially explosive atmosphere.	No additional requirements	No additional requirements					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Act No. 22/1997 Coll. ČSN 331600 Government Regulation No 378/2001 Coll.	Competent person, Review technician	Inspections of equipment Revision of electrical components

DE	Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln)	Competent person (befähigte Person)	Inspections must be carried out before first use, after modifications subject to mandatory testing. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment.
ES	Building Technical Code (CTE). Health Standards Basic Document (DB HS3 – Air Quality). RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2103 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 374/2001, of April 6, about health and safety protection on workers against risks related to chemical agents during worktime. Technical Guide for the evaluation and prevention of risks related to the exposure of chemical agents on workplaces. Prevention Technical Note NTP 742. General ventilation on buildings. Prevention Technical Note NTP 741. General ventilation by dilution.	Competent person.	Maintenance and inspections conducted at least every 12 months.
FR	No additional requirements	N/A	No additional requirements.
IT	Legislative Decree 13/08/2010 n.155 (Adoption of Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Legislative Decree 24/12/2012 n.250 (Changes and integrations to Legislative Decree no. 155 of August 13, 2010, implementing Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Decree 10/02/2014 Decree 22/01/2008 n.37 Legislative Decree 9/04/2008 n.81 Legislative Decree 3/04/2006 n.152 Directive 2006/42/EC	Competent person.	Regular maintenance in accordance with manufacturer's instructions. Inspections at least every 12months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of 26 September 1997 of Minister of Labor and Social Policy on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 12 April 2002 of Minister of Infrastructure on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 27 April 2001 on environmental law (Journal of Law 2020, item 1219) Regulation of Minister of the Environment of August 24, 2012 on the levels of certain substances in the air (Journal of Laws 2021, item 845) Regulation of Minister of Environment of 2 July 2010 on the types of installations the operation of which requires notification (Journal of Laws 2019, item 1510)	Competent or qualified person	Inspections every 12 months. If within a potentially explosive atmosphere, every 6 months.
ROI	Safety, Health and Welfare at Work Act 2005 S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 S.I. No. 78/2001 - Safety, Health and Welfare At Work (Carcinogens) Regulations, 2001. S.I. No. 619/2001 - Safety, Health and Welfare At Work (Chemical Agents) Regulations, 2001 S.I. No. 572/2013 - Safety, Health and Welfare at Work (Biological Agents) Regulations 2013.	Competent person, best practice to outsource to specialist.	Inspections of all LEV to be conducted at least every 14 months.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Ordinance No. 94/2004 Coll. on technical requirements for fire safety during construction and use of buildings Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions or technical norm. Inspections based on standardized testing of selected technical equipment.
UK	The Control of Substances Hazardous to Health Regulations 2002 Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003	Competent person, best practice to outsource to specialist.	Thorough Examinations of all LEV to be conducted at least every 14 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Earthing and electrical discharging
APM Object	CT.ELEC.DISCHARGE
APM Description	Earthing and electrical discharging systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.EARTHING	**Related CT Areas:**	Not Specified		

Scope

Any site with an electrical installation. Inspection of the earthing and electrical discharging systems is mandatory as part of the inspection of the electrical installation as a whole.
Inspection requirements of electrical installations are covered under Compliance Standard CT.ELEC.ELECINST

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's and vendor's instructions and recommendations.	Routine maintenance of all electrical equipment and infrastructure	Competent person (e.g. Electrician accredited by NICEIC, ECA or SELECT.)	Maintenance logbook.	PM					EVID		
All	2	Inspection frequency based on type of installation or equipment, its use and operating conditions (risk assessment). It is generally part of the inspection of the electrical installation as a whole (see "Compliance HV inspection and	Thorough inspection of earthing and electrical discharging systems.	Competent person (Electrician accredited by NICEIC, ECA or SELECT.)	Inspection report, records or certificate Risk assessment	PM					EVID		
CZ	3	No additional requirements	Inspections as per [1] and [2].	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					EVID		
CZ	3	No additional requirements	Inspections as per [1] and [2].	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					EVID		
DE	4	Every 3 years	Additional inspection to comply with building regulations (testing for effectiveness and operational safety).	Expert according to state building law.	No additional requirements								3 year CT

DE	5	Based on insurance contract	Additional inspection (VdS-check) of HV installations and equipment for insurance cover purposes (fire risk).	VdS-approved electrical expert.	Periodic examination certificates VdS 2229								
ES	9	At least annual inspections when the soil is dryer	Inspection as per [2]	No additional requirements	No additional requirements	(PM)					EVID		
FR	6	Annual inspections.	Annual check to ensure electrical continuity and earthing efficiency.	No additional requirements	No additional requirements	(PM)					EVID		
FR	6	Annual inspections.	Annual check to ensure electrical continuity and earthing efficiency.	No additional requirements	No additional requirements	(PM)					EVID		
ROI	7	No additional requirements	Inspection as per [2]	No additional requirements	HV equipment register Schematic drawings of installation. Switchgear labelled.	(PM)					EVID		
UK	8	No additional requirements	Inspection as per [2]	No additional requirements	HV equipment register Schematic drawings of installation. Switchgear labelled.	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., Decree 50/1978 ČSN 331500, ČSN 332000-6 ed. 2, ČSN EN 62305, ČSN 332570, ČSN 332000, , ČSN 331600.ed.2	Competent, trained review technician	Frequency determined by the Protocol on the determination of external influences, between 6 and 60months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Vorschrift 3 (§5) - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel DIN VDE 0105-100 - Betrieb von elektrischen Anlagen DIN VDE 0100-600 VDE 0100-600:2017-06 - Errichten von Niederspannungsanlagen Teil 6: Prüfungen	Qualified electrician (Elektrofachkraft) An independent VdS-approved competent person for fire-safety insurance inspection.	Inspection must be conducted before first use and after any modification or repair to electrical installations or other conductive components of the building. Additional inspection and testing for effectiveness and operational safety in accordance with building regulations, at least every 3 years. Annual inspection of electrical installations for fire-safety insurance, preferably in the first 3 months of each insurance year.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions. ITC-BT-18. Earthing and electrical discharging. ITC-RAT-13. Earthing and electrical discharging.	Accredited company (OCA) by ENAC.	At least annual inspections when the soil is dryer.
FR	Labour Code Art . R . 4226-16, R . 4226-17, R . 4226-19 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000022761568/#LEGISCTA000022765074 26th December 2011 Decree about electrical installations verification "Arrêté du 26 décembre 2011 relatif aux vérifications ou processus de vérification des installations électriques ainsi qu'au contenu des rapports correspondants" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000025046978/#:~:text=Le%20pr%C3%A9sent%20arr%C3%AAt%C3%A9%20fixe%20%3A,14%20du%20code%20du%20travail%20%3B&text=%E2%80%95%20les%20m%C3%A9thodes%2C%20l'%C3%A9tendue%20et%2C%20le%20cas%20%C3%A9ch%C3%A9a	Accredited organisation or employee who is qualified or trained.	Annual inspection
IT	Legislative Decree 8/04/2008 n.81 DPR 462/01 DM 22/01/2008 n.37 CEI EN 50110-1 (Operation of electrical installations) CEI 11-27 (Work on electrical installations) CEI 0-14 (Guidelines for application of DPR 462/01) CEI 64-14 (Guidelines for electrical installations inspections)	National authorities (ASL, ARPA) or accredited inspection organization	Routine maintenance. Grounding system inspection every 5 years after first putting into service, or every 2 if there is a risk of fire according to DPR 151/11.

PL	Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333) Act of 29 August 2014 on the energy performance of buildings (Journal of Laws 2021, item 497) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy	Qualified or competent person	Inspection frequency depends on manufacturers or vendor recommendations, but at least every 5 years.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI 5th Edition National Rules for Electrical Installations, IS 10101:2020 on 6 March 2020	Competent and qualified electrician, approved by RECI or ECSSA.	Routine maintenance. Frequency of inspection and testing depends on the type of installation, its use and operation, but at least every 3 to 5 years.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 314/2001 Coll. on fire prevention Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified & certified person.	Once a year in case of complex inspection. Otherwise quarterly monthly or daily.
UK	The Electricity at Work Regulations 1989 (legislation.gov.uk) Approved code of practice BS 6626:1985 - Maintenance of Electrical Switchgear and Control gear for Voltages above 1 kV and up to and including 36 kV. BS 7671 / IET Wiring Regulations Keeping electrical switchgear safe HSG230 (hse.gov.uk) Electrical switchgear safety: A guide for owners and users (hse.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Registered electrician, approved by NICEIC, ECA or SELECT.	Routine maintenance. Inspection frequency of LV, MV and HV installation and/or equipment based on type of installation or equipment, its use and operating conditions, but at least every 3 (industrial premises) to 5 years (commercial premises).

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Electrical Installations
APM Object	CT.ELEC.ELECINST
APM Description	HV and LV wiring, switchgear, transformers and associated environments. Where sites have photovoltaic systems, items outside the scope of CT.ELEC.PHOTOV such as inverters and protection relays should be considered under this standard and/or CT.ELEC.FIXEDWIRE as appropriate.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LEC.LV.BSBR ELEC..LV.CABS ELEC.HV.SWITCHGEAR ELEC.LV.PFC	**Related CT Areas:**	Not Specified		

Scope

Any site with an electrical installation. CEN and CENELEC standards define incoming electricity at:
Less than 1 kV - low voltage installations
More than 36 kV - high voltage
However, EU RME simplifies to LV < 1 kV AC and HV ≥ 1 kV AC.
Between 1 kV and 36 kV - medium voltage installation

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's and vendor's instructions and recommendations.	Routine maintenance of all electrical equipment and infrastructure	Competent, trained and certified vendor.	Maintenance logbook	PM					EVID		
All	2	Inspection frequency based on type of installation or equipment, its use and operating conditions (risk assessment), but at least every 3 to 5 years.	Thorough inspection of low voltage installations and equipment, including circuit breakers, interlocks, cover shutter devices, insulation, earthing, heating and lighting, testing, etc.	Competent, trained and certified vendor.	Inspection report, records or certificate. Risk assessment	PM					EVID		
All	3	Inspection frequency based on type of installation or equipment, its use and operating conditions (risk assessment), but at least every 3 to 5 years.	Thorough inspection of medium voltage installations and equipment, including circuit breakers, interlocks, cover shutter devices, insulation, earthing, heating and lighting, testing, etc.	Competent, trained and certified vendor.	Inspection report, records or certificate. Risk assessment	PM					EVID		
All	4	Inspection frequency based on type of installation or equipment, its use and operating conditions (risk assessment), but at least every 3 to 5 years.	Thorough inspection of high voltage installations and equipment, including circuit breakers, transformers, substations, busbars, insulation, earthing, switchgear, testing, etc.	Competent, trained and certified vendor.	Inspection report, records or certificate. Risk assessment	PM					EVID		
CZ	5	No additional requirements	Inspections as per [2], [3], and [4].	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					EVID		

DE	6	Every 3 years	Additional inspection to comply with building regulations (testing for effectiveness and operational safety).	expert according to state building law.	No additional requirements	(PM)					EVID		
DE	7	Based on insurance contract	Additional inspection (VdS-check) of HV installations and equipment for insurance cover purposes (fire risk)	VdS-approved electrical expert.	Periodic examination certificates VdS 2229	(PM)					EVID		
FR	8	Annual inspections.	Inspection as per [2], [3] and [4].	No additional requirements	No additional requirements	(PM)					EVID		
ROI	9	No additional requirements	Inspection as per [4]	No additional requirements	HV equipment register Schematic drawings of installation. Switchgear labelled.	(PM)					EVID		
UK	10	No additional requirements	Inspection as per [4]	No additional requirements	HV equipment register Schematic drawings of installation. Switchgear labelled.	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent electrician. Review technician.	Frequency determined by the Protocol on the list of external influences, between 6 and 60months.
DE	DGUV Vorschrift 3 (§5) - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel DIN VDE 0105-100 - Betrieb von elektrischen Anlagen DIN VDE 0100-600 VDE 0100-600:2017-06 - Errichten von Niederspannungsanlagen Teil 6: Prüfungen VdS 2871 - Richtlinien für die Prüfung elektrischer Anlagen - Prüfrichtlinien nach Klausel SK 3602 - Hinweise für den anerkannten Elektrosachverständigen insurance contract	Qualified electrician (Elektrofachkraft).	Inspection must be conducted before first use and after any modification or repair. Inspection frequency based on risk assessment, but at least every 4 years for electrical installations and fixed electrical equipment, and every 6 - 24 months for electrical installations and mobile electrical equipment in special types of premises according to DGUV 4. Monthly functional inspection of residual current, mobile devices. Functional test of the residual and differential current, and residual voltage circuit breakers by user: daily for mobile equipment and every 6 months for fixed equipment.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions.	Accredited company (OCA) by ENAC.	Low voltage Inspections and testing at least every 5 years. HV inspections and testing to be conducted at least every 3 years.
FR	Section 5 : Vérification des installations électriques (Articles R4226-14 à R4226-21) - Légifrance (legifrance.gouv.fr) Arrêté du 26 décembre 2011 relatif aux vérifications ou processus de vérification des installations électriques ainsi qu'au contenu des rapports correspondants - Légifrance (legifrance.gouv.fr)	Accredited organisation or employee who is qualified or trained.	Annual inspection
IT	Legislative Decree 8/04/2008 n.81 DPR 462/01 DM 22/01/2008 n.37 CEI EN 50110-1 (Operation of electrical installations) CEI 11-27 (Work on electrical installations) CEI 0-14 (Guidelines for application of DPR 462/01) CEI 64-14 (Guidelines for electrical installations inspections) CEI EN 60079-17 (Electrical installations maintenance for ATEX) CEI O-10 (Guidelines for maintenance) CEI 0-15 (Maintenance for medium voltage installations)	Competent person. Except for grounding systems inspection: National authorities (ASL, ARPA) or accredited inspection organization.	Routine maintenance. Grounding system inspection every 5 years after first put into service, or every 2 if there is a risk of fire. Electrical systems inspection every 5 years, or every 2 if there is a risk of fire.
PL	Act of 7 July 1994 of Construction Law (Journal of Laws 2020, item 1333) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065) Act of 29 August 2014 on the energy performance of buildings (Journal of Laws 2021, item 497) Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348). Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828). Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830).	Qualified or competent person	Inspection frequency depends on manufacturer's or vendor recommendations, but at least every 5 years.

ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI 5th Edition National Rules for Electrical Installations, IS 10101:2020 on 6 March 2020.	Competent and qualified electrician, approved by RECI or ECSSA.	Routine maintenance. Frequency of inspection and testing depends on the type of installation, its use and operation, but at least every 3 to 5 years.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 314/2001 on fire prevention Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified & certified person	Once a year in case of complex inspection. Otherwise quarterly, monthly, or daily.
UK	The Electricity at Work Regulations 1989 (legislation.gov.uk) Approved code of practice BS 6626: 1985 - Maintenance of Electrical Switchgear and Control gear for Voltages above 1 kV and up to and including 36 kV. BS 7671 / IET Wiring Regulations Keeping electrical switchgear safe HSG230 (hse.gov.uk) Electrical switchgear safety: A guide for owners and users (hse.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Registered electrician, approved by NICEIC, ECA or SELECT.	Routine maintenance. Inspection frequency of LV, MV and HV installation and/or equipment based on type of installation or equipment, its use and operating conditions, but at least every 3 (industrial premises) to 5 years (commercial premises)

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Emergency Lighting systems
APM Object	CT.ELEC.EMERGENCYAC
APM Description	Emergency lighting system and associated infrastructure.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LIGHT.SAFETY	**Related CT Areas:**	Not Specified		

Scope

Any site where an emergency lighting system (including battery) is installed to aid safety in the event of power failure and/or safe evacuation of the site in emergency situations.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance and cleaning of equipment.	Competent person, usually internally sourced.	Maintenance logbook.	PM					EVID		
All	2	At least monthly, but more frequent inspections might be needed based on risk assessment.	Flick test, consisting of a mains power interruption to check correct operation of lighting	Competent person	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	3	Based on risk assessment, but at least every 6 months.	Functional inspection of the entire emergency lighting system.	Competent person (e.g. Registered Electrician). Generally outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	4	At least every 12 months, but more frequent inspections might be needed based on risk assessment.	Discharge test to be conducted, consisting of mains power interruption to assess the duration of the batteries under emergency situations.	Competent person (e.g. Registered Electrician). Generally outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	5	In accordance with manufacturer's recommendations and instructions, but at least every 12 months.	Servicing of emergency lighting system, include inspection of the overall condition, readiness and marking of the equipment, completeness, integrity and functionality of the equipment, and the state of the alternative source of electricity.	Competent person (e.g. Registered Electrician). Generally outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		

DE	6	Every 3 years	Metering of illuminance of safety lighting according to DIN EN 1838	No additional requirements	If automatic equipment is used, record and keep the results of the rated endurance test.								3 Year CT
DE	7	Every 3 years	Inspection conducted by expert in accordance with building regulations.	Expert according to building law. Certification is necessary.	No additional requirements								3 Year CT
DE	8	In accordance with manufacturer's instructions and operating conditions. Generally 6-12 months.	Regular functional and safety inspection of batteries and its operating environment.	No additional requirements	No additional requirements	(PM)					EVID		
FR	9	At least every 6 months.	Inspection as per [1], [2], [3] & [4]. Discharge test (1 hour mini.)	No additional requirements	No additional requirements.	(PM)					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree No. 246/2001 Coll. EN 1838, EN 50172 ČSN 73 0802 ČSN 73 0804 ČSN 33 2000-6	Competent person, qualified electrician	Test carried out monthly. Full discharge test at least every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regeln für Arbeitsstätten ASR 3.4/7 - Sicherheitsbeleuchtung, optische Sicherheitsleitsysteme DIN EN 50172 VDE 0108-100 – Sicherheitsbeleuchtungsanlagen DIN EN 1838:2019-11 - Angewandte Lichttechnik - Notbeleuchtung	Competent person (befähigte Person), qualified electrician (Elektrofachkraft).	Before building/facility is used for the first time, immediately after any modifications to the building or installation, and at least every 3 years.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. ITC-BT-09. Emergency lighting system. DB- SUA4 – CTE (Construction Technical Code- Safety Using Basic Document number 4 – section 2). UNE-EN 60.598-2-22 and UNE 20.392 o UNE 20.062	Accredited company (OCA) by ENAC.	Functional test to be conducted monthly. Discharge test conducted annually. Emergency lighting servicing to take place every 5 years.
FR	Labor Code Article R4226-7 & R4226-16 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000022765084/ https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000022765070/ 14th December 2011 Ministerial Order on emergency lighting system "Arrêté du 14 décembre 2011 relatif aux installations d'éclairage de sécurité" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000025055364/	Qualified person	Flick test conducted monthly. Discharge test conducted every 6 months. Servicing of emergency lighting systems at least annually.
IT	UNI CEI 11222:2013 (Maintenance) UNI EN 1838:2013 (Emergency lighting) CEI EN 60598-2-22/EC (Illumination systems- special applications: emergency systems) CEI EN 50172 (Emergency illumination systems) Legislative Decree 9.04.2008 n° 81 DPR 151/2011 DM 10/03/98 Decree 22/01/08 n.37	Competent person.	Functional check to be conducted every 6 months. Full discharge test to be conducted at least every 12 months (Autonomy verification). Emergency lighting servicing at least every 6 months.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333)	Qualified or competent person.	Test conducted weekly/monthly. Full discharge test in accordance with manufacturer's instructions but at least every 12 months. Servicing of the lighting system at least every 12 months.
ROI	Safety, Health and Welfare at Work (General Application) Regulations 2007 to 2012	Competent, electrician registered on RECI or ECSSA.	Daily visual checks. Flick test to be conducted every 3 months. Functional test of the entire system to be conducted at least every 6 months. Full discharge test to be conducted at least every 12 months.

SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 121/2002 Coll. on fire prevention Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Government Regulation No. 387/2006 Coll. on requirements for ensuring safety and health marking at work	Qualified and certified person	If the complex inspection is realized on an annual basis, more frequent (and less complex) checks are not necessary.
UK	The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) BS5266-8:2004 / BS EN 50172:2004 Emergency escape lighting systems	Competent, registered electrician on the Electrical Safety Register (NICEIC, ECA, SELECT	Weekly checks. Flick test to be conducted monthly. Functional test of the entire system to be conducted at least every 6 months. Full discharge test to be conducted at least every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fixed wiring
APM Object	CT.ELEC.FIXEDWIRE
APM Description	Fixed wiring, including all the equipment required to distribute electrical power safely from the origin to all the plant, equipment and appliances at the relevant site (e.g. conductors, distribution boards, switching devices, protective devices, enclosures, etc. Where sites have photovoltaic systems, items outside the scope of CT.ELEC.PHOTOV such as inverters and protection relays should be considered under this standard and/or CT.ELEC.ELECINST as appropriate.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	BLDG.EARTHING - ELEC.LV.CABS - ELEC.LV.BSBR - ELEC.HV.SWITCHGEAR - ELEC.UPS -ELEC.GEN - ELEC.LV.PFC - ELEC.LV.SWITCHGEAR	**Related CT Areas:**	CT.ELEC.ELECINST		

Scope

Any site with an electrical installation. Fixed wiring inspections are mandatory as part of a comprehensive inspection of any electrical installation.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's and vendor's instructions and recommendations.	Routine maintenance of all electrical equipment and infrastructure.	Competent person (Accredited Electrician on the Electrical Safety Register e.g. NICEIC, ECA, SELECT)	Maintenance logbook	PM					EVID		
All	2	Frequency based on risk assessment (type of installation, use and operating conditions). Generally, fixed wiring inspections are part of the inspections of the electrical installation as a whole (see "Compliance HV inspection and	Thorough inspection of fixed wiring, including conductors, distribution boards, switching devices, protective devices, enclosures, etc.	Competent person (Accredited Electrician on the Electrical Safety Register e.g. NICEIC, ECA, SELECT)	Inspection report, records or certificate. Risk assessment	(PM)					(EVID)		
CZ	3	No additional requirements	Inspections as per [2]	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					(EVID)		
DE	4	Every 3 years	Additional inspection to comply with building regulations (testing for effectiveness and operational safety).	Expert according to building law	No additional requirements								3Y CT
DE	5	Based on insurance contract	Additional inspection (VdS-check) of HV installations and equipment for insurance cover purposes (fire risk).	VdS-approved electrical expert.	Periodic examination VDS certificates						CT*		

ROI	6	No additional requirements	Inspection as per [2]	No additional requirements	HV equipment register. Schematic drawings of installation. Switchgear labelled.	(PM)					(EVID)		
SK	7	Every two years in case of movable object	Inspection as per [2].	No additional requirements	No additional requirements	(PM)					(EVID)		
UK	8	No additional requirements	Inspection as per [2]	No additional requirements	HV equipment register. Schematic drawings of the installation. Switchgear labelled.	(PM)					(EVID)		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6and 60months.
DE	DGUV Vorschrift 3 - Elektrische Anlagen und Betriebsmittel DIN VDE 0105-100 - Betrieb von elektrischen Anlagen DIN VDE 0100-600 VDE 0100-600:2017-06 - Errichten von Niederspannungsanlagen Teil 6: Prüfungen VdS 2871 - Richtlinien für die Prüfung elektrischer Anlagen - Prüfrichtlinien nach Klausel SK 3602 - Hinweise für den anerkannten Elektrosachverständigen insurance contract	Qualified electrician (Elektrofachkraft).	Inspection frequency based on risk assessment, but at least every 4 years for electrical installations and fixed electrical equipment. Functional test of the residual and differential current, and residual voltage circuit breakers by user: daily for mobile equipment and every 6 months for fixed equipment. Annual inspection of electrical installations for fire-safety insurance, preferably in the first 3 months of each insurance year.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions.	Accredited company (OCA) by ENAC.	Low voltage Inspections and testing at least every 5 years. HV inspections and testing to be conducted at least every 3 years.
FR	N/A	N/A	N/A
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 CEI 64-14 (Guidelines for electrical installations inspections) CEI EN 60079-17 (Electrical installations maintenance for ATEX) CEI O-10 (Guidelines for maintenance) CEI 0-15 (Maintenance for medium voltage installations) CEI 78-17 (Maintenance for medium voltage installations) CEI 64-8/3 (Electric installations under 1000V- general information) CEI 64-8/6 (Electric installations under 1000V-Inspections) CEI 64-8/7 (Electric installations under 1000V-special applications)	Competent person.	Routine maintenance. Electrical systems inspection usually every 5 years, or every 2 if there is a risk of fire.
PL	Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333) Regulation of the Minister of Energy of 28 August 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	Qualified or competent person	Inspection frequency depends on manufacturer's or vendor recommendations, but at least every 5 years.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI 5th Edition National Rules for Electrical Installations, IS 10101:2020 on 6 March 2020.	Competent and qualified electrician, approved by RECI or ECSSA.	Routine maintenance. Frequency of inspection and testing depends on the type of installation, its use and operation, but at least every 3 to 5 years.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified & certified person	Twice per year in case of temporary installations. Other installations are less frequent.

UK	The Electricity at Work Regulations 1989 (legislation.gov.uk) Approved code of practice BS 6626 : 1985 - Maintenance of Electrical Switchgear and Control gear for Voltages above 1 kV and up to and including 36 kV. BS 7671 / IET Wiring Regulations Keeping electrical switchgear safe HSG230 (hse.gov.uk) Electrical switchgear safety: A guide for owners and users (hse.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Registered electrician, approved by NICEIC, ECA or SELECT.	Routine maintenance. Inspection frequency of LV, MV and HV installation and/or equipment based on type of installation or equipment, its use and operating conditions, but at least every 3 (industrial premises) to 5 years (commercial premises).

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	General lighting
APM Object	CT.ELEC.LIGHTING
APM Description	Indoor and outdoor lighting systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LIGHT.EXT LIGHT.INT	**Related CT Areas:**	Not Specified		

Scope

All sites with indoor and/or outdoor lighting systems.
Inspection requirements of the electrical installation of which the indoor/outdoor lighting system is part of is covered under Compliance Standard CT.ELEC.ELECINST

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's and vendor's recommendations and instructions	Routine maintenance of all lighting systems (cleaning, repairing or replacing and disposing of lamps/luminaires).	Competent person	Maintenance logbook	PM					EVID		
All		Based on risk assessment	Check of correct illuminance for the specific tasks being undertaken in each area.	Competent person	Inspection records. Risk assessment	PM					EVID		
All		Based on risk assessment	Routine inspection to assess health and safety risks arising from incorrect lighting systems (e.g. glare, flickers, etc.)	Competent person	Inspection records. Risk assessment	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60 months.

DE	Technische Regeln für Arbeitsstätten: ASR A3.4 - Beleuchtung Betriebssicherheitsverordnung (BetrSichV) DGUV Vorschrift 3 - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel	Qualified electrician (Elektrofachkraft).	Inspection intervals determined based on risk assessment and manufacturer recommendations.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. ITC-BT-44. Lighting system receivers. DB- SUA4 – CTE (Construction Technical Code- Safety Using Basic Document number 4 – section 2).	Competent person	Routine maintenance and inspections based on risk assessment.
FR	Labour Code Art. R4223-4 relating to lighting conditions https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018532265	N/A	N/A
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 UNI EN 12464-1:2011 (Lighting at work-internal) UNI EN 12464-2:2014 (Lighting at work-external)	Competent person	Maintenance and inspection every 5 years, or every 2 if there is a risk of fire.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	Competent person	Routine maintenance and inspections based on risk assessment, at least every 5 years.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) untitled (hsa.ie)	Competent person	Routine maintenance and inspections based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Competent person	At least annually. In case of significant dust sediments, at least two times or four times per year.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Electricity at Work Regulations 1989 (legislation.gov.uk) BS 7671 / IET Wiring Regulations Lighting at work - HSG38 (hse.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Competent person	Routine maintenance and inspections based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Lightning protection
APM Object	CT.ELEC.LIGHTNING
APM Description	Lightning protection systems.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	BLDG.LIGHTNING	**Related CT Areas:**	CT.ELEC.ELECINST - CT.ELEC.EMERGENCYAC - CT.ELEC.POWERGENERATOR - CT.ELEC.UPS		

Scope

Any site with an electrical installation. Inspection of the earthing and electrical discharging systems is mandatory as part of the inspection of the electrical installation as a whole.
More than 36 kV - high voltage
However, EU RME simplifies to LV < 1 kV AC and HV ≥ 1 kV AC.
Any site where an emergency lighting system (including battery) is installed to aid safety in the event of power failure and/or safe evacuation of the site in emergency situations.
Inspection requirements of electrical installations are covered by "Compliance HV inspection and test", "High/Medium Voltage" and "Low Voltage" Standards.
Any site with an electrical installation. CEN and CENELEC standards define incoming electricity at:
Less than 1 kV - low voltage installations
Between 1 kV and 36 kV - medium voltage installation
Any site where diesel power generators are commissioned to produce electricity, generally as a back-up in emergency situations. This includes all diesel generators, whether stationary or mobile.
This Compliance Standard only covers the inspection requirements associated with the electrical components of diesel generators. The maintenance of a UPS is covered in CT.ELEC.UPS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance and cleaning of lightning protection systems and associated infrastructure.	Competent person (Accredited Electrician on the Electrical Safety Register e.g. NICEIC, ECA, SELECT)	Maintenance logbook	PM					EVID		
All	2	At least every 12 months. More frequent inspections might be required based on risk assessment and operating conditions.	Regular thorough inspections to assess the integrity and operation of the lightning protection systems (e.g. visible damage due to lightning strikes, integrity of all elements, continuity of conductors, corrosion, etc.)	Competent person (Accredited Electrician on the Electrical Safety Register e.g. NICEIC, ECA, SELECT)	Inspection records. Risk assessment	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., Decree. 50/1978 ČSN 331500, ČSN 332000-6 ed. 2, ČSN EN 62305, ČSN 332570, ČSN 332000, , ČSN 331600.ed.2,	Competent, trained review technician	Light conductor checks carried out every 5 years before 2009 and post-2009 inspections for 4 years. In hazardous areas, the frequency is reduced to 2 years. Visual inspection to be carried out between checks (1 or 2 years) Frequency determined by the Protocol on the determination of external influences, 6 and 60months.
DE	VdS-Richtlinie 2010 - Risikoorientierte Blitz- und Überspannungsschutz DIN EN 62305-3 VDE 0185-305-3 – Beiblatt 3 - Zusätzliche Informationen für die Prüfung und Wartung von Blitzschutzsystemen Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) §4 (3) Respective law of the federal state with reference to the building permit	Qualified electrician and lightning protection expert (Blitzschutz-Fachkraft). Additional inspection: expert according to building law, certificate necessary.	Before initial commissioning, after extensions or modifications to the building, after lightning strikes. Protection classes I and II require visual inspections yearly and extended inspection every 2 years, while classes III and IV require visual inspection every 2 years and extended inspections every 4. More frequently in case of a critical event or based on risk assessment. Additional inspection based on building law.

ES	UNE 21.186: 2011 standard DB- SUA8 – CTE (Construction Technical Code- Safety Using Basic Document number 8 – lightning protection).	Qualified technician.	Regular maintenance. Inspections conducted at least every 12 months.
FR	Ministerial Order of October 4th, 2010 Article 16 to 23 https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023081900/	Qualified organism	Visual inspection every year and full inspection every 2 years.
IT	Legislative Decree 8/04/2008 n.81 DPR 462/01 DM 22/01/2008 n.37 CEI EN 50110-1 (Operation of electrical installations) CEI 11-27 (Work on electrical installations) CEI 81-2 (Guidelines for lightning protection systems inspection) CEI EN 62305-4/EC (Maintenance)	National authorities (ASL, ARPA) or accredited inspection organization.	Regular maintenance. Inspections every 5 years after putting into service, or every 2 years if the building is at risk of fire according to DPR 155/11.
PL	Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	Qualified or competent person. Authorised by Construction Law.	General inspection conducted every 12 months. Testing every 5 years.
ROI	Safety, Health and Welfare at Work (General Application) Regulations 2007 The NSAI - IS 10101:2020 on 6 March 2020	Competent person approved by RECI or ECSSA.	Test and inspection for lightning and earth protection at least ever 12 months. Recommended every 11 months to cover every month over a 12 year period
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Ordinance No. 94/2004 Coll. laying down technical requirements for fire safety in the construction and use of buildings	Qualified and certified person	Protection systems level I and II require a visual inspection yearly and a functional inspection and testing every 2 years. Protection systems level III and IV require visual inspection yearly and a functional inspection and testing every 4 years.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Electricity at Work Regulations 1989 (legislation.gov.uk) BS 7671 / IET Wiring Regulations Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk) BS EN 62305-3 Protection Against Lightning BS 7430 Code of Practice for Earthing	Electrician registered on the Electrical Safety Register. Approved by NICEIC, ECA or SELECT.	Test and inspection for lightning and earth protection at least ever 12 months. Recommended every 11 months to cover every month over a 12 year period.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Portable Appliance Testing
APM Object	CT.ELEC.PAT
APM Description	Portable Appliances
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where Portable Appliances are used. This includes hand-held and moveable equipment, such as computers, photocopiers, kitchen equipment, floor cleaners, hand-held or moveable power tools, etc.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendations.	Regular maintenance of all portable appliances	Competent person	Maintenance logbook						CT		
All		Frequency determined by risk assessment (type of equipment, frequency of use and operating conditions) of each individual appliance. Additionally, following any repair or modification.	Visual checks to assess whether the appliance is suitable for its intended use, including any use changes, damages to the appliance, cables or plug, any previously reported issues, earthing, etc. If any defects are identified, prevent subsequent use through quarantine prior to repair or destruction – do Not use. Report issue.	Competent person	Inspection records. Risk assessment						CT		
All		Frequency determined by risk assessment (type of equipment, frequency of use and operating conditions) of each individual appliance. Additionally, following any repair or modification.	Inspection and testing of portable appliances (PAT) to check correct polarity of supply cables, correct fusing, any potential loss of earth integrity, deterioration of insulations or contamination of surfaces, suitability of the equipment for its intended use. If any defects are identified, prevent subsequent use through quarantine prior to repair or destruction – do Not use. Report issue	Competent person	Inspection records. Risk assessment								
All		In accordance with manufacturer's instructions and recommendations.	Regular maintenance of all portable appliances	Competent person	Maintenance logbook						CT		
All		Frequency determined by risk assessment (type of equipment, frequency of use and operating conditions) of each individual appliance. Additionally, following any repair or modification.	Visual checks to assess whether the appliance is suitable for its intended use, including any use changes, damages to the appliance, cables or plug, any previously reported issues, earthing, etc. If any defects are identified, prevent subsequent use through quarantine prior to repair or destruction – do Not use. Report issue.	Competent person	Inspection records. Risk assessment						CT		

All		Frequency determined by risk assessment (type of equipment, frequency of use and operating conditions) of each individual appliance. Additionally, following any repair or modification.	Inspection and testing of portable appliances (PAT) to check correct polarity of supply cables, correct fusing, any potential loss of earth integrity, deterioration of insulations or contamination of surfaces, suitability of the equipment for its intended use. If any defects are identified, prevent subsequent use through quarantine prior to repair or destruction – do Not use. Report issue	Competent person	Inspection records. Risk assessment						CT		
IT	6	No additional requirements	No additional requirements	No additional requirements	CE Declaration of Conformity								
SK	5	Group A: Inspection before every lease. Group B: Once per three months (III.: Once per six months). Group C: Once per six months (I.), Once per 12 months (II.), Depends on their function (III.). Group D: Once per twelve months (III.: Depends on their	Inspection requirements depend on the way how appliances are used.	No additional requirements	No additional requirements					CT*	CT*	CT*	On demand EVID
SK	5	Group A: Inspection before every lease. Group B: Once per three months (III.: Once per six months). Group C: Once per six months (I.), Once per 12 months (II.), Depends on their function (III.). Group D: Once per twelve months (III.: Depends on their	Inspection requirements depend on the way how appliances are used.	No additional requirements	No additional requirements								

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 73/2010 Coll., ČSN 33 1600 ed.2, Decree No. 50/1978 Coll.	Review technician	Frequency depends on type of space, equipment and type of insulation, between 6 and 24 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Vorschrift 3 - Elektrische Anlagen und Betriebsmittel DIN VDE 0105-100 - Betrieb von elektrischen Anlagen	Qualified electrician (Elektrofachkraft).	Frequency of inspections based on risk assessment (type, use and failure rate). If failure rate is <2%: - yearly on construction sites, manufacturing plants, etc. - 2 yearly in offices.
ES	RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment.	Competent person	Maintenance in accordance with manufacturer's instructions. Regular Inspections and tests where appropriate.
FR	Arrêté du 26 décembre 2011 relatif aux vérifications ou processus de vérification des installations électriques ainsi qu'au contenu des rapports correspondants - Légifrance (legifrance.gouv.fr)	Accredited organisation or employee who is qualified or trained.	Annual inspection
IT	Legislative Decree 8/04/2008 n.81 Directive 2006/42/EC on machinery Directive 2014/35/EU CEI EN 60335-1 (Safety of household and similar electric appliances) CEI EN 60730-1 (Automatic electrical control devices) CEI EN 60320-1/EC (Connectors for household and similar electric appliances) CEI EN 60745-1 (Safety of hand-held electric power tools)	Competent person.	Periodic maintenance in accordance with manufacturer's instructions. Inspection and testing frequency of portable equipment depend on risk assessment. Inspection every 12 months for hand-held or movable power tools.
PL	Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work. (Journal of Laws of 2002, No. 191, item 1596)	Competent person	Regular inspections and tests based on risk assessment of each individual appliance, but up to 5 years.
ROI	Guide to the Safety, Health and Welfare at (Work General Application) Regulations 2007 - Health and Safety Authority (hsa.ie) Maintaining portable electrical equipment in low-risk environments (INDG236(rev2)) (hse.gov.uk)	Competent person, registered electrician approved by RECI or ECSSA.	Regular visual checks based on risk assessment, generally between 6 months and 4 years. Regular inspections and tests based on risk assessment of each individual appliance, but up to 5 years.

SK	Act No. 124/2006 Coll. on safety and health at work Act No. 314/2001 on fire prevention Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment STN 33 1610: Revisions and inspections of electrical appliances during their use STN 33 1500: Electrical engineering regulations. Inspection and testing of electrical installations	Competent & certified person.	Pre-use checks and regular inspections in accordance with manufacturer's instructions and depending on use (A-E) and type of coverage (I-III). Group A: Leased appliances. Group B: Appliances used in exterior space. Group C: Appliances used in interior space. Group D: Appliances used in public interior space. Group E: Appliances used for administrative activities. I.: Hand-held equipment. II.: Moveable equipment. III.: Stationary equipment.
UK	The Electricity at Work Regulations 1989 (legislation.gov.uk) The Electricity at Work Regulations 1989. Guidance on Regulations (hse.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) puwer.pdf (hse.gov.uk) Maintaining portable electrical equipment in low-risk environments (INDG236(rev2)) (hse.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent person, trained and skilled in electrical work.	Regular visual checks based on risk assessment, generally between 6 months and 4 years. Regular inspections and tests based on risk assessment of each individual appliance, but up to 5 years.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Photovoltaic Installation
APM Object	CT.ELEC.PHOTOV
APM Description	Photovoltaic installations
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

Any site where photovoltaic installations are used to generate solar power.
The standard covers only the components of the installation, the electrical elements are covered in CT.ELEC.ELECINST and CT.ELEC.FIXEDWIRE

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions, and with consideration of site risk assessment but at least annually. Interim inspections will be required following adverse	Regular inspection of condition of components (PV cells including mounts, batteries, wiring, balance of system equipment) for cracks, chips, discolouration and corrosion (e.g. to mounting frame or battery terminals). Schedule resultant remedial actions as required.	Competent person.	No additional requirements						CT		
All	2	In accordance with manufacturer's recommendations and/or where efficiency has been observed to fall.	Cleaning of PV Cells (if required - N.B some installations are designed to be self cleansing).	Competent person.	No additional requirements						CT*		
All	3	Calibration of photovoltaic meters .	In accordance with manufacturer's recommendations and instructions.	Competent person.	No additional requirements						CT*		
DE	4	Every 16 years	Calibration of mechanical meters with induction movement	Competent person. State approved inspection body.	No additional requirements								16 Year CT
DE	5	Every 12 years	Calibration of mechanical transducer meters with induction movement, rotor disc	Competent person. State approved inspection body.	No additional requirements								12 Year CT

DE	6	Every 8 years	Calibration of electronic meters	Competent person. State approved inspection body.	No additional requirements								8 Year CT
FR	7	Every year and after climatic event.	Annual inspection of the equipment and safety elements of the photovoltaic production unit.	Competent person	No additional requirements						CT		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	From acon No. 505/1990 Coll.	Certified laboratory	N/A
DE	DIN VDE 0105-100 - Betrieb von elektrischen Anlagen DIN VDE 0100-600 VDE 0100-600:2017-06 - Errichten von Niederspannungsanlagen Teil 6: Prüfungen RBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und üb DGUV Vorschrift 3 - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel DIN EN 62446-1 VDE 0126-23-1:2019-04 - Photovoltaik (PV)-Systeme – Anforderungen an Prüfung, Dokumentation und Instandhaltung	Testing organisation or specialist electrical company (Prüforganisation oder einen Elektrofachbetrieb)	Comprehensive inspection at least every 4 years, as well as additional inspections based on insurance requirements and risk assessment. Recommended: Daily visual inspection of the display to check the functionality of the inverter system by the operator. Daily check of remote monitoring system by the operator. Monthly check by operator to check and document the meter reading.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. ITC-BT-40. Low voltage generator facilities RD244/2019, of April 5, which establishes regulation about technical, economic, and administrative conditions for the for self-supply of electric energy. RD413/2014, of June 6, which establishes regulation about energy produced from renewable energy, cogeneration, and waste.	Accredited company (OCA)	Low voltage Inspections and testing at least every 5 years.
FR	Ministerial Order of October 4th, 2010 Article 16 to 23 https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023081900/ The provisions shall apply to solar photovoltaic electricity generation equipment on the roof, façade or ground of a classified installation subject to authorisation. Solar photovoltaic electricity generation equipment is not subject to the requirements of this regulation if an analysis shows that it has no significant impact on the classified installation.	Competent Person	Every year and after climatic event.
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 CEI EN IEC 62446-2 (Maintenance of photovoltaic installations) CEI 0-16 (Interface systems-high and medium voltage) CEI 0-21 (Interface systems-low voltage) Resolution AEEG 786/2016/R/eel	Competent, accredited person	Meter's inspection every 5 years (electrodynamics meters) or 3 years (static meters). Interface systems maintenance every 5 years for installations over 11,08 kW. General cleaning and maintenance in accordance with manufacturer's instructions, best practice is every 12 months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 1994 No. 89 pos. 414), as amended Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	N/A	Inspections and testing at least every 5 years.
ROI	Safety, Health and Welfare at Work Act 2005	Competent Person	Provision and maintenance of plant and systems of work that are, so far as is reasonably practicable, safe and without risks to health.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified and certified person	Twice per year in case of temporary installations. Other installations with lower frequency.

UK	Health and Safety at Work etc. Act 1974 The Health and Safety at Work (Northern Ireland) Order 1978	Competent Person	Provision and maintenance of plant and systems of work that are, so far as is reasonably practicable, safe and without risks to health.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Power Generators
APM Object	CT.ELEC.POWERGENERATOR
APM Description	Diesel power generators.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Diesel Back-up Power Generators	**Related CT Areas:**	Not Specified		

Scope

Any site where diesel power generators are commissioned to produce electricity, generally as a back-up in emergency situations. This includes all diesel generators, whether stationary or mobile.
This Compliance Standard only covers the inspection requirements associated with the electrical components of diesel generators. The maintenance of a UPS is covered in CT.ELEC.UPS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	At least every month.	Operational check – fire generator and run for 30 minutes, check fuel levels and EVIDence of leaks and damage	Competent person	Maintenance logbook	PM					EVID		
All	2	In accordance with manufacturer's recommendations, but at least every 12 months unless defects identified during monthly operational checks	Inspection and maintenance of all diesel generators (components, fuel pipes, exhaust flues etc) including load bank testing if required.	Competent person, often best practice to outsource	Maintenance logbook	PM					EVID		
All	3	Based on risk assessment. Best practice states an inspection every 400 hours or 6 months, whichever comes first.	Inspection of electrical components and associated infrastructure (e.g. wiring, connections, batteries, alternators, etc.), including correct operation.	Competent person, often best practice to outsource	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	4	As per permit requirements	Where generators are part of combustion plant with a permit (Medium Combustion Plant Directive) – complete air monitoring as dictated in permit conditions NB this is being phased in depending on type of plant, age of installation and capacity	Competent person, usually outsourced as requires emission monitoring of stack	Air quality results	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Government Regulation No. 101/2005 Coll. Government Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist.	Checks to be conducted every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Vorschrift 3 - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel DGUV Information 203-032 - Auswahl und Betrieb von Stromerzeugern auf Bau- und Montagestellen	Qualified electrician (Elektrofachkraft)	Inspection prior to initial commissioning, and for mobile units a visual inspection before every use (by user). Periodic inspection frequency based on risk assessment, but at least every 4 years for fixed installations.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. ITC-BT-40. Low voltage generator facilities.	Accredited company (OCA) by ENAC.	Low voltage Inspections and testing at least every 5 years.
FR	N/A	N/A	N/A
IT	UNI EN ISO 8528-13:2016 (Safety requirements)	Competent person	Maintenance in accordance with manufacturer's instructions, usually every 12 months.
PL	Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065) Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	Qualified or competent person	Inspections and maintenance based on manufacturer's recommendations. Inspections every 12 months if they relate to fire protection installations.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Inspection frequency not stipulated in regulations. Based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 121/2002 Coll. on fire prevention Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Government Regulation No. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment	Competent person, best practice to outsource to specialist.	Routine maintenance programme. Inspection frequency not stipulated, but it is best practice to conduct one every 12 months.
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent person, best practice to outsource to specialist.	Maintenance in accordance with manufacturer's instructions. Inspection frequency not determined, based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Residual Current Device
APM Object	CT.ELEC.RCDMETER
APM Description	Residual-current devices (RCDs).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where Residual-current devices (RCDs) are used to prevent fires and harm (electric shock) to employees using electrical equipment by switching circuits off when it detects electricity flowing down an unintended path (e.g. a person).

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Periodic maintenance of all RCDs.	Competent person	Maintenance logbook					CT			
All	2	Based on risk assessment, but at least every 6 months.	Regular RCD button checks, consisting in manually tripping and stopping the current by pressing the "Test" button. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person	Inspection records, report or certificate. Risk assessment					CT			
All	3	Based on risk assessment, but at least once every 12 months.	Functional inspection of RCDs, consisting on measuring their response time or tripping time to ensure compliance. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent Person (Accredited Electrician on the Electrical Safety Register e.g. NICEIC, ECA, SELECT)	Inspection records, report or certificate. Risk assessment						CT		
DE	4	Monthly inspections	Additional inspection and testing of RCDs in non-stationary installations.	No additional requirements	No additional requirements			CT					
ES	5	Monthly inspections	Inspection as per [4].	Accredited company	No additional requirements			(CT)					

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201- Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Vorschrift 3 - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel DGUV Information 203-032 - Auswahl und Betrieb von Stromerzeugern auf Bau- und Montagestellen DIN VDE 0105-100- Betrieb von elektrischen Anlagen	Button checks conducted by user. RCD test meter inspection by qualified electrician (Elektrofachkraft)	RCDs in non-stationary systems must be checked for effectiveness by a qualified electrician at least once a month. RCD button check to be conducted at least every 6 months. RCD test meter inspection to be conducted at least every 4 years as part of the periodic inspection of the electrical installation.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions.	Accredited company (OCA) by ENAC.	Low voltage Inspections and testing at least every 5 years. High Voltage inspections and testing to be conducted at least every 3 years.
FR	26th December 2011 Decree about electrical installations verification ""Arrêté du 26 décembre 2011 relatif aux vérifications ou processus de vérification des installations électriques ainsi qu'au contenu des rapports correspondants" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000025046978/	Accredited organisation or employee who is qualified or trained.	Annual inspection
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 CEI 64-8/6 (Electric installations under 1000V-Inspections) CEI IEC 60755 (RCD-safety requirements) CEI 23-98 (Maintenance)	RCD inspection by competent person.	Periodic maintenance. RCD button check to be conducted at least every 6 months. RCD test meter inspection every 12 months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 1994 No. 89 pos. 414), as amended Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Act of April 24, 2009 on batteries and accumulators (Journal of Laws 2020, item 1850) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	Qualified & competent person, authorised according to Construction Law.	Periodic maintenance. RCD button check to be conducted at least every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) The NSAI - IS 10101:2020 March 2020	Competent, registered electrician. Approved by RECI or ECSSA.	RCD button checks conducted regularly. Test meter conducted at least every 12 months.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 205/2010 Coll. on designated technical equipment and designated activities and activities on designated technical equipment Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Ordinance No. 121/2002 Coll. on fire prevention STN 33 2000 Low voltage electrical installations. Part 4-41: Ensuring safety	Qualified (based at the level of education and the length of experience) & certified person.	Frequency according to the technical documentation.
UK	IET Wiring Regulations/BS 7671	Competent, registered electrician on Electrical Safety Register. Approved by NICEIC, ECA or SELECT.	Test button check conducted at least every 6 months. Test meter conducted at least every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Electric shock protective equipment
APM Object	CT.ELEC.SHOCKPROTECTION
APM Description	Earthing and electrical discharging systems All sites with indoor and/or outdoor lighting systems.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with an electrical installation. Inspection of the earthing and electrical discharging systems is mandatory as part of the inspection of the electrical installation as a whole.
More than 36 kV - high voltage
However, EU RME simplifies to LV < 1 kV AC and HV ≥ 1 kV AC.
Any site where an emergency lighting system (including battery) is installed to aid safety in the event of power failure and/or safe evacuation of the site in emergency situations.
Inspection requirements of electrical installations are covered by "Compliance HV inspection and test", "High/Medium Voltage" and "Low Voltage" Standards.
Any site with an electrical installation. CEN and CENELEC standards define incoming electricity at:
Less than 1 kV - low voltage installations
Between 1 kV and 36 kV - medium voltage installation
Any site where diesel power generators are commissioned to produce electricity, generally as a back-up in emergency situations. This includes all diesel generators, whether stationary or mobile.
This Compliance Standard only covers the inspection requirements associated with the electrical components of diesel generators. The maintenance of a UPS is covered in CT.ELEC.UPS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Based on risk assessment, but at least every 6 months for hand protection clothing and 12 months for other protective equipment	Regular inspection of all insulating protective equipment	Competent person (Electrician accredited by NICEIC, ECA or SELECT.)	Risk assessment Inspection records					CT*	CT*		
IT	2	No additional requirements.	No additional requirements.	No additional requirements.	CE Declaration of Conformity.								N A R

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	ČSN EN 60903, ČSN 35 9700, ČSN EN 61481, ČSN EN 50508, ČSN EN 62193, ČSN EN 60855, ČSN EN 61243	Competent electrician	Frequency determined by the type of protective equipment, between 6 and 60 months.
DE	DGUV Vorschrift 3 - Elektrische Anlagen und Betriebsmittel (Tabelle 1C: Prüfungen für Schutz- und Hilfsmittel)	Qualified electrician (Elektrofachkraft)	Regular inspections based on risk assessment. For insulating protective clothing: Visual inspection before each use by user, general inspection at least every 12 months, but every 6 months for insulating gloves. For insulated tools: visual inspection before each use, and functional observation during each use by user. For voltage testers, phase comparators and voltage testing systems for nominal voltages above 1 kV: at least every 6 years.

ES	RD 614/2001, of June 8, about health and safety protection for workers toward electric risks. Technical guide for the assessment and prevention of electric risks.	Competent person	Regular maintenance in accordance with manufacturer's instructions.
FR	Labor Code Article R4322-1 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018531543/ Labor Code Article R4323-99 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018531296/	N/A	N/A
IT	Legislative Decree 9/04/2008 n.81 CEI EN 60903 (Hand protection clothing) CEI EN 60984 (Protective sleeves) CEI EN 50321-1 (Dielectric protective footwear) CEI EN 61482 (Protective clothing against the thermal effect of the electric arc) CEI EN 60895 (Dielectric protective clothing) CEI EN 50365 (Helmets- requirements for dielectric protection) UNI EN 397:2013 (Protective helmets) UNI EN 166:2004 (Personal eye protection)	Competent person	Maintenance in accordance with manufacturer's instructions. Every 6 months for hand protection gear (every 12 months for gloves used under 1000V).
PL	Regulation of minister of Labor and Social Policy on general health and safety regulations (Journal of Laws 2003, numer 169, item 1650) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	Competent person	Regular maintenance in accordance with manufacturer's instructions.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI - IS 10101:2020 on 6 March 2020	Competent person	Routine maintenance, repair or replacements based on use and operating conditions.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 205/2010 Coll. on designated technical equipment and designated activities and activities on designated technical equipment Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment. STN 33 2000-4-41: Low voltage electrical installations. Part 4-41: Ensuring safety. Protection against electric shock.	Qualified and certified person	Routine maintenance, repair or replacements based on use and operating conditions.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Electricity at Work Regulations 1989 (legislation.gov.uk) The Personal Protective Equipment (Enforcement) Regulations 2018 (legislation.gov.uk) The Personal Protective Equipment at Work Regulations 1992 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk) Personal Protective Equipment at Work Regulations (Northern Ireland) 1993 (legislation.gov.uk)	Competent person	Routine maintenance, repair or replacements based on use and operating conditions.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Thermal scanning
APM Object	CT.ELEC.THERMAL
APM Description	Thermal scans of electrical installations
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	LIFTS.PASSENGER - LIFTS.GOODS - LIGHT.SAFETY - FIRE.DET.FIREALRM - FIRE.DET.BOS - FIRE.DET.COMM - FIRE.SUP - FIRE.SUP.PUMP.CNTRL - ELEC..LV.CABS - ELEC.LV.BSBR - ELEC.HV.SWITCHGEAR -	**Related CT Areas:**	Not Specified		

Scope

Any site where thermal imaging/scanning is used for inspections of electrical systems to help in the early identification of faults before they occur, and therefore preventing breakdowns, replacements and even fires.
Thermographic surveys are generally part of the thorough inspection of the electrical installation, which is covered under Compliance Standard CT.ELEC.ELECINST

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	After installation is complete	Initial thermographic survey at installation stage.	Competent person, usually outsourced	Inspection records, report or certificate. Risk assessment								One off EVID
All	2	Thermographic surveys are generally part of the inspection of the electrical installation as a whole, and therefore they frequency is based on risk assessment (type, use and operating conditions), but normally between 3 and 5 years.	Periodic thermographic surveys of the electrical installation and equipment to aid in the early detection and the prevention of issues.	Competent person, usually outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		
CZ	3	No additional requirements	Inspection as per [1] and [2].	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					(EVID)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500 ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305 ČSN 331600.ed.2, Decree 50/1978	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60 months.

DE	DIN 54191 - Zerstörungsfreie Prüfung - Thermografische Prüfung elektrischer Anlagen	Qualified electrician (Elektrofachkraft)	Regular thermal scans depending on the use and operating conditions of the equipment, and risk assessment. Annual scans are recommended.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions.RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions.	Accredited company (OCA) by ENAC.	Frequency not stipulated by regulations.
FR	N/A	N/A	Frequency not stipulated by regulations.
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 CEI 64-14 (Guidelines for electrical installations inspections) CEI O-10 (Guidelines for maintenance) CEI 64-8/6 (Electric installations under 1000V-Inspections) UNI EN ISO 9712:2012 (Qualification of non-destructive testing personnel) UNI EN 16714-3:2016 (Thermographic testing)	Competent person.	Frequency not stipulated by regulations.
PL	N/A	N/A	Frequency not stipulated by regulations.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI 5th Edition National Rules for Electrical Installations, IS 10101:2020 on 6 March 2020.	Registered electrician, approved by ECSSA.	Initial inspection and at least every 5 years.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified and certified person.	Depends on class. Minimum inspection period is 3 years.
UK	The Electricity at Work Regulations 1989 (legislation.gov.uk) BS 7671 / IET Wiring Regulations The Electricity at Work Regulations 1989. Guidance on Regulations (hse.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Registered electrician, approved by NICEIC, ECA or SELECT.	Initial inspection and at least every 5 years

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Transformer oil testing
APM Object	CT.ELEC.TROILTEST
APM Description	Transformers containing oil
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	ELEC.HV.SWITCHGEAR	**Related CT Areas:**	Not Specified		

Scope

Any site with operating transformers where oils are used as coolant and for its electrical insulating properties. Equipment owned and operated by third parties (e.g. power company) are not included in prescribed PPM activities.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations. Based on risk assessment (operational and environmental conditions). Generally performed at least every 12 months.	Regular transformer oil testing undertaken to identify potential issues at an early stage, including visual inspection, acidity, dielectric constant, density, water content, etc.	Competent person	Analysis results						CT		
All	2	In accordance with manufacturer's instructions and recommendations. Based on risk assessment (operational and environmental conditions). Generally performed at least every 12 months.	Where transformers pre-date 1986, Poly Chlorinated Biphenyls (PCB) analysis should have already been completed.	Competent person	Analysis results						CT		
All	3	During maintenance of the equipment, and following an oil change, disposal and refurbishment.	Old, unlabelled transformers and those manufactured before 1986 could potentially contain PCBs. Transformers with PCBs of less than 0.05% by weight are still allowed to be used, however maintenance frequency should be reviewed.	Competent person	PCB-containing equipment register. Analysis results								On demand EVID

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A

CZ	- ČSN 35 1090 - ČSN 33 1500 Decree No. 50/1978 Coll.	Competent person - qualified electrician	Inspections according to the preventive maintenance specified by the employer.
DE	DIN EN 60422 VDE 0370-2 - Isolieröle auf Mineralölbasis in elektrischen Betriebsmitteln - Leitlinie zur Überwachung und Wartung	Competent person	Oil testing frequency is decided by the operator and depends on the type of equipment, its function, voltage, power, stress, the results of previous examinations, and the effects that a failure of the operating equipment has on the company.
ES	RD 228/2006, of February 24, which modifies RD1378/1999 and establishes regulation for the elimination and management of polychlorinated biphenyls, polychlorinated terphenyls and all the devices where are contained. RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions. UNE-EN 60422 Isolating oils in electrical equipment	Accredited company (OCA) by ENAC.	High Voltage inspections and testing to be conducted at least every 3 years.
FR	Equipment manufactured after 18 June 1994 is considered to be free of PCB contamination https://aida.ineris.fr/consultation_document/24152 For equipment built before 1987, without free PCB label, an oil analysis is required to determine PCB concentration https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000027298297 https://www.legifrance.gouv.fr/loda/id/JORFTEXT000028478731/	Competent person, trained to undertake sampling and analysis.	No Frequency defined by French regulation.
IT	CEI EN 60422 (Mineral insulating oils in electrical equipment- Supervision and maintenance guidance)	Competent person	Dielectric strength analysis, gas chromatography of the oil, if the PCB level is superior than 50 p.p.m report to local authorities (ASL). Frequency depends on equipment and operating conditions, best practice is every 12 months.
PL	The Act of April 27, 2001, Environmental Protection Law. (Journal of Laws of 2001, No. 62, item 627) Regulation of the Minister of Economy of 24 June 2002. On the requirements for the use and movement of substances posing a particular threat to the environment and the use and cleaning of installations or devices in which they were or are used substances posing particular environmental threat. (Journal of Laws of 2002, No. 96, item 860) Regulation of the Minister of Economy of September 26, 2002 on the determination of devices in which substances posing a particular threat to the environment could be used (Journal of Laws of 2002, No. 173, item 1416)	Competent person, trained to undertake sampling and analysis.	From June 30, 2010, it is not allowed to use PCBs in devices or installations in use.
ROI	BS EN 60422:2013 - Mineral insulating oils in electrical equipment. Supervision and maintenance guidance	Competent person	Frequency depends on equipment and operating conditions.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment STN EN 60076-2: Power transformers. Part 2: Temperature rise	Certified and qualified person	Every two years for objects containing flammable materials.
UK	BS EN 60422:2013 - Mineral insulating oils in electrical equipment. Supervision and maintenance guidance	Competent person	Frequency depends on equipment and operating conditions, but analysis is generally undertaken at least every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Surge Protection Devices
APM Object	CT.ELEC.TVSS
APM Description	Surge Protection Devices (SPDs)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where Surge Protection Devices (SPDS), also known as Transient Voltage Surge Suppressor (TVSS), are used to provide protection to electrical equipment and appliances due to surges of voltage, which can be due to lighting strikes, switching operations or electrostatic discharges.
Lightning protection equipment is covered in Lightning protection.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all SPDs.	Competent person	Maintenance logbook	PM					EVID		
All		Based on risk assessment (type, use, operational conditions and risks associated with the area, but at least every 12.	Visual check of all SPDs to ensure.	Competent person. Generally, externally sourced.	CE Declaration of Conformity Risk assessment Inspection records, reports or certificates.						CT		
All		Based on risk assessment (type, use, operational conditions and risks associated with the area), but at least every 2 years.	Testing of all SPDs to ensure correct operation. This is achieved through a simulated surge voltage to confirm the device functionality.	Competent person. Generally, externally sourced.	CE Declaration of Conformity Risk assessment Inspection records, reports or certificates.							CT	

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A

CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60 months.
DE	DIN EN 62305-3 VDE 0185-305-3:2011-10 – DIN VDE 0100-443 - Errichten von Niederspannungsanlagen – Teil 4-44: Schutzmaßnahmen – Schutz bei Störspannungen und elektromagnetischen Störgrößen DIN VDE 0100-534 – Errichten von Niederspannungsanlagen – Teil 5-54: Auswahl und Errichtung elektrische Betriebsmittel – Trennen, Schalten und Steuern	Lightning protection specialist (Blitzschutz Fachkraft)	Regular inspections should be carried out every 1 to 4 years. Protection class I and II should have a visual inspection, and an inspection of critical systems at least every year, and a general inspection at least every 2 years. Protection class III and IV should have a visual inspection at least every 2 years, an inspection of critical systems at least every year, and a general inspection at least every 4 years.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions.RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions.	Accredited company (OCA) by ENAC.	Low voltage Inspections and testing at least every 5 years. High Voltage inspections and testing to be conducted at least every 3 years.
FR	26th December 2011 Decree about electrical installations verification ""Arrêté du 26 décembre 2011 relatif aux vérifications ou processus de vérification des installations électriques ainsi qu'au contenu des rapports correspondants" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000025046978/	Accredited organisation or employee who is qualified or trained.	Annual inspection
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 CEI 64-8; V5 (Sections 443;534: safety requirements for surge protection devices) CEI EN 61643-11 (Safety requirements) CEI 64-14 (Guidelines for electrical installations inspections) CEI O-10 (Guidelines for maintenance) CEI 64-8/3 (Electric installations under 1000V- general informations) CEI 64-8/6 (Electric installations under 1000V-Inspections) CEI 64-8/7 (Electric installations under 1000V-special applications) CEI EN 50191 (Installation and use of electric systems)	Competent person	Inspection every 5 years, or every 2 if there is a risk of fire.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 1994 No. 89 pos. 414), as amended Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Act of April 24, 2009 on batteries and accumulators (Journal of Laws 2020, item 1850) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	Competent person	Inspection every 5 years, or every year if there is a risk of fire.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI - IS 10101:2020 on 6 March 2020.	Competent, trained electrician	Routine maintenance. Inspection and testing frequency based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Ordinance No. 94/2004 Coll. laying down technical requirements for fire safety in the construction and use of buildings	Qualified and certified person	Protection systems level I and II require a visual inspection yearly and a functional inspection and testing every 2 years. Protection systems level III and IV require visual inspection yearly and a functional inspection and testing every 4 years.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Electricity at Work Regulations 1989 (legislation.gov.uk) BS 7671 / IET Wiring Regulations Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk) BS EN 62305-3 Protection Against Lightning BS 7430 Code of Practice for Earthing	Competent, trained or qualified engineer, authorised to undertake the task.	Routine maintenance. Inspection frequency dependant on the building, type of SPD, use and operational conditions. Generally, visual checks at least annually and testing at least every 2 years.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Uninterrupted power supply (UPS)
APM Object	CT.ELEC.UPS
APM Description	Uninterrupted power supply (UPS)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	ELEC.UPS	**Related CT Areas:**	Not Specified		

Scope

Any site where Uninterrupted Power Supply (UPS) systems (e.g. back-up batteries) are used to provide back-up sources of electricity when the mains service fails.
The maintenance of Generators is covered in Power Generators.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's recommendations and instructions.	Routine maintenance and remedial actions as required.	Competent person, best practice to outsource	Maintenance logbook	PM					EVID		
All		Based on risk assessment, but at least every 12 months.	Full inspection of UPS systems to ensure correct operation and integrity, including visual checks, review of electrical connections, functionality, environmental conditions, etc. If defects are identified, remedial actions should be addressed as soon as possible.	Competent person, best practice to outsource	Inspection records, report or certificate. Risk assessment	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6and 60months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Vorschrift 3 (§5) - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel DIN VDE 0105-100 - Betrieb von elektrischen Anlagen	Qualified electrician (Elektrofachkraft)	Every 4 years for stationary facilities which do not fall under group 700. Group 700 facilities require yearly inspections and include: ·Rooms with a bathtub or shower ·Rooms with swimming pools or other basins ·Rooms with sauna heaters ·Building sites ·Electrical installations in agriculture or horticulture ·Conductive areas with limited freedom of movement ·Campsites and similar areas

ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage & its 52 complementary Technical Instructions. ITC-BT-36. Very low voltage devices. ITC-BT-40. Low voltage generator facilities. RD 1215/97 Working equipment	Accredited company (OCA) by ENAC.	Low voltage Inspections and testing at least every 5 years Inspections in accordance with manufacturer's instructions.
FR	N/A	N/A	Not stipulated by regulations
IT	Directive 2004/108/EC Directive 2006/95/EC CEI EN IEC 62040-1 (Safety requirements) CEI EN 50171 (General requirements) CEI 11-20 (UPS installation) CEI EN 60896-11 (Open-type batteries) CEI EN 60896-21 (Valve-regulated batteries)	Competent person.	Inspections in accordance with manufacturer's instructions. Best practice: every 6 months for Systems > 20 kVA and every 12 months for systems </= 20 kVA.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 1994 No. 89 pos. 414), as amended Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	Qualified or competent person, authorised by Construction Law and Energy Law	Inspections in accordance with manufacturer's instructions. Measurements insulation resistance / impedance measurement every 5 years.
ROI	Safety, Health and Welfare at Work Act 2005 Safety, Health and Welfare at Work (General Application) Regulations 2007 to 2012. c 30-31	Competent person, best practice to outsource to specialist.	Routine maintenance. Inspection/service frequency not stipulated in regulations, in accordance with manufacturer's recommendations.
SK	Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Government Regulation No. 391/2006 on the minimum safety and health requirements for the workplace Government Regulation No. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment	Competent person, best practice to outsource to specialist.	Routine maintenance. Inspection/service frequency not stipulated in regulations, in accordance with manufacturer's recommendations.
UK	Provision and Use of Work Equipment Regulations 1998 (PUWER) Reg. 5 Health and Safety at Work Act 1974	Competent person, best practice to outsource to specialist.	Routine maintenance. Inspection/service frequency not stipulated in regulations, but it is best practice to inspect UPS systems every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Asbestos
APM Object	CT.ENVIRO.ASBESTOS
APM Description	Asbestos
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

Maintenance and repair works at any site with Asbestos Containing Materials (ACM), where ACM has either been identified on site or has not been identified but there is a risk of ACM being present. The use of asbestos and ACM in buildings is banned in all countries included in this Compliance Standard, but on different years. Refer to table 2 for details.
Asbestos removal/demolition and associated legal requirements as well as annual reporting to local government is presumed to be managed as a standalone project via EHS Manager.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Undertake a survey if site is likely to contain asbestos, specifying type, condition and quantities (and review register prior to undertaking any maintenance activity).	Initial inspection and risk assessment	Competent person, best practice to outsource to specialist, licenced company	Up-to-date asbestos register Asbestos surveys reports Asbestos Management Plan (AMP) Training records								Initial Activity EVID
All	2	Produce and update a risk assessment for each ACM identified.	Initial inspection and risk assessment	Competent person, best practice to outsource to specialist, licenced company	Up-to-date asbestos register Asbestos surveys reports Asbestos Management Plan (AMP) Training records						CT		
All	3	Monitor condition of identified ACM	Annual reinspection of known ACM unless significant deterioration is observed before this, or incident e.g. accidental damage.	Depending on type and condition of ACM, could be external company, or, if low risk a suitably trained and competent person	Up-to-date asbestos register Asbestos surveys reports Asbestos Management Plan (AMP) Training records						CT		
SK	4	Before starting work in which workers may be exposed to asbestos dust.	Submit a notification to the competent public health authority.	Trained person	Submitted notification								As Needed EVID*
SK	5	Every time when such activity is performed	Keep records of employees who carry out an activity in which they could be exposed to asbestos dust.	N/A	Records of employees, need to be kept for 40 years.								As Needed EVID*

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Survey: Decree No. 499/2006 (as amended by Decree No. 62/2013, resp. 405/2017 Coll.) on the documentation of buildings (Annex 15, paragraph B.2.h) Notification - Act No. 258/2000 Coll. on the protection of public health (§37, 38, 40, 41) Decree no. 6/2003, setting hygiene limits (§4, Annex 2) Asbestos abatement: Notification - Act No. 258/2000 Coll. on the protection of public health (§37, 38, 40, 41) Health protection Regulation 361/2007, plus Decree No. 394/2006 for work with asbestos Act No. 225/2012 Coll., amending Act No. 309/2006 Coll. (§7, 8) Decree No. 6/2003, setting hygiene limits (§4, Annex 2); inside of the building after asbestos	Specialist company / technicians; accreditation is not required for survey; accreditation is required for taking/analyses of samples Accreditation is not required for asbestos abatement company; accreditation is required for measurement after/during abatement	Likely present in buildings built before 2000. Safety plan for the work (RA) before works commence. Reporting of asbestos work
DE	Gefahrstoffverordnung (GefStoffV) Technical Rules for Hazardous Substances: TRGS 519 – Asbestos: Demolition, reconstruction or maintenance work.	Specialist company (Fachbetriebe), expert (sachkundige Person).	Likely present in buildings built before 1992. Initial survey and risk assessment of each identified ACM, including sampling where necessary. Monitoring based on RA.
ES	RD 396/2006, on H&S measures for activities work activities exposed to asbestos Prevention Technical Notes NTP 463: exposition to asbestos fibbers Prevention Technical Notes NTP 796: working plans for maintenance and removal of asbestos containing materials (ACM) Prevention Technical Notes NTP 632: identification of asbestos containing materials (ACM) Prevention Technical Notes NTP 633-II: identification of asbestos containing materials (ACM) Prevention Technical Notes NTP 862 : practical examples of maintenance and removal of asbestos containing materials (ACM) Prevention Technical Notes NTP 707-708: diagnosis of ACM in buildings	Competent person. Activities with maintenance or removal of ACM with risk of fibre release must be done by certified companies (RERA). Before removal of ACM, a Working Plan must be approved by the Work Authorities.	Likely present in buildings built before 1992. It was totally banned in 2002. Produce, update and manage a Risk assessment. Ensure yearly training of personnel.
FR	Public Health Code Art. L.1334-16 to L.1334-17 https://www.legifrance.gouv.fr/codes/id/LEGIARTI000031927993/2016-01-28 Public Health Code Art. R1334-14 to R1334-29-9 https://www.legifrance.gouv.fr/codes/id/LEGISCTA000024140902/2012-02-01 Decree n°2011-629 of 3rd June 2011 relating to the protection of people against asbestos risks "Décret n°2011-629 du 3 juin 2011 relatif à la protection de la population contre les risques sanitaires liés à une exposition à l'amiante dans les immeubles bâtis" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000024114426/ 12th December 2012 Decrees list A and B evaluation "Arrêté du 12 décembre 2012 relatif aux critères d'évaluation de l'état de conservation des matériaux	Qualified and certified person or operator.	Likely present in buildings built before 1997. Survey and assessment before commencing the works.
IT	Lex n. 257 27 March 1992 – regulation regarding the ban of the use of Asbestos Legislative Decree n. 81 of 9 April 2008 – protection of health and safety in the workplace	Competent person.	Likely present in buildings built before 1992. In case of presence of Asbestos, produce, and early update a Management and Control Plan. Ensure training of personnel.
PL	Act of June 19, 1997 on the prohibition of the use of asbestos- containing products (Journal of Laws of 2020, item 1680) as amended Regulation of the Minister of Economy, Labor and Social Policy of 2 April 2004 on the methods and conditions for safe use and removal of asbestos-containing products (Journal of Laws of 2004, item 649) Regulation of the Minister of Economy of 13 December 2010 on requirements for the use of asbestos-containing products and the use and cleaning of installations or devices in which asbestos-containing products have been or are used. (Journal of Laws 2011, number 8, item 31) Regulation of Minister of Economy and Labor on the principles of occupational health and safety for the protection and removal of asbestos-containing products and the training program on the safe use	Qualified or competent person.	Likely present in buildings built before 1997. Periodical technical inspection if asbestos is known to be present. Formal assessment every 1-5 years. Asbestos register. Monitoring each year.
ROI	Safety, Health and Welfare at Work (Exposure to Asbestos) Regulations 2006 (S.I. No. 386/2006)	Competent person.	Likely present in buildings built before 2004. Initial survey and risk assessment of each identified ACM. Monitoring based on RA and AMP. Asbestos register.
SK	Act No. 355/2007 Coll. on protection, support and development of public health and amending certain Acts, as amended Government Regulation No. 253/2006 Coll. on the protection of workers from risks related to exposure to asbestos at work	Trained person considered best practice to outsource to licensed company. Removal of asbestos or ACM only by licensed person or company.	Likely present in buildings built before 1999. Initial and periodical training. Initial and periodical assessment. Monitoring is based on RA. Undertake risk assessment and create AMP. Asbestos register.
UK	The Control of Asbestos Regulations 2012 Managing and working with asbestos (hse.gov.uk) A comprehensive guide to Managing Asbestos in premises (hse.gov.uk) The Control of Asbestos Regulations (Northern Ireland) 2012	Competent person, considered best practice to outsource to licensed, specialist company.	Likely present in buildings built before 2000. Initial survey and risk assessment of each identified ACM. Monitoring based on RA and AMP. Asbestos register.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Kitchen extract and grease management
APM Object	CT.ENVIRO.EXTRACT
APM Description	Kitchen grease systems, including air ducts, fans, chambers, filters, etc.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.DH	**Related CT Areas:**	CT.ENVIRO.INTERCEPTOR		

Scope

Any site with a kitchen air extraction system (e.g. exhaust air ducts, extractor hoods, chimneys etc.) that require inspection in order to reduce the risk of fire occurring.
The maintenance of grease traps is covered in the procedure CT.ENVIRO.INTERCEPTOR

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, suggested monthly.	Regular maintenance of the equipment (lubrication, filter replacement, parts replacement, etc.).	Competent person.	Records of inspections (including cleaning and maintenance).	PM					EVID		
All	2	Maintenance frequency not specified in regulations, based on site fire risk assessment. Generally, every 6-12 months unless heavy use (>12-16hrs/day).	Regular inspection, cleaning and removal of grease from extractor system, including flow efficiency, cleanliness, checks on filters to ensure they are not clogged.	Operator. Competent person (cleaning and filter change).	Records of inspections (including cleaning and maintenance) Recommended to be included in the site Fire Risk Assessment.	PM					EVID		
DE	3	Aerosol separators must be checked every working day and cleaned if necessary. In case of heavy grease accumulation, daily cleaning of the separators may be necessary. Kitchen ventilation ceilings and bonnets should be checked	Maintenance as per [1]	No additional requirements	No additional requirements	(PM)					(EVID)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Law No. 133/1985 Coll., Fire protection; Law No. 201/2012 Coll., Air protection Decree No. 246/2001 Coll. about fire prevention	Competent person. Usually outsourced.	Regular inspection and maintenance. Frequency based on risk assessment.

DE	VDI 2052 - Raumlufttechnik - Küchen (VDI-Lüftungsregeln) DIN EN 16282 - Equipment in commercial kitchens - Elements for aeration and ventilation TRBS 1201 Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen	Expert (sachkundige Person). Knowledgeable person for simple inspection, cleaning and maintenance.	Aerosol separators must be checked every working day and cleaned if necessary. In case of heavy grease accumulation, daily cleaning of the separators may be necessary. Kitchen ventilation ceilings and bonnets should be checked regularly and cleaned if necessary e.g. kitchen ventilation bonnets should be checked daily and ceilings at least monthly for soiling. The components of the exhaust air system (e.g. exhaust air ducts, fans, unit chambers) should be checked at least every six months and cleaned if necessary.
ES	Real Royal Decree 732/2019 Technical Code of Buildings NORMA UNE 100165 on fumes extraction	Competent person.	Monthly maintenance and cleaning. Inspections carried out every 12 months.
FR	Decree of 10th October 2005 on fire security rules Arrêté du 10 octobre 2005 portant approbation de diverses dispositions complétant et modifiant le règlement de sécurité contre les risques d'incendie et de panique dans les établissements recevant du public - Légifrance (legifrance.gouv.fr)	Competent, qualified person.	Chimney sweeping and verification of potential obstructions every 12 months.
IT	Legislative Decree n. 81 of 9 April 2008 - regarding the protection of health and safety in the workplace UNI EN 16798-1:2019 (Ventilation for buildings). UNI EN 16798-3:2018 (Energy performance of buildings) UNI 7129 (Gas plant)	Competent person. Usually outsourced	Inspections follow manufacturer's instructions. Generally every 12 months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333), as amended	Competent, trained person.	Inspections at least twice a year. Notification in writing the building inspector.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 Fire Services Act 1981	Competent, qualified person.	Inspection frequency follow manufacturer's instructions.
SK	Act No. 314/2001 Coll. on fire protection Ordinance No.121/2002 Coll. on fire prevention	Competent person. Usually outsourced.	Inspection frequency follow manufacturer's instructions.
UK	The Regulatory Reform (Fire Safety) Order 2005 Fire Scotland (2005) Act RC44 (FPA/BSRIA) Recommendations for fire risk assessment of catering extract ventilation The Fire and Rescue Services (Northern Ireland) Order 2006 The Fire Safety Regulations (Northern Ireland) 2010	Competent person, best practice is to outsource to specialist.	Regular maintenance. Cleaning frequency based on hours of use. 3 months (12-16h/day), 6 months (6-12h/day) and 12 months (2-6h/day). Inspection frequency based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Hazmat Cabinets
APM Object	CT.ENVIRO.HAZCAB
APM Description	Hazmat Cabinets
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site using and storing hazardous products, with safety cabinets designed to safely store hazardous materials (e.g. flammable liquids).

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Frequency based on risk assessment. Generally, every 12 months.	Identify hazardous substances used and identify storage requirements using Safety Data Sheet	Competent person (likely to be internal)	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.						CT		
All	2	Frequency based on risk assessment. Generally, every 12 months.	Correctly label all substances hazardous to health used or stored at the site and ensure storage containers are labelled with appropriate hazard pictograms and stored away from conflicting hazard sources e.g. separate oxidisers and flammables.	Competent person (likely to be internal)	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.						CT		
All	3	Frequency based on risk assessment. Generally, every 12 months.	Periodic inspection to ensure correct integrity of the cabinets e.g. spill prevention or resistance to fire.	Competent person (likely to be internal)	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.						CT		
CZ	4	HAZMAT cabinets are generally inspected at least every 6 months.	Inspection as per [3]	No additional requirements	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Act No. 258/2000 Coll. on public health protection (§44a) Regulation No. 375/2017 Coll. on safety signs and signalisation (§4) Labour Code No. 262/2006 Coll. (§101-103) Water Act No. 254/2001 Coll. (§39) Decree No. 450/2005 Coll. on requirements of handling harmful substances and emergency plan (§3), Decree No. 246/2001 Coll. on fire safety (§44) CSN 65 0201	N/A	There are no specific stipulations for safety cabinets. In general HAZMAT warehouses or cabinets should be inspected every 6 months at least. Specific provisions for flammables are set in CSN 65 0201 (see Annex 5).
DE	Gefahrstoffverordnung (GefStoffV) Betriebssicherheitsverordnung (BetrSichV) Technical Rules for hazardous substances: TRGS 510 – Storage of hazardous substances in portable containers	Competent person (fachkundige Person).	Cabinets for hazardous substances must be regularly checked (TRGS 510), frequency based on risk assessment; annual inspection is common; follow the manufacturer recommendation.
ES	Royal Decree 656/2017 on the storage of hazardous chemicals	Depending on the quantity and hazard assessment, by competent person or by a certified company.	Exam periodicity depends on stored quantities and type of hazard assessment.
FR	French Labor Code – Article R4412-1 to 57 - Chemicals management: labelling and storage rules for risk assessment and prevention https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018490115/#LEGISCTA000018531162	N/A	Exam periodicity has to be defined by the risk assessment as Best Practice to manage chemical hazards
IT	Legislative Decree n. 81 of 9 April 2008 - regarding the protection of health and safety in the workplace EN 14470-1:2005 EN 14470-2:2007 EN 1363-1:2020	Competent person.	Hazardous substances (toxic and flammable substances) must be properly stored in order to avoid any damaging events. Frequency of the periodic inspections of the cabinets, which must be periodically performed, depends on the content of the cabinet and must be in line with the maintenance manual provided by the manufacturer.
PL	N/A	N/A	N/A
ROI	Dangerous Substances Act, 1972	N/A	Limits the maximum amount of fuel stored on site and conditions on storage.
SK	Act No. 67/2010 Coll. - Chemical Act Government Regulation No. 355/2006 Coll. on the protection of workers from the risks related to exposure to chemical agents at work STN EN 14470-1: Fire safety storage cabinets - Part 1: Safety storage cabinets for flammable liquids	N/A	No special legislation for Hazmat cabinets. Stated legislation is more general, setting up compliance with EU RME Standards .Technical norm sets up technical requirements for storage cabinets for flammable liquids.
UK	The Control of Substances Hazardous to Health Regulations 2002 Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003	N/A	Regular inspection of chemical storage areas, including the condition of the structure and fittings within the storing area.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Interceptor
APM Object	CT.ENVIRO.INTERCEPTOR
APM Description	Oil and grease interceptors fitted to drainage network.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.OILSEP BLDG.GREASESEP	**Related CT Areas:**	CT.ENVIRO.EXTRACT		

Scope

Any site with an oil or grease interceptor fitted to provide treatment of surface or foul drainage systems prior discharge

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Frequency not specified in regulations. It is based on site conditions, manufacturer instructions, risk assessment or conditions of sewage permit. Suggest monthly inspection/clean for kitchen grease trap and 12 month	Regular inspection, cleaning and removal of waste to ensure the effectiveness of the interceptor in line with manufacturers instructions.	Competent person	Records of inspections (including cleaning and maintenance). Records of the site water drainage plan.	PM					EVID		
DE	2	General inspection by expert every 5 years. 12 monthly maintenance, emptying and cleaning of interceptor. Sludge trap and grease separator must be completely emptied and cleaned at least	Maintenance and inspection of the grease interceptor, including sludge trap and grease separator to ensure optimal operation.	Expert person (sachkundige Person).	Record of periodic general inspection. Operational logbook.	PM					EVID		5Y CT

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Water Act No. 258/2000 Coll. Act No. 274/2001 Coll., on Water supply and sewerage systems for public use CSN EN 858-2 Decree No. 8/2021 Coll., waste catalogue Waste Act No. 541/2020 Coll.	Competent person, best practice is to outsource to specialist.	Regular inspections following manufacturer's instructions or operation rules, regular cleaning and removal of waste, frequency based on the site conditions and risk assessment. Where a site has a discharge permit or a wastewater contract follow given conditions. The CSN EN 858-2 recommends general inspection every 5 years and inspection every 6 months.
DE	Verordnung über Anlagen zum Umgang mit wassergefährdenden Stoffen (AwSV) DIN 1999-100 - Abscheideranlagen für Leichtflüssigkeiten - Teil 100: Anwendungsbestimmungen für Abscheideranlagen für Leichtflüssigkeiten nach DIN EN 858-1 und DIN EN 858-2 DIN 4040-100 Grease Separators Wasserhaushaltsgesetz – WHG (Federal Water Act) and Abwasserverordnung (AbwV) (discharge of stormwater and wastewater law) https://www.bmu.de/themen/wasser-abfall-boden/binnengewaesser/gewaesserschutzrecht/deutschland/das-wasserhaushaltsgesetz/	Expert (sachkundige Person).	General inspection (Generalinspektion) every 5 years. Self-inspection every month. Maintenance, emptying and cleaning every 6 months.

ES	Royal Decree 732/2019 Technical Code of Buildings UNE-EN 1825-1 and 2	Competent person.	Recommended inspection every 6 months and maintenance every 2 years.
FR	Departemental Sanitary Regulations – Article 29 https://www.hauts-de-seine.gouv.fr/content/download/1942/13180/file/R%C3%A9glement%20sanitaire%20d%C3%A9partemental%20-%20ARS%2092.pdf This is a local regulation (Department area) but all departments request the same regular cleaning.	Competent person.	Regular cleaning, emptying and maintenance. Frequency not specified and region-specific.
IT	European Standard BS EN 858-1 Legislative Decree n.152 of 3 April 2006 - Environmental code	Competent person, best practice is to outsource to specialist.	Inspections every 3, 6 and 12 months, depending on site conditions. Periodic inspections frequency must be in line with the maintenance manual provided by the manufacturer.
PL	Regulation of the Minister of Maritime Economy and Inland Navigation of 12 July 2019 on substances particularly harmful to the aquatic environment and the conditions to be met when discharging sewage into waters or soil, as well as when discharging rainwater or meltwater into waters or into devices water (Journal of Laws 2019, item 1311) Act of 20 July 2017 - Water Law (Journal of Laws of 2017, item 1566) The Act of July 7, 1994 - Construction Law. (Journal of Laws 1994 No. 89 item 414)	Competent, trained person.	Inspections every 6 and 12 months, depending on site conditions. Periodic inspections frequency must be in line with the maintenance manual provided by the manufacturer.
ROI	Water Services Act 2007	Competent person.	Ensure maintenance to avoid hazards and damage to network. No frequency specified in regulations.
SK	Act No. 364/2004 Coll. on Waters Ordinance No. 200/2018 Coll., laying down details on the treatment of pollutants, on the details of the emergency plan and on the procedure for dealing with extraordinary water deterioration STN 75 0905/Z1: Water and sewerage tanks. Testing of water-tightness.	Competent person. Usually outsourced.	Regular frequency following manufacturer's instructions.
UK	Water Industry Act 1991 The Water and Sewerage Services (Northern Ireland) Order 2006	Competent person, with appropriate training.	In line with conditions of Trade Effluent Consent

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Oil Tanks
APM Object	CT.ENVIRO.OIL
APM Description	Any site with oil storage containers above and below ground (e.g. tanks, drums, intermediate bulk containers (IBCs) and mobile containers (bowsers).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.FUELSTOR	**Related CT Areas:**	Not Specified		

Scope

Any site with oil storage containers above and below ground (e.g. tanks, drums, intermediate bulk containers (IBCs) and mobile containers (bowsers).

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of the equipment.	Competent person.	Visual inspection records and associated maintenance repair reports.	PM					EVID		
All	2	Where site has a tank permit – inspection should be completed in line with permit conditions. For other tanks, detailed maintenance inspection every 6 months of tank and infrastructure. Annual calibration/test of	Inspection of the oil storage containers over 200L capacity, including pipework, gauges, alarms, pumps and associated structures to monitor condition, identify defects, ensure correct operation and leaks are identified and fixed promptly.	Competent person. Best practice to outsource	Visual inspection records and associated maintenance repair reports. Pressure testing and leak detection certificate.	PM					EVID		
All	3	Weekly inspection of external bunds for rainwater and damage.	Where an above ground, single skin tank is sited outside a building it should be fitted with secondary containment, the bund should be inspected for defects (damage, holes, cracking etc) and the accumulation of rainwater and debris.	Competent person (likely to be internal)	Visual inspection records and associated maintenance repair reports.		CT						
DE	4	Before first use or after any additions/changes, and at least every 30 months.	Underground tanks >200L	No additional requirements	No additional requirements								One off 30 monthly CT
IT	5	Every 3 years.	Internal inspection of tanks containing fuel oils.	No additional requirements	Inspection Report								3Y CT

IT	6	Every 5 years.	Internal inspections of tanks containing diesel fuel	No additional requirements	Inspection Report								5Y CT

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Water Act No. 254/2001 Coll. (§39), Decree No. 450/2005 Coll. on requirements of handling harmful substances and emergency plan (§3, 3a) CSN 75 3415 CSN 65 0201	Competent person, best practice is to outsource to specialist.	In general, regular inspection of the oil tanks and associated pipework/structures (inspection every 6 months, leak detection test by an external qualified company every 5 years). Specific provisions are set for flammables in CSN 65 0201 (Annex 5) – a leak test annually, a pressure test every 10 years for tanks which cannot be controlled externally, every 20 years for tanks externally controllable.
DE	Verordnung über Anlagen zum Umgang mit wassergefährdenden Stoffen (AwSV) TRGS 510 - Storage of hazardous substances in non-stationary containers ADR / RID 6.5.4.4 for IBC inspection	Expert (sachkundige Person) according to AwSV.	Underground tanks >200L: before first use or after any additions/changes, and at least every 30 months. Aboveground tanks >1000L: before first use or after additions/changes, and at least every 5 years. For IBCs before first use, and at least every 5 years according to ADR/RID.
ES	Royal Decree 656/2017 on the storage of hazardous chemicals Royal Decree 1523/1999, modifying MI-IP03, approved by Royal Decree 1427/1997 on fuel storage for internal use	Depending on the quantity and hazard assessment, by competent person or by a certified company.	Exam periodicity depends on stored quantities and type of hazard assessment. Normally every 5 to 10 years
FR	Decree 22nd June 1998 on flammable liquids "Arrêté du 22 juin 1998 relatif aux réservoirs enterrés de liquides inflammables ou combustibles et de leurs équipements annexes" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000572509/	Accredited company.	Regular inspection of oil tanks for leaks and correct operation. Maintenance every 5 years. Single skin tanks located in a pit must be checked for leaks every five years by an accredited company. For double outer jacket tanks, inspections every 10 years.
IT	UNI 8364-3: 2007 (Heating plant) Guidelines for Underground Storage Tanks of Local environmental protected agency ARPA of Lombardy Region "Linee guida sui serbatoi interrati ARPA 15/03/2013"	Competent person, best practice is to outsource to specialist.	Inspections in accordance with manufacturer's instruction. Every 3 years for tanks containing fuel oils, every 5 years for tanks containing diesel. In case of an Underground Storage Tanks (UST), a thickness test must be performed periodicity: - Every year: in case of an UST installed more than 30 years ago - Every 2 years: in case of an UST installed between 15 and 30 years ago
PL	Regulation of the Minister of Economy of 18 September 2001 on the technical conditions of technical inspection to be met by non-pressure and low-pressure tanks intended for the storage of flammable liquids (Journal of Laws 2001, No. 113, item 1211) Regulation of the Minister of Development of 2 June 2016 on simple pressure vessels (Journal of Laws of 2016, item 812) Regulation of the Minister of Economy of April 16, 2002 on the technical conditions of technical inspection to be met by non-pressure and low-pressure tanks intended for the storage of poisonous or corrosive materials (Journal of Laws of 2002, No. 63, item 572) Regulation of the Council of Ministers of 7 December 2012 on the types of technical devices subject to technical inspection (Journal of Laws of 2012, item 1468)	Competent, trained person.	Periodic frequency, in accordance with regulations and/or manufacturer's instructions and hazard assessment.
ROI	Local Government (Water Pollution) Act 1977	Competent person.	Not specified
SK	Act No. 364/2004 Coll. on Waters Ordinance No. 200/2018 Coll., laying down details on the treatment of pollutants, on the details of the emergency plan and on the procedure for dealing with extraordinary water deterioration STN 75 3415/Z1: Water protection against petroleum substances. Plants for handling of petroleum matters and their storage. STN 65 0201/Z2: Flammable liquids. Plants and storage rooms.	Competent person. Usually outsourced.	Regular frequency in accordance with manufacturer's instructions.
UK	The Control of Pollution (Oil Storage) (England) Regulations 2001 (legislation.gov.uk) Control of Pollution (Oil Storage) (Wales) Regulations 2016 The Water Environment (Oil Storage) (Scotland) Regulations 2006 Control of Pollution (Oil Storage) Regulations (Northern Ireland) 2010	Competent person.	Regular inspection of the oil tanks and associated pipework/structures. Best practice is 1 year.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Waste
APM Object	CT.ENVIRO.WASTE
APM Description	Equipment associated with controlled non-hazardous and hazardous waste
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Maintenance of waste infrastructure for sites producing, importing, carrying, keeping, treating, recycling or disposing of controlled non-hazardous and hazardous waste.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
CZ	13	No additional requirements	Duration of storage of both hazardous and non-hazardous waste at the place of production must be less than 1 year.	No additional requirements	Provide annual report to Ministry of Environment of waste evidence - deadline is 28 February to report on previous year						CT		
DE	6	No additional requirements	Site plans of the container locations and photographs of the staging areas.	No additional requirements	Site Plan						CT		
DE	7	Annual	Declaration of the waste disposal company about the type of treatment.	No additional requirements	Declaration						CT		
ES	12	No additional requirements	Hazardous waste storage time cannot exceed 6 months. Non-hazardous waste storage time cannot exceed 12 months. All unless expressly permitted by the Regional Authorities.	No additional requirements	No additional requirements					CT			
FR	8	Monitor to ensure suitable containers available.	Sufficient containers must be provided to allow plastic, glass, cardboard, wood and metal to be stored separately.	No additional requirements	Records of waste transfers to private companies must be kept for at least 5 years.						CT		

FR	9	Monitor to ensure suitable containers available.	Recycling of biowaste is mandatory if production is more than 10 tonnes.	No additional requirements	Waste Management Plan.						CT		
IT	10	Annual	Annual presentation of the MUD declaration (art. 189 of Legislative Decree 152/2006).	No additional requirements	MUD declaration (submitted by websites).						CT		
IT	11	Ongoing	If the stored waste has a volume of more than 30 m3 (of which maximum 10 m3 of hazardous waste), then waste must be sent to recovery/disposal within 3 months of their production.	No additional requirements	MUD declaration (submitted by websites).			CT					

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree No. 8/2021 Coll., waste catalogue. No. 541/2020 Coll. Waste Act Act No. 258/2000 Coll., health protection.	Competent person.	Regular inspection of waste storage areas to ensure compliance. Keep records of amount, type and removals. Records of handed over wastes – amount, type, to whom. Record on HW transport. No frequency defined.
DE	Kreislaufwirtschaftsgesetz (KrWG) Gewerbeabfallverordnung (GewAbfV) Nachweisverordnung (NachwV) Abfallverzeichnis-Verordnung, AVV Verordnung über Anlagen zum Umgang mit wassergefährdenden Stoffen (AwSV)	Expert (sachverständige) according to AwSV) for water endangering substances i.e. oils. Competent person for other waste bins.	Not regulatory frequency of inspections defined. Based on contract with waste management company.
ES	Law 22/2011, on contaminated waste and soil. Royal decree 553/2020 on the shipment of waste Royal Decree 833/1988 on hazardous waste	Competent person.	Not regulatory frequency of inspections defined.
FR	Ministerial order of 2nd Feb 1998 – articles 44 to 46	Private company or competent person.	Inspection frequency as per contract with waste management company or maintenance best practice. Maximum duration of storage of 1 year.
IT	CE Decision 18/12/2014 RUE 1357/2014 Legislative Decree n.152 of 3 April 2006 - Environmental code Presidential Decree n. 254 of 15 July 2003 - on Sanitary Waste Management Ministerial Decree of 27 September 2010 - regarding the criteria and procedures for the acceptance of waste at landfills	Competent person.	Duration of storage of both hazardous and non-hazardous waste at the place of production must be less than 1 years. If the stored waste has a volume of more than 30 m3 (of which maximum 10 m3 of hazardous waste) waste must be sent do recovery/disposal within 3 months from their production. Regular inspection of waste storage areas to ensure compliance. The temporary storage of hazardous medical waste presenting a risk of infection must be manage in such a way as not to cause any deterioration which would pose a risk to health and may last up to five days from the time the container is closed. Under the responsibility of the producer, this period shall be extended to 30 days for quantities of less than 200 liters. If the waste characterization is required, the characterization shall be carried out at the first delivery to the
PL	Act of December 14, 2012 on Waste Journal Of April 27, 2001 on environmental law (Journal of Laws 2020, item 1219) Act of September 13, 1996 on maintaining cleanliness and order in communes (Journal of Laws, 2020, item 1439) Regulation of the Minister of the Climate of 2 January 2020 on waste catalogue (Journal of Laws 2020, item 10) Regulation of the Minister of Climate of September 11, 2020 on detailed requirements for the storage of waste (Journal of Laws of 2020, item 1742) Regulation of the Minister of Economy of 5 October 2015 on the detailed handling of waste oils (Journal of Laws of 2015, item 1694)	Competent, trained person	Regular supervision of waste storage areas, following internal procedures. Register in State BDO system as waste producer and upload records. Not regulatory frequency of inspections defined. Based on contract with waste management company.
ROI	Waste Management (Hazardous Waste) Regulations, 1998 (S.I. No. 163 of 1998) Waste Management Act 1996 (as amended) (S.I. No. 10 of 1996) and European Communities (Waste Directive) Regulations 2011 (S.I. 126 of 2011)	Competent person.	No specific regulatory frequency for inspection or other storage requirements.
SK	Act No. 79/2015 Coll. on Waste Ordinance No. 371/2015 Coll., which implements certain provisions of the Waste Act Ordinance No. 365/2015 Coll., which establishes the Waste Catalogue	Competent person. Disposal through a certified organisation.	No specific regulatory frequency for inspection or other storage requirements.

UK	Environmental Protection Act 1990 (legislation.gov.uk) The Waste (England and Wales) Regulations 2011 (as amended) The Hazardous Waste (England and Wales) Regulations 2005 (as amended) Environment (Northern Ireland) Order 2002 The Waste Regulations (Northern Ireland) 2011 The Hazardous Waste Regulations (Northern Ireland) 2005 The Special Waste Regulations 1996 (as amended) The Environmental Protection (Duty of Care) (Scotland) Regulations 2014	Competent person.	Inspection frequency not regulated, ongoing compliance required.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Building technical and environmental review
APM Object	CT.FAC.BUILDING
APM Description	Building technical and environmental review
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	BLDG.INT BLDG.ROOF BLDG.EXT BLDG.EXTSURFACES +D&C structural assessment)	**Related CT Areas:**	CT.FAC.ROOFTOPINSPECT		

Scope

All sites should be structurally checked regularly to ensure that structural deficiencies, such as deteriorated or corroded beams and connections along with other issues like slippage and settlement in the foundation, cracks and holes in walls and floors, etc., are identified and corrected promptly.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Based on risk assessment (use and environmental conditions), but at least every 2 or 3 years.	Regular on-site structural system inspections to identify signs of deterioration (e.g. cracks, holes, etc.).	Competent person, usually internally sourced.	Records of periodic inspection Risk assessment	PM					EVID		
All		Based on risk assessment (use and environmental conditions), but at least every 4 or 5 years.	Regular professional visual inspections (extended on-site inspection).	Competent person, best practice to outsource	Records of periodic inspection Risk assessment								4Y
All		Based on risk assessment (use and environmental conditions), but at least every 12 or 15 years.	Regular detail structural inspection, which might include material testing.	Competent person, best practice to outsource	Records of periodic inspection Risk assessment								12Y
All		In line with engineer's recommendations or instructions.	Corrective or improvement actions need to be actioned to prevent further issues.	Competent person, best practice to outsource	Records of periodic inspection Risk assessment	PM					EVID		
All		12 monthly	Carry out the structural assessment owned using D&C SOP	Trained person	Records of periodic inspection Risk assessment						CT		

All		On off 2 months after PC	Engineering inspection	External consultant (e.g. civil engineer)	Inspection report								Check
All		On off 24 months after PC	Engineering inspection	External consultant (e.g. civil engineer)	Inspection report								Check
All		5 yearly inspection	Engineering inspection	External consultant (e.g. civil engineer)	Inspection report								5Y
All		Safety inspection 6 monthly in the first 2 years after PC	Follow D&C `s"Structural Inspection Handbook" https://quip-amazon.com/OgtHATffQjNK/Concrete-Inspection-Handbook#temp:C:JbC7edde02fa3754617a8e98c83b	External consultant (e.g. civil engineer)	Inspection report					CT			
All		Safety inspection 12 monthly starting 2 years after PC	Follow D&C `s"Structural Inspection Handbook" https://quip-amazon.com/OgtHATffQjNK/Concrete-Inspection-Handbook#temp:C:JbC7edde02fa3754617a8e98c83b	External consultant (e.g. civil engineer)	Inspection report					CT			
CZ		Regular revisions - from 1 year to 5 years	Regular revisions depending on the type of environment according to the Protocol on The Determination of External Influences	Review technician	Revision report	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60 months.
DE	VDI 6200 - Standsicherheit von Bauwerken - Regelmäßige Überprüfung Musterbauordnung (MBO) Relevant Building Codes of the pertinent Federal States (Landesbauordnung)	On-site inspection usually by site owner. Extended on-site and detailed inspections by competent person (befähigte Person)	Recommended that an initial inspection is conducted as soon as possible after taking over a property. On-site structural system inspections every 1-5 years, based on damage class (Schadensfolgeklase). Visual inspection (extended on-site inspection without the use of technical aids) every 2-5 years. Detailed inspection, including material testing if necessary, every 6-15 years. Unscheduled inspections should be carried out after extraordinary impacts such as subsidence, heavy snow, extreme weather events etc., or as soon as any damage to the building is observed.
ES	RD 314/2006, of March 17, which approves the Building Technical Code, and further modifications such us RD732/2019, of December 20. Structural Security Basic Document (DB SE) - Appendix D of existing buildings structural assessment.	Architect, technical architect, or structural engineer associated with any Official Architect or Engineer Association.	Responsibility of maintaining the workplace in a good condition. Regular inspections of structural condition of workplaces based on information recompilation, structural analysis, verification, and qualitative assessment. Inspection's periodicity according to assessments results.
FR	Labor Code Art R4224-17 to 19 relating to site and installation maintenance https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532199/	On-site inspection by competent person	Responsibility of maintaining the workplace in a good condition, including walls and floors. Regular inspections of structural condition of workplace (e.g. cracks, uneven floors, etc.), based on risk assessment.
IT	Legislative Decree 9/04/2008 n.81 DPR 06/06/2001 n.380	Competent person.	Regular inspections of structural condition of workplace based on the maintenance program, contained in the worksheet (Fascicolo dell'Opera) provided by the building design coordinator.

PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333)	Competent person.	Responsibility of maintaining the workplace in a good condition, including walls and floors. Regular inspections of structural condition of workplace (e.g. cracks, uneven floors, etc.),
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, usually outsourced to specialist company or engineer.	Responsibility of maintaining the workplace in a good condition, including walls and floors. Regular inspections of structural condition of workplace (e.g. cracks, uneven floors, etc.), based on risk assessment.
SK	STN 73 2011/a Non-destructive testing of concrete structures STN ISO 13822 Bases for design of structures. Assessment of existing structures STN EN 15643-1 Sustainability of construction works. Sustainability assessment of buildings. Part 1:General framework	Competent person, usually outsourced to specialist company or engineer.	Regular inspection (by owner or administrator of building) of conditions, including walls and floors, inspections of structural condition of workplace (e.g. cracks, uneven floors, etc).
UK	The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 (legislation.gov.uk)	Competent person, usually outsourced to specialist company or engineer.	Responsibility of maintaining the workplace in a good condition, including walls and floors. Regular inspections of structural condition of workplace (e.g. cracks, uneven floors, etc.), based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Drainage system inspection
APM Object	CT.FAC.DRAIN
APM Description	Drainage system, above and below ground, including gutters and pipes
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.RAINCOLL BLDG.DRAIN	**Related CT Areas:**	Not Specified		

Scope

All sites should conduct routine maintenance and inspections of the drainage system, including gutters, down pipes, and surface water and sewage pipe network to ensure they are free from blockages and prevent environmental pollution incidents and flooding.
Note that interceptor maintenance is covered in CT.ENVIRO.INTERCEPTOR and pumps associated with surface water and sewerage are covered in CT.SEWAGE.RAINWATERPUMP and CT.SEWAGE.SEWAGEPUMP.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Frequency dependant on environmental conditions (e.g. leaf fall) and surroundings, known issues etc, but at least 6 - monthly.	Regular visual checks and maintenance of all building drainage elements such as gutters, down pipes, drains, etc (including cleaning, leak inspections, signs of damage, etc.)	Competent person	Maintenance and inspection records.	PM					EVID		
All	2	CCTV drain inspections recommended if signs of blockages, damage or leaks to ground are identified.	CCTV inspection of waste and rainwater drains/sewers to ensure they are free from blockages or damage and to identify potential leaks to ground.	Competent person, best practice to outsource	Maintenance and inspection records.	PM					EVID		
All	3	Frequency dependent on risk assessment but at least annually.	Testing and inspection of pollution control valves installed in the drainage system (if fitted).	Competent person	Inspection records	PM					EVID		
DE	4	Every 20 years for domestic-type wastewater.	Inspection as per [2].	No additional requirements	Inspection records.	(PM)					EVID		
IT	5	No additional requirements	No additional requirements	No additional requirements	Worksheet of the building (Fascicolo dell'Opera)	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	N/A	N/A	N/A
DE	Wasserhaushaltsgesetz (WHG) Self-monitoring Ordinance (Selbst- / Eigenkontrollverordnung) of the Federal States DIN 1986-3 - Entwässerungsanlagen für Gebäude und Grundstücke - Teil 3: Regeln für Betrieb und Wartung DIN 1986-30 - Entwässerungsanlagen für Gebäude und Grundstücke - Teil 30: Instandhaltung	Competent person (befähigte Person), best practice to outsource to specialist company (Fachbetrieb	Regular visual inspection of drainage facilities at least twice a year. According to DIN 1986-30, a tightness inspection must be conducted every 5 years for sites located in water protection zone II, every 15 years for sites located in water protection zones III and III A, and every 30 years in other locations. CCTV inspection of waste or rainwater sewer to detect obstruction or leaks at least every 5 years for systems located before a wastewater treatment plant, and for systems after a wastewater treatment plant every 20 years, or every 30 years for the first inspection of new systems with verifiable testing.
ES	RD 314/2006, of March 17, which approves the Building Technical Code, and further modifications such us RD732/2019, of December 20. Health Standards Basic Document (DB HS) – Water Discharge: DB HS3.	Competent person, best practice to outsource to specialist company.	Periodic maintenance according to DB HS5 (evacuación de aguas) – Section 7: - Every 6 month: cleaning of drains and gullies - Every year: sump boxes and the rest of the possible elements of the installation such as manholes or lifting pumps will be cleaned. - Every 10 years: cleaning of downpipe and drains, or before if smells are generated
FR	N/A	N/A	No additional requirements Observe local site permit and waste/rain water releases agreement from local municipality
IT	Legislative Decree 9/04/2008 n.81 DPR 06/06/2001 n.380	Competent person.	Regular maintenance and cleaning of gutters based on the maintenance program, contained in the worksheet (Fascicolo dell'Opera) provided by the building design coordinator. Frequency in dependence on weather conditions and location, best practice is every year. CCTV inspection of waste or rainwater sewer recommended if there are signs of blockages or leaks.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333) Act of 7 June 2001 on collective water supply and collective sewage disposal. (Journal of Laws 2020, item 2028) Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624)	Competent person.	Regular maintenance and cleaning of gutters. Frequency dependant of weather conditions and surroundings, but at least annually.
ROI	S.I. No. 547/2008 - European Communities (Environmental Liability) Regulations 2008 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Regular maintenance and cleaning of gutters. Frequency dependant of weather conditions and surroundings, but at least annually. CCTV inspection of waste or rainwater sewer recommended if there are signs of blockages or leaks.
SK	Act No. 442/2002 Coll. on public water supply and public sewerage STN 73 6760 Drainage systems inside buildings STN EN 752 Drain and sewer systems outside buildings - Sewer system management	Competent person, best practice to outsource to specialist company.	Inspection of sewerage network (Twice per year) Cleaning of drains and pipes (Annually) Maintenance of shafts (Annually) Restoration of coatings, grids (Annually)
UK	The Environmental Damage (Prevention and Remediation) (England) Regulations 2015 (legislation.gov.uk) The Environmental Damage (Prevention and Remediation) (Wales) Regulations 2009 (legislation.gov.uk) The Environmental Liability (Scotland) Regulations 2009 (legislation.gov.uk) The Environmental Liability (Prevention and Remediation) Regulations (Northern Ireland) 2009 (legislation.gov.uk) The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk)	Competent person, best practice to outsource to specialist company.	Regular maintenance and cleaning of gutters. Frequency dependant of weather conditions and surroundings, but at least annually. CCTV inspection of waste or rainwater sewer recommended if there are signs of blockages or leaks. Annual testing and inspection of pollution control valves installed in the drainage system (if fitted).

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Rooftop inspection
APM Object	CT.FAC.ROOFTOPINSPECT
APM Description	Rooftops
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.ROOF	**Related CT Areas:**	CT.FAC.BUILDING		

Scope

All sites should undertake routine rooftop inspections to ensure stability, adequate condition of all roof features, such as flues, parapet walls, etc., in order to prevent or minimise health and safety risks to employees and visitors.
Note the inspection of the remaining building fabric is covered in CT.FAC.BUILDING

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Based on risk assessment and building O&M manual but at least annually.	Routine maintenance and cleaning of rooftop areas.	Competent person, usually internally sourced	Inspection records, report of certificate. Risk assessment.	PM					EVID		
All	2	Based on risk assessment (use and environmental conditions and building O&M manual), but at least annually.	Regular inspection of the rooftops. This includes roof surface and coverings, general condition to prevent leaks, inspection of flues and chimneys (if present), parapet walls, internal structure (e.g. signs of stress), etc.	Competent person, best practice to outsource	Inspection records, report of certificate. Risk assessment.	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll. Act No. 133/1985 Coll. Decree No. 34/2016 Coll.	Competent person, best practices for outsourcing to a specialist. chimney sweep	Inspection and maintenance every 12 months
DE	DIN 18531-4 - Abdichtung von Dächern sowie von Balkonen, Loggien und Laubengängen - Teil 4: Nicht genutzte und genutzte Dächer - Instandhaltung	Competent person (befähigte Person), best practice to outsource to specialist company (Fachbetrieb)	Maintenance and cleaning from contamination conducted annually. Recommended twice a year maintenance and inspection of the roof surface, its connections and terminations of the penetrations and transitions to neighbouring surfaces and, if necessary, the condition of the surface layers.

ES	RD 314/2006, of March 17, which approves the Building Technical Code, and further modifications such us RD732/2019, of December 20. Health Standards Basic Document (DB HS) – Protection against humidity: DB HS1. Section 2.4: roofs.	Competent person, best practice to outsource to specialist company.	Responsibility of maintaining the workplace in a good condition, including rooftops. Regular inspections based on risk assessment and in accordance with a planned safe system of work.
FR	Labor Code Art R4224-17 to 19 relating to site and installation maintenance. Code du travail article R4224-17 à 19 relatifs à la maintenance du site et de ses installations https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532199/	On-site inspection by competent person.	Responsibility of maintaining the workplace in a good condition, including rooftops. Regular inspections based on risk assessment and in accordance with a planned safe system of work.
IT	Legislative Decree 9/04/2008 n.81 DPR 06/06/2001 n.380	Competent person.	Regular inspections of structural condition of workplace (including rooftops) based on the maintenance program, contained in the worksheet (Fascicolo dell'Opera) provided by the building design coordinator.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333)	Competent person.	Responsibility of maintaining the workplace in a good condition, including rooftops. Regular inspections based on risk assessment.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, usually outsourced to specialist company or engineer.	Responsibility of maintaining the workplace in a good condition, including rooftops. Regular inspections based on risk assessment.
SK	Ordinance No. 391/2006 Coll. on the minimum safety and health requirements for the workplace STN 73 1901 Designing of roofs. Basic provisions	Competent person, usually outsourced to specialist company or engineer.	Regular inspection of roof by the owner or administrator of the building.
UK	The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 (legislation.gov.uk) The Work at Height Regulations 2005	Competent person, usually outsourced to specialist company or engineer.	Responsibility of maintaining the workplace in a good condition, including rooftops. Regular inspections based on risk assessment and in accordance with a planned safe system of work.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Aspirating Smoke Detectors (ASD)
APM Object	CT.FIRE.ASD
APM Description	Aspirating air sampling systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.DET.FIREALRM	**Related CT Areas:**	Not Specified		

Scope

Any site where aspirating air samplers are used as a replacement or supplement to smoke detectors to aid in fire prevention strategies and plans.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 12 months.	Inspection and testing of VESDA air sampling systems		Inspection records, report or certificate	PM					EVID		
IT	2	Every 6 months	Inspection as per [1]	No additional requirements	No additional requirements	(PM)					EVID		
IT	3	Every 12 years	Review of the compliance of the installation	No additional requirements	No additional requirements								12Y CT
SK	4	In case of a need to perform more frequent than annual inspection, inspection is performed: Daily (changes in reported parameters); Monthly (mechanical check, communication channels); or	Inspection as per [1].	No additional requirements	No additional requirements	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 54-20:2007. Fire detection and fire alarm systems - Part 20: Aspirating smoke detectors.	Quarterly servicing by competent person Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Routine checks (maintenance) every 3 months. Official maintenance operation every year. Inspections every 10 years.
FR	Labour Code Article R47227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person. APSAD and NF certified companies	Inspection every 6 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11224:2019 (Maintenance)	Competent, qualified person, best practice to outsource to specialist.	Routine maintenance in accordance with manufacturer's instructions. Inspections every 6 months. Review of the compliance of the installation every 12 years.
PL	Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person	In accordance with manufacturer's instructions, but at least yearly.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. 3218:2013 Fire Detection and Alarm Systems for Buildings - System Design, Installation, Commissioning, Servicing and Maintenance NSAI	Competent person, best practice to outsource to specialist.	Inspection and testing every 12 months.
SK	Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent person, best practice to outsource to specialist. (e.g. fire protection technician)	Regular inspections. In case annual inspection is performed, more frequent inspections are not needed.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice	Competent person, best practice to outsource to specialist.	Inspection and testing every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Fire dampers
APM Object	CT.FIRE.DAMPERS
APM Description	Fire dampers of all types including (for example) curtain, pivot and intumescent.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where fire dampers are used to prevent fire (when occurring) from escaping the room where it originated through ducting vents.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 12 months.	Regular inspection and servicing of fire dampers	Competent person (e.g. fire safety engineer)	Inspection records, report or certificate						CT		
DE	2	Every 6 months. *If no defects are found during 2 consecutive inspections, frequency is changed to 12 months.	Inspection as per [1]	No additional requirements	No additional requirements					CT*			
ES	3	6 months	Regular maintenance of fire dampers to ensure correct operation	Accredited company	No additional requirements					CT			
IT	4	Every 6 months	Inspection as per [1]	No additional requirements	CE Declaration of Conformity.					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company – manufacturer trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) DIN EN 15650/ Muster-Verwaltungsvorschrift Technische Baubestimmungen des DIBt (MVV TB) DIN EN 13306 DIN 31051	Competent person according to state building law (befähigte Person)	Inspection before commencement, in case of significant changes and at regular intervals: Inspection and servicing every 6 months. If 2 consecutive inspections show no defects, inspections can be done yearly. In certain cases, inspection can be omitted; if: The release is thermoelectric and not via a fusible link; Fire dampers are equipped with actuators on which function tests can be carried out by remote control; Moving parts are secured with an enclosure; and Functional tests are carried out at least once a month.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) RD 842/2013, of October 31, approving the classification of construction products and construction elements based on their reaction properties and resistance to fire.	Qualified person or competent external company	Maintenance (functional) before commissioning and every 6 months. Inspections every 10 years.
FR	Labor Code Article R4227-28 to 33: Firefighting and prevention means https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	Qualified person or competent external company	Maintenance (functional) before commissioning.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI EN 15423:2008 (Maintenance) UNI EN 15650:2010 (Fire dumpers)	Competent, qualified person, best practice to outsource to specialist	Checks conducted every 6 months (Cleaning and visual inspection, checks of opening/closing mechanism).
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Inspection by competent engineer	Inspected and serviced yearly.
SK	Ordinance No. 478/2008 Coll. on the properties, specific operating conditions and ensuring regular inspection of the fire separation closures Ordinance No. 121/2002 Coll. on fire prevention	Qualified & certified person	Inspection every 12 month unless stated otherwise by operating instructions.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice.	Inspection by competent engineer	Inspected and serviced yearly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire Doors
APM Object	CT.FIRE.DOORS
APM Description	Fire doors
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	FIRE.DOOR	**Related CT Areas:**	Not Specified		

Scope

Any site where fire doors are installed to aid in the event of a fire, by either preventing the fire from spreading between compartments or to provide means of escape

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance and visual checks	Competent person, generally outsourced	Maintenance logbook	PM					EVID		
All	2	Based on risk assessment, but at least every 12 months.	Thorough inspection of mechanical and electrical components to ensure fire safety.	Competent person, generally outsourced	Risk assessment Inspection records, report or certificate	PM					EVID		
DE	3	Every 3 months	Functional inspection of electrically controlled systems	Not additional requirements	Not additional requirements	PM					EVID		
DE	4	Every 3 years	Additional inspection for effectiveness in accordance with building permit	Expert according to building law	Inspection records								36 Month CT
IT	5	Visual check every month. Inspection every 6 months.	Inspection as for [1] & [2]	No additional requirements	CE Declaration of Conformity (Commercial, garage and external use doors only).	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company – manufacturer - trained worker	Inspection conducted every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) Federal State construction laws and according to building permits Technische Regel für Arbeitsstätten ASR A1.7 - Türen und Tore DGUV Information 208-022 Türen und Tore DGUV Information 208-026 Sicherheit von kraftbetätigten Karusselltüren DIN 14677 - Instandhaltung von elektrisch gesteuerten Feststellanlagen für Feuerschutz- und Rauchschutzabschlüsse sowie für elektrisch gesteuerte Feststellanlagen für Feuerschutzabschlüsse im	competent person (befähigte Person) for fire doors according to ASR A1.7 Expert (Sachverständiger) according to state building law	Manufacturer's operating, maintenance and test instructions have to be met. Inspection before the first commencement, significant changes and at regular intervals, at least every 12 months. Functional inspection by operator monthly and by competent person annually. Electrically-controlled systems need to have functional inspections conducted quarterly. Additional inspection for effectiveness in accordance with building permit every 3 years.
ES	RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA). RD 842/2013, of October 31, approving the classification of construction products and construction elements based on their reaction properties and resistance to fire. UNE 23740-1:2016: Fire safety. Shutter assemblies' elements. Specific requirements for installation, use and maintenance. Part 1 Fire doors.	Qualified person or competent external company	Maintenance (functional) before commissioning.
FR	Labor Code Article R4227-28 to 33: Firefighting and prevention means https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams	N/A	N/A
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11473-1:2013 (Maintenance) UNI EN 16034:2014 (Performance requirements)	Competent, qualified person.	Visual checks (surveillance) usually monthly. Inspection every 6 months (check, lubrification, adjustment). Ordinary and extraordinary maintenance in the event of anomalies detected.
PL	Act of July 7, 1994 - Construction Law (Journal of Laws of 1994, No. 89, item 414) Regulation of Minister of Interior and Administration of 7 June 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of the Minister of Internal Affairs and Administration of 24 July 2009 on firefighting water supply and fire roads (Journal of Laws of 2009, No. 124, item 1030).	Qualified or competent person (e.g. fire specialist)	According to manufacturers instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) British Standard 476 Fire Tests EN 1364-1: Fire resistance tests for non-loadbearing elements	Competent person, best practice to outsource to specialist.	Routine maintenance in accordance with manufacturer's recommendations. Inspection frequency based on risk assessment, but at least yearly.
SK	Ordinance No. 478/2008 Coll. on the properties, specific operating conditions and ensuring regular inspection of the fire separation closures Ordinance No. 121/2002 Coll. on fire prevention	Qualified & certified person	Inspection every 12 months unless stated otherwise by operating instructions.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice British Standard 476 Fire Tests EN 1364-1: Fire resistance tests for non-loadbearing elements	Competent person, best practice to outsource to specialist.	Routine maintenance in accordance with manufacturer's recommendations. Inspection frequency based on risk assessment, but at least yearly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Dry risers
APM Object	CT.FIRE.DRYRISERS
APM Description	Dry risers.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP.DRYRISERS	**Related CT Areas:**	Not Specified		

Scope

Any site where dry risers are installed to aid firefighters in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 6 months.	Routine maintenance to ensure correct operation of the dry risers, including valves, brackets, joints, etc.	Competent person (engineer), generally outsourced	Maintenance logbook	PM					EVID		
All	2	Every 12 months	Water pressure test.	Competent person (engineer), generally outsourced	Inspection & test records	PM					EVID		
ES	4	Every 6 months	Visual checks of pipes, tanks and hoses and their infrastructure	No additional requirements	No additional requirements					CT			
ES	5	At least every 3 months.	Inspection as per [1]	No additional requirements	No additional requirements				CT				
FR	3	No additional requirements	Inspection as per [1] & [2]	No additional requirements	Fire/Security register	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspections and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) DIN 14461-6 - Feuerlösch-Schlauchanschlusseinrichtungen - Teil 6: Wandhydranten mit Flachschlauch für geschultes Personal DIN 14462 - Löschwassereinrichtungen - Planung, Einbau, Betrieb und Instandhaltung von Wandhydrantenanlagen sowie Anlagen mit Über- und Unterflurhydranten	Competent person (befähigte Person) according to DIN 14462	Inspections by experts before commissioning and after significant changes. Inspection frequency in accordance with manufacturer's instructions. Every 2 years, the dry risers with their hose connection devices must be subjected to a cold water pressure test. A test report shall be prepared on the test. Quarterly visual inspections by operator.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 12845:2016+A1:2021. Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance	Quarterly and half-year servicing by competent person. Maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular maintenance of extinguishing agents and system components, including reading and checking manometers, checking signalling circuits and general cleaning every 3 months. Visual checks of pipes, tanks and hoses and their infrastructure every 6 months. Fully inspection every 1, 3 and 5 years. Intrusive Inspections every 10 years.
FR	Labor Code Article R4227-28 to 33 : Firefighting and prevention means https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Qualified person or competent external company	Inspections every 12 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI/TS 11559:2014 (Dry risers) UNI 10779:2021 (Fire hydrant networks)	Competent, qualified person, best practice to outsource to specialist.	Maintenance every 6 months (Valves manoeuvrability and status conditions of the coupling device, after completing operations ensure that the main shut-off valve is in the open positions) Functional testing (pressure test) and servicing every 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 24 July 2009 of the Minister of the Interior and Administration on fire water supply and fire routes (Journal of Laws 2009, number 124, item 1030)	Qualified or competent person	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Annual pressure test and inspection annually.
SK	Ordinance No. 699/2004 Coll. on securing buildings with fire - fighting water	Competent person, best practice to outsource to specialist.	Inspections every 12 months unless more frequent inspection is prescribed by producer.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999: 2017 - Fire safety in the design, management and use of buildings. Code of practice BS 5306 – Fire extinguishing installations BS 9990:2015 - Non automatic fire-fighting systems in buildings	Competent person, best practice to outsource to specialist.	Visual inspection (maintenance) at least every 6 months. Water pressure test every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire Evacuation
APM Object	CT.FIRE.EVACUATION
APM Description	Evacuation tests / Fire drills
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.FIRE.FRAMANAGEMENT		

Scope

All sites are required to have a site-specific fire emergency evacuation plan which should be based on the risks identified as part of the Fire Risk Assessment (covered under "Fire Risk Management (FRA)")
Fire drills or evacuation tests are essential elements of fire safety and aim to provide a comprehensive understanding of the fire evacuation procedures, risks and strategy to all employees.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Based on risk assessment, but at least annually. Additionally, following any changes to the building, occupants, activities, etc.	Review of fire emergency evacuation plan to ensure all procedures are suitable. It needs to be communicated to all employees and visitors.	Competent person	Fire emergency evacuation plan						CT		
All	2	Frequency of fire drills based on fire risk assessment, but at least once a year.	Evacuation test or fire drill to familiarise employees with the emergency procedures in place Drill shall assess, whether; •the alarm can be triggered immediately at any time, •the alarm reaches all persons who are in the building, •all persons in the building are aware of the significance of the respective alarm, •the escape routes can be used quickly and safely.	Competent person, but generally delivered by site manager or owner	Written fire risk assessment, Records of attendance Summary of fire drill Any actions and evidence to follow up						CT		
FR	3	^ Monthly fire drill	As per [2]	Competent person, but generally delivered by site manager or owner	Written fire risk assessment, Records of attendance Summary of fire drill Any actions and evidence to follow up					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Competent person in fire protection	According to the set exercise schedule, but at least once in 12 month.

DE	Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten: ASR A2.2 - Maßnahmen gegen Brände ASR A2.3 - Fluchtwege und Notausgänge, Flucht- und Rettungsplan	Employer, supported by fire protection and evacuation assistants	Evacuation tests should be completed at least annually based on the emergency and rescue maps (Flucht- und Rettungspläne).
ES	RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA). RD 393/2007, of March 23, which approves the Self-Protection Basic Regulation on premises, facilities and all spaces dedicated to activities which may give rise to emergency situations.	Competent person or company.	The self-protection emergency plan must be reviewed at least every 3 years. Evacuation simulations at least once per year.
FR	Labor Code Article R4227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386	Competent person, but generally delivered by site manager or owner.	Fire drills to be completed every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DM 10/03/1998 (Currently being replaced)	Competent person, but generally delivered by site manager or owner.	Mandatory in businesses with more than 10 employees or in activities subject to control by the Fire Brigade in accordance with DPR 151/2011. Fire and evacuation drills to be completed every 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869)	The owner or manager	For buildings with more than 50 regular workers, every 2 years.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety Signs at a Place Work - Health and Safety Authority (hsa.ie)	Competent person, often delivered by manager or owner.	Fire drills frequency based on fire risk assessment, but at least annually.
SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 121/2002 Coll. on fire prevention	Competent person, generally a fire protection technician	Fire drills every 12 months.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS 5499 - Safety Signs, Including Fire Safety Signs ISO 7010 - Safety colours and safety signs — Registered safety signs BS 5839 – Fire detection and fire alarm systems for buildings	Competent person, often delivered by manager or owner	Fire drills frequency based on fire risk assessment, but at least annually.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire alarm system (FAS)
APM Object	CT.FIRE.FAS
APM Description	Fire Alarm System (FAS).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.DET.FIREALRM	**Related CT Areas:**	Not Specified		

Scope

All sites are required to have a suitable and sufficient fire detection system. The complexity of the fire detection system will depend on the site-specific fire risk assessment, which is covered under CT.FIRE.FRAMANAGEMENT, and will be based on the size and complexity of the premises, the type of activities undertaken or materials stored, the presence of vulnerable occupants and the ease of spotting and making everyone aware of a fire.
Small, single-storey or open-plan premises, where no high-risk substances are stored, no high-risk activities are undertaken, no vulnerable occupants can be present and where a fire is easy to spot and a shout of "fire" would be easily heard might be exempt from requiring a Fire Alarm system.
If either of these conditions does not apply to your premises, then a Fire Alarm System is likely to be required.
Inspection and testing of heat and smoke detectors is covered under CT.FIRE.SMOKEDETECT.
Fire drills and evacuation tests are covered under CT.FIRE.EVACUATION

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	Fire alarm test to ensure correct operation, including Voice communication.	Competent person, generally internal	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment		CT						
All	2	Based on risk assessment, but at least every 6 months	Routine maintenance and servicing of the Fire Alarm System in its entirety.	Competent person (e.g. Fire safety assessor / engineer)	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment	PM					EVID		
All	3	Based on risk assessment, but at least every 6 months	Inspection and servicing of Voice Communication Systems / Voice Alarm Systems.	Competent person (e.g. Fire safety assessor / engineer)	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment					CT			
All	4	Based on risk assessment, but at least annually. Electrical emergency lighting covered under "Emergency lighting systems"	Fire signing inspection and testing	Competent person (e.g. Fire safety assessor / engineer)	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment	PM					EVID		
DE	6	3 years	Additional inspection in accordance with building law.	Expert (Sachverständiger) in accordance with building law	No additional requirements								3 year (CT)

DE	7	3 months	Visual and functional inspection of FAS	No additional requirements	No additional requirements	(PM)					EVID		
DE	8	Every 3 months and at regular intervals when inspection FAS	Inspection of notifier and data transmission system to the fire brigade	No additional requirements	No additional requirements	(PM)					EVID		
ES	9	Every 3 months	Maintenance of FAS, including functional checks, replacements of faulty parts, etc.	Accredited company	No additional requirements	(PM)					EVID		
FR	5	No additional requirements	Inspection as per [1], [2], [3] and [4].	No additional requirements	Fire and security register	(PM)							N A R
IT	1	Daily.	Visual inspection of the control unit	No additional requirements	No additional requirements	PM					EVID		
IT	1	Every 12 years.	Review of the compliance of the installation	No additional requirements	No additional requirements								12 Year CT
SK	1	In case of a need to perform more frequent than annual inspection, inspection is performed daily (changes in reported parameters), monthly (mechanical check, communication channels) or quarterly (functional control	Inspection and testing of FAS	No additional requirements	No additional requirements	(PM)					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll. Act No. 133/1985 Coll. on fire protection. ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree No. 50/1978 Coll.	Monthly test trained by a worker from the device manufacturer Accredited company Review technician	Control of the control panel once a month Check fire sensors every 6 months. Inspection of the entire FAS (service) system annually. Voice communication system to be checked every year Inspection and testing of fire markings annually.
DE	Federal State building codes and building permit. Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A2.2 - Maßnahmen gegen Brände DIN 14675 - Brandmeldeanlagen, Teil: 1 Aufbau und Betrieb und Teil 2: Anforderungen an die Fachfirma DIN VDE 0833-1 - Gefahrenmeldeanlagen für Brand, Einbruch und Überfall - Teil 1: Allgemeine Festlegungen Model Ordinance for Inspections (Muster-Prüfverordnung)	Competent person FAS / qualified electrician FAS Inspection as per building permit by expert according to state building law	Visual and functional inspection of FAS and voice communication/alarm systems (VAS) conducted every 3 months. Annual maintenance of VAS and FAS in accordance with manufacturer's instructions. Additional inspection of FAS and VAS in accordance with building law every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE 23007: fire detection and fire alarm systems. UNE-EN 54-1. Fire detection and fire alarm systems	Quarterly servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Maintenance of FAS every 3 months, including functional checks, replacements of faulty parts and verifications. Every year by authorised maintenance company: software, programmed manoeuvres, and all existing manoeuvres. Inspection carried out by accredited company (OCA) every 10 years.
FR	Labor Code Article R4227-34 to 36 relating to Alarm system https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489143/#LEGISCTA000018532069 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	Qualified person or competent external company	FAS Inspection yearly and testing (firedrill) to be conducted every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11224:2019 (Maintenance)	Competent, qualified person, best practice to outsource to specialist	Daily surveillance of the state of the central control unit. Inspection and testing of FAS to be conducted every 6 months. Routine and extraordinary maintenance in the event of anomalies detected. Verification of the compliance of the installation every 12 years.

PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person (e.g. fire safety specialist)	Inspection and testing of the entire FAS in accordance with manufacturer's instructions, but at least yearly. Voice Communication system to be inspected in accordance with manufacturer's instructions, but at least yearly. Fire signage inspection and testing in accordance with internal procedures or good practice. Electric signage should be inspected at least yearly.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. 3218:2013 Fire Detection and Alarm Systems for Buildings - System Design, Installation, Commissioning, Servicing and Maintenance NSAI Safety Signs at a Place Work - Health and Safety Authority (hsa.ie)	Weekly testing by competent person (manager) Inspections and testing by competent person, generally outsourced.	Testing of the fire alarm system weekly. Annual inspection and test with maintenance (service) of all the components of the FAS at least every 6 months. Voice Communication Systems need to be tested weekly and serviced every 6 months. Fire signage should be inspected at regular intervals based on risk assessment.
SK	Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent person, best practice to outsource to specialist (e.g. fire protection technician)	Before activation of fire alarm system: Complex inspection During the use of fire alarm system: Annual inspection unless producer of equipment prescribes more frequent inspections.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS 5499 - Safety Signs, Including Fire Safety Signs ISO 7010 - Safety colours and safety signs — Registered safety signs BS 5839 – Fire detection and fire alarm systems for buildings	Weekly testing by competent person (manager) Inspections and testing by competent person, generally outsourced	Testing of the fire alarm system (including RED break glass point) weekly. Annual inspection and test with maintenance (service) of all the components of the FAS at least every 12 months. Voice Communication Systems need to be tested weekly and serviced quarterly and annually. Fire signage should be inspected at regular intervals based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Firefighting media
APM Object	CT.FIRE.FIGHTINGEQUIP
APM Description	Firefighting media (e.g. fire extinguishers, fire blankets, etc.).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

All sites with firefighting equipment (e.g. fire extinguishers, fire blankets, etc.).

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Based on risk assessment, but at least monthly.	Regular checks to ensure fire extinguisher are in good condition and are unused. If defects are identified, prevent subsequent use through quarantine prior to replacement – do Not use. Report issue.	Competent person, generally internal	Record of inspections Label must be affixed to the extinguisher after each inspection. Label must show type of extinguisher	PM					EVID		
All		Based on risk assessment, but at least yearly.	Servicing of all fire extinguishers.	Competent person, best practice to outsource (e.g. fire safety engineer).	Record of inspections Label must be affixed to the extinguisher after each inspection. Label must show type of extinguisher	PM					EVID		
All		Every 5 years for water, powder and foam fire extinguishers. Every 10 years for CO2 fire extinguishers.	Regular pressure and discharge test of all fire extinguishers (extended service)	Competent person, best practice to outsource (e.g. fire safety engineer).	Record of inspections Label must be affixed to the extinguisher after each inspection. Label must show type of extinguisher								5 year 10 Year (CT)
DE	4	Every 5 or 10 years	Additional inner inspection of pressure equipment depending on pressure of the pressure device.	Competent person according to TRBS 1203	Inspection records								5 year 10 Year (CT)
DE	5	Every 10 years	Additional strength / rigidity inspection of pressure equipment depending on pressure of the pressure device (Druckgerät)										10 Year (CT)

IT	7	Every 6 months	Inspection as for [2]	No additional requirements.	CE Declaration of Conformity.	(PM)					EVID		
ROI	6	Every 3 years	Test discharge (and refill) of all extinguishers every 3 years (recommended 33% of all extinguishers every year).	No additional requirements	Service record								3 Year (CT)

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll. CSN 73 0802, CSN 11602 - 2, CSN 73 0804, CSN 73 0873, CSN 73 0875	Accredited fire protection specialist	Optime control once a year. Pressure test every 3 years for water and foam fire extinguishers and every 5 years for each other type of fire extinguisher
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbstättV) Technische Regel für Arbeitsstätten ASR A 2.2 - Maßnahmen gegen Brände DIN 14406-4 - Tragbare Feuerlöscher - Teil 4: Instandhaltung Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen	Competent person (befähigte Person) Accredited inspection body (ZÜS) for inner and strength testing/ inspections according to BetrSichV	Based on risk assessment (use and operating conditions), but at least every 2 years for portable fire extinguishers. Additional inner inspection to assess pressure equipment every 5 years, and depending on the type of fire extinguisher, and additional strength test (Festigkeitsprüfung) every 10 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI)	Quarterly servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Check for accessibility, presence, condition, label, etc. every 3 months. Every 12 month by authorised maintenance company. Intrusive inspection carried out by accredited company (OCA) every 10 years.
FR	Labor Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	Checks by qualified or competent person. Service by certified company (APSAD, NF)	Check for accessibility, presence, condition, label, etc. every 6 months. Servicing of fire extinguishers annually.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 20/12/2012 DM 10/03/1998 (Currently being replaced) UNI 9994:2013 (Fire extinguishers maintenance) UNI EN 3-7:2008 (Performance requirements) Directive 2014/68/EU	Competent, qualified person, best practice to outsource to specialist.	Monthly check for accessibility, presence, condition, label and manometer's needle in green position (surveillance). Inspection of all fire extinguishers every 6 months (correct filling in of the maintenance card and check of the state of charge through weight measurement (CO_2) or independent pressure verification). Technical review every 24 months for water or foam extinguishers (48 months in presence of inox tanks), every 36 months for powder devices and every 60 months for CO_2 extinguishers. Testing every 6 years for foam devices (12 for inox tanks), 12 years for powder devices and every 10 years for CO_2 extinguishers.
PL	Regulation of the Minister of Internal Affairs and Administration dated 7 June 2010 on the fire protection of buildings, other buildings and sites OJ 2010 No 109, item 719 Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869)	Qualified or competent person (e.g. fire safety specialist)	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) I.S 291:2015 The Use, Siting, Inspection and Maintenance of Portable Fire Extinguishers NSAI	Competent person, best practice to outsource to specialist	Monthly checks to ensure fire extinguishers are in good condition and unused. Annual servicing 3 yearly test discharge and refill
SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 719/2002 Coll. on characteristics, operating conditions and ensuring regular inspection of portable fire extinguishers and mobile fire extinguishers	Qualified and certified person.	Every 12 months or 24 months depending on the type of fire extinguisher and manufacturer's instructions

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice	Monthly checks by competent person (internally). Inspection and servicing by competent person, best practice to outsource to specialist.	Monthly checks to ensure fire extinguishers are in good condition and unused. Annual inspection of all (P50 extinguishers only every 10 years). 5 yearly extended service for water, foam and powder fire extinguishers and 10 years for CO2 fire extinguishers.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire Risk Management (FRA)
APM Object	CT.FIRE.FRAMANAGEMENT
APM Description	Fire risk assessment
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

All non-domestic properties are required to complete a suitable and sufficient Fire Risk Assessment (FRA) specific to each site identifying the risks to relevant persons and the fire precautionary measures that need to be implemented in order to comply with relevant regulations, as well as the emergency procedures to follow in the event of a fire.
FRAs need to be reviewed and updated regularly to reflect the most up-to-date situation of the premises.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Before the premises are occupied for the first time. At regular intervals based on risk assessment, but at least every 12 months. Following any changes to the number of occupants, materials stored, furniture, equipment	A Fire Risk assessment needs to be completed for all non-domestic premises. As a minimum, it should cover fire detection systems, emergency exits, emergency signage and routes (including evacuation plans), firefighting equipment and the availability of information and advice to the building's occupants.	Competent person (e.g. fire risk assessor, fire technician engineer).	Current Fire Risk Assessment document Major findings and reportable issues.						CT		Additional As Required CT
IT	2	Before the premises are occupied.	CLASS A: submission of the SCIA and work project followed, on a sample basis within 60 days, by inspections of the Fire Brigade.	Fire Brigade	Certificato di Prevenzione Incendi (CPI). Segnalazione Certificata Inizio Attività (SCIA)								As Needed CT
IT	2a	Every 5 years for most activities.	CLASS B: presentation of the prior opinion of conformity for which the fire brigade gives an answer within 60 days, followed by the submission of the SCIA in the manner described above.	Fire Brigade	Certificato di Prevenzione Incendi (CPI). Segnalazione Certificata Inizio Attività (SCIA)								5Yr CT*
IT	2b	Every 10 years for activities listed in rows 6, 7, 8, 64, 71, 72, 77 of the Annex. I of DPR 151/20	CLASS C: submission of the prior opinion of conformity for which the Fire Brigade gives response within 60 days, followed by the presentation of the SCIA with systematic control of the Fire Brigade and release of the CPI	Fire Brigade	Certificato di Prevenzione Incendi (CPI). Segnalazione Certificata Inizio Attività (SCIA)								10Yr CT*
PL	3	Before the construction of the building and prior to any alteration that may affect fire safety.	Certain buildings are required to prove compliance with fire protection in relation to the purpose, method of usage, running technological process, the method of storage, fire hazards and technical conditions occurring in the building, including fire hazards ("Project reconciliation")	No additional requirements	Documentation to prove compliance with fire protection.								As Needed CT

PL	4	Reviewed after changes to the number of occupants, materials stored, furniture, equipment, activities or any alteration to the building.	Completion of a Fire Safety Instruction, including emergency procedures, drawings, etc.	Manager or owner	Fire Safety Instruction								As Needed CT
ROI	5	Before the construction of new buildings and alterations, changes to materials or use of existing buildings.	A Fire Safety Certificate is required prior to the construction of new buildings and alterations, changes to materials or use of existing buildings.	Fire safety consultant, architect or engineer for FSC	Fire Safety Certificate								As Needed CT

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Act. No. 133/1985 Coll.	Authorised person in the field of fire protection	Before the construction of new buildings and modifications, changes in materials or use of existing buildings, the development of a Fire Safety Solution for the construction is required
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten: ASR A2.2 - Maßnahmen gegen Brände ASR A2.3 - Fluchtwege und Notausgänge, Flucht- und Rettungsplan DIN 14095 - Feuerwehrpläne für bauliche Anlagen DIN 14096 - Brandschutzordnung - Regeln für das Erstellen und das Aushängen	Competent person (befähigte Person)	FRA needs to be completed before the premises are occupied, in case of significant (structural and technical) changes and regularly based on risk assessment but at least every 2 years
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA).	Accredited company (OCA) in case of inspections on industrial premises	FRA needs to be completed before the premises are occupied and every time any change in the facility is carried out. In case of industrial premises FRA needs to be inspected according to their Intrinsic Risk (art. 7 RD 2267/2004: 2, 3 or 5 years).
FR	Labor Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	No additional requirements	No additional requirements
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced)	Fire risk assessment conducted by a competent person (outsourced to specialist). Fire Prevention Certificate (CPI) and SCIA provided by Fire Brigade	FRA is required in businesses with more than 10 employees or for activities subject to control by the Fire Brigade in accordance with DPR 151/2011. Additional inspections to ensure appropriate building design in relation to fire safety required depending on the type of building and associated risk (Class A, B or C). Successful inspections lead to the provision of a Fire Prevention Certificate Certificato di Prevenzione Incendi – (CPI, for activities of Category C), which needs to be renewed every 5 years, ,every 10 years for activities listed in rows 6, 7, 8, 64, 71, 72, 77 of the Annex I of DPR 151/2011.
PL	Ordinance of the Minister of Internal Affairs and Administration of 7 June 2010 on Fire Safety of Buildings, Other Constructions and Sites (Dz.U. 2010, No. 109, Item 719), Section 36 Regulation of the Minister of Internal Affairs and Administration of 2 December 2015 on the reconciliation of the construction project in terms of fire protection Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869)	Qualified or competent person, best practice to outsource to fire safety expert.	FRA is part of general workplace risk assessment. Regular reviews, generally every 1 or 2 years, and following any significant changes that might affect fire risk. Additionally, businesses are required to complete a Fire Safety Instruction, which includes procedures in case of fire, drawings, fire equipment, etc. Certain buildings are required to prove compliance with fire protection in relation to the purpose, method of usage, running technological process, the method of storage, fire hazards and technical conditions occurring in the building, including fire hazards. This needs to be completed before the construction of the building and prior to any alteration that may affect fire safety.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) Fire - Health and Safety Authority (hsa.ie)Fire Services Act, 1981 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company (e.g. fire safety engineer or assessor) for FRA. Fire safety consultant, architect or engineer for FSC	FRA needs to be completed before the premises are occupied, and reviewed regularly. The frequency of the review is determined as part of the risk assessment, but it is good practice to do so at least every 12 months. FRA reviews should also be conducted before any changes to the occupants, the activities, the materials stored or located in the premises, and any alteration to the building. A Fire Safety Certificate is required prior to the construction of new buildings and alterations, changes to materials or use of existing buildings.
SK	Ordinance No. 94/2004 Coll. technical requirements for fire safety during construction and use of buildings Ordinance No. 611/2006 Coll. on fire-fighting brigades	Competent and certified person	FRA needs to be completed before the premises are occupied. FRA is being prepared on the request from the side of fire-surveillance authority. Analysis needs to be adapted based at changed conditions within the time frame of 3 month from the factual change of situation.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) BS 9999 : 2017 The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) BS 9999 : 2017 – Fire safety in the design, management and use of buildings. Code of practice. DocHdl1OnPTRSERVERtmpTarget (publishing.service.gov.uk)	Competent person, best practice to outsource to specialist company (e.g. fire safety engineer or assessor)	FRA needs to be completed before the premises are occupied, and reviewed regularly. The frequency of the review is determined as part of the risk assessment, but it is good practice to do so at least every 12 months, but not longer than every 5 years. Additionally, FRA reviews should be conducted before any changes to the occupants, the activities, the materials stored or located in the premises, and any alteration to the building.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Hose reels
APM Object	CT.FIRE.HOSES
APM Description	Hose reels for fire fighting.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP.HDRNT	**Related CT Areas:**	Not Specified		

Scope

Any site where hose reels are installed to aid firefighters in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 6 months.	Routine maintenance to ensure correct operation and integrity of the hose reels	Competent person (e.g. engineer), generally outsourced	Maintenance logbook					CT			
All	2	Every 12 months	Water pressure check	Competent person (e.g. engineer), generally outsourced	Inspection & test records	PM					EVID		
All	3	Every 5 years	Full water pressure test.	Competent person (e.g. engineer), generally outsourced	Inspection & test records	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit

DE	DIN EN 671-3:2009-07 - Ortsfeste Löschanlagen - Wandhydranten - Teil 3: Instandhaltung von Schlauchhaspeln mit formstabilem Schlauch und Wandhydranten mit Flachschlauch; Deutsche Fassung EN 671-3:2009 DIN EN 694:2014-10 - Feuerlöschschläuche - Formstabile Schläuche für Wandhydranten DIN 14462:2012-09 – Löschwassereinrichtungen - Planung, Einbau, Betrieb und Instandhaltung von Wandhydrantenanlagen sowie Anlagen mit Über- und Unterflurhydranten DIN 14461-1 Feuerlösch-Schlauchanschlusseinrichtungen	Qualified person (sachkundige Person) according to DIN 14462	A full assessment including operating pressure test, at least once a year for wet risers and wet/dry risers and every two years for dry risers. Annual inspection of pressure hoses W (dimensionally stable hoses). Pressure hoses C (collapsible hoses) inspection interval every 5 years or after each use. A highest permissible operating pressure test every 5 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE: 23091. firefighting equipment. impulsion hose: flat flexible hose of 25, 45, 70 and 100 mm. for hard service.	Quarterly servicing by competent person. Annual, maintenance by authorised company. 10 years inspections by accredited company (OCA).	Check for accessibility, presence, condition, label, etc. every 3 months. Every 12 month by authorised maintenance company. Fully and intrusive Inspection every 10 years.
FR	Labour Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	N/A	N/A
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 10779:2021 (Fire hydrant networks) UNI EN 671-3:2009 (Maintenance)	Competent, qualified person.	Maintenance every 6 months. Water pressure check every 12 months. Full water pressure test every 5 years.
PL	Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Internal Affairs and Administration of 2 December 2015 on the reconciliation of the construction project in terms of fire protection	Qualified or competent person	According to manufacturer's instruction but at least once per year. Pressure test once every 5 years. (at their maximum working pressure, which is 1.2 MPa)
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 671-3:2009 Fixed Firefighting Systems - Hose Systems - Part 3: Maintenance of Hose Reels with Semi-rigid Hose and Hose Systems with Lay-flat hose (NSAI)	Competent person, best practice to outsource to specialist	Visual inspection (maintenance) at least every 6 months. Water pressure check every 12 months. Water pressure test every 5 years
SK	Ordinance No. 699/2004 Coll. on securing buildings with water for fire – fighting	Competent person, best practice to outsource to specialist	Inspections every 12 months unless stated otherwise by manufacturer.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice British Standard EN-671/3 (Fixed firefighting systems. Hose systems)	Competent person, best practice to outsource to specialist	Visual inspection (maintenance) at least every 6 months. Water pressure check every 12 months. Water pressure test every 5 years

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Fire hydrants
APM Object	CT.FIRE.HYDRANTS
APM Description	Fire hydrants
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 6M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP.HDRNT	**Related CT Areas:**	Not Specified		

Scope

Any site with fire hydrants under their jurisdiction to provide a water supply connection for firefighters in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	At least every 6 months	Visual checks to ensure there is no apparent damage to the hydrant frame and cover. General maintenance of fittings.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	2	At least every 6 months	Cut back and clear any overgrown vegetation.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	3	At least every 6 months	Check information on hydrant plate is accurate and clearly visible.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	4	At least every 6 months	Check the hydrant pit and hydrant itself for integrity, debris and leakage.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	5	At least every 12 months	Inspection and testing of hydrant, including wet test, water pressure and flow.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		

DE	6	Every 3 years.	Additional inspection and testing for effectiveness and operational safety according to building law.	Expert according to state building law	Inspection records				(CT)				
ES	7	every 3 to 6 months	General maintenance (accessibility, tightness of connections, grease and check condition of fittings, etc.).	Accredited company or internal competent person	No additional requirements	PM					EVID		
IT	8	Every 5 years.	Full water pressure test	No additional requirements.	No additional requirements.								5 Year CT

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit
DE	Technische Regel für Arbeitsstätten: ASR A2.2 - Maßnahmen gegen Brände DIN EN 671-3:2009-07 - Ortsfeste Löschanlagen - Wandhydranten - Teil 3: Instandhaltung von Schlauchhaspeln mit formstabilem Schlauch und Wandhydranten mit Flachschlauch; Deutsche Fassung EN 671-3:2009 DIN 14462:2012-09 – Löschwassereinrichtungen - Planung, Einbau, Betrieb und Instandhaltung von Wandhydrantenanlagen sowie Anlagen mit Über- und Unterflurhydranten Federal State construction laws and according to building permits	Inspection by qualified person (sachkundige Person) according to DIN 14462 Building regulations inspection by expert according to state building law, legitimation and certificate necessary.	Inspection frequency in accordance with the manufacturer's specifications, but no longer than 1 year. Additional inspection and testing for effectiveness and operational safety according to building law every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 14384: 2006. Pillar fire hydrants. UNE-EN 14339:2006. Underground fire hydrants.	Quarterly and half-year servicing by competent person. Annual, quinquennial maintenance by authorised company. 10 years inspections by accredited company (OCA).	General maintenance every 3 to 6 months (accessibility, tightness of connections, grease, and check condition of fittings, etc.). Every 12 months: water tightness in plugs. Every 5 years: Change of the union joints. Intrusive inspections.
FR	Labour Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams. APSAD or NF - voluntary standard for insurance	APSAD and NF certified companies	Annual inspection and testing.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 10779:2021 (Fire hydrant networks)	Competent, qualified person, best practice to outsource to specialist.	Regular checks of hydrant every 6 months. Water pressure testing every 12 months. Regular checks of water tank and full water pressure test every 5 years.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 24 July 2009 of the Minister of the Interior and Administration on fire water supply and fire routes (Journal of Laws 2009, number 124, item 1030)	Qualified or competent person, usually a fire safety specialist	Inspection and testing yearly.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 14339:2005 Underground Fire Hydrants I.S. EN 14384:2005 Pillar Fire Hydrants	Competent person, best practice to outsource to specialist (engineer)	Inspection and testing of fire hydrants, including water pressure testing and flow annually.
SK	Ordinance No. 699/2004 Coll. on securing buildings with water for fire – fighting	Competent person, best practice to outsource to specialist.	Inspections every 12 months unless stated otherwise by manufacturer.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk)	Competent person, best practice to outsource to specialist (engineer)	Inspection and testing of fire hydrants, including water pressure testing and flow annually.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire pump test
APM Object	CT.FIRE.PUMP
APM Description	Fire pumps
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP	**Related CT Areas:**	Not Specified		

Scope

Any site with fire pumps used to supply water through the sprinkler system in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	General maintenance and testing to ensure correct operation. Check fuel level is sufficient following the completion of the test.	Competent person, generally a manager.	Maintenance logbook	PM					EVID		
All	2	Annually	Servicing of fire pumps	Competent person, best practice to outsource (e.g. engineer).	Inspection records, reports or certificate.						CT		
DE	3	Every 6 months	Inspection as per [2].	No additional requirements	No additional requirements					CT			
FR	4	Every 6 months	Inspection as per [2].	No additional requirements	Fire/Security register					CT			
IT	5	Monthly	Inspections to check density of electrolyte.	No additional requirement	Inspection records	(PM)					EVID		

IT	6	Every 3 months	Inspection of valves, pipework and power supply.	No additional requirement	Inspection records	(PM)					EVID		
IT	7	Every 6 months	Inspection of the system and check of the alarm reporting link with the Fire Brigade	No additional requirement	Inspection records					CT			
IT	8	Annually	Pump flow test and inspection of filters, storage tank and diesel engines.	No additional requirement	Inspection records	(PM)					EVID		
SK	9	Weekly (visual check, test of functionality). Monthly (test of functionality, cleanliness check, completeness check). Annually (test of functionality, check of parameters).	If inspection frequency is not specified by manufacturer or technical description, following frequencies apply.	No additional requirement	Inspection records	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker.	Inspection and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) DIN EN 14466 - Feuerlöschpumpen - Tragkraftspritzen - Sicherheits- und Leistungsanforderungen, Prüfungen DIN EN 1028-1 - Feuerlöschpumpen - Feuerlöschkreiselpumpen mit Entlüftungseinrichtung - Teil 2: Feststellung der Übereinstimmung mit den allgemeinen und Sicherheitsanforderungen DIN EN 12845 - Ortsfeste Brandbekämpfungsanlagen - Automatische Sprinkleranlagen - Planung, Installation und Instandhaltung	Qualified person	Fire pumps should be controlled and tested according to manufacturer requirements and fire insurer. Portable pumps need to be checked after each use but at least once every three months. Weekly check of correct operation (e.g. functional readiness of the pumps and their drives). Inspection and service every 6 months.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE 23500: 2018: Water supplies systems for firefighting.	Quarterly and half-year servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	General maintenance every 3 to 6 months (tanks, valves, controls, pump alarms, signals, general cleaning, water levels, electric supply, etc.). Every 12 months: water supply, cleaning of filters, battery conditions and pump testing. Inspections carried out every 10 years.
FR	Labour Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams. APSAD or NF - voluntary standard for insurance	Competent person, best practice to outsource to specialist.	Inspections every 6 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI EN 12845:2020 (Maintenance)	Competent, qualified person.	Weekly checks to ensure correct operation (automatic pump start-up test and diesel engine restart test). Monthly inspections to check density of electrolyte. Inspection of valves, pipework and power supply every 3 months. Inspection of the system and check of the alarm reporting link with the Fire Brigade every 6 months. Tests of pump flow rate, of the failure to start the engine, float valve tests, tests on suction chambers and pump filters, at least annually.
PL	Regulation of the Minister of Interior and Administration of 7 June 2010 on fire protection of buildings, other buildings and land (Journal of Laws 2010, number 109, item 719 Regulation of the Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) (sejm.gov.pl) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869). (sejm.gov.pl) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) (sejm.gov.pl) Regulation of the Minister of Interior and Administration of 24 July 2009 on fire water supply and fire roads (Journal of Laws 2009, number 124, item 1030). (sejm.gov.pl)	Qualified or competent person, usually a fire specialist.	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Weekly testing to ensure correct operation. Serviced annually.

SK	Ordinance No. 169/2006 Coll. on the specific characteristics of fixed fire-fighting equipment and semi-stable fire-fighting equipment and on the conditions of their operation and ensuring their regular inspection Ordinance No. 699/2004 Coll. on securing buildings with water for fire – fighting	Competent and certified person	Inspection after the first installation. Regular inspections are realized according to manufacturer's instructions or technical descriptions.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS EN 12845: 2015 + A1: 2019 Fixed firefighting systems. Automatic sprinkler systems. Design, installation and maintenance	Competent person, best practice to outsource to specialist company.	Weekly testing to ensure correct operation. Serviced annually.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire shutters and fire curtains
APM Object	CT.FIRE.SHUTTERS
APM Description	Fire dampers of all types including (for example) curtain, pivot and intumescent.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**		**Delivered By:**	
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where fire dampers are used to prevent fire (when occurring) from escaping the room where it originated through ducting vents.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	If the fire shutter or fire curtain is interfaced with the Fire Alarm System, regular testing when testing the FAS.	Competent person	Inspection records, report or certificate		CT						
All	2	In accordance with manufacturer's instructions and recommendations, but at least every 12 months.	Regular inspection and servicing of fire shutters and fire curtains.	Competent person	Inspection records, report or certificate						CT		
DE	4	Every 6 months.	Inspection as for [2]	No additional requirements	No additional requirements					CT			
IT	3	Every 6 months.	Inspection as for [2]	No additional requirements	CE Declaration of Conformity					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit
DE	DIN EN 15650:2010-09 - Lüftung von Gebäuden - Brandschutzklappen	Recognised specialist (anerkannten Sachverständigen) or competent person (befähigte Person)	According to risk assessment but at least every 6 months. If two consecutive tests at intervals of six months do not reveal any functional defects, inspection intervals can be lengthened to once a year.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) RD 842/2013, of October 31, approving the classification of construction products and construction elements based on their reaction properties and resistance to fire.	Qualified person or competent external company	Maintenance (functional) before commissioning.
FR	Labour Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD or NF - voluntary standard for insurance	N/A	N/A
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11473-1:2013 (Maintenance)	Competent, qualified person.	Inspection every 6 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist.	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Weekly test by competent person, often the manager. Inspection by competent engineer.	Test functionality weekly if interfaced with the FAS. Inspected and serviced yearly.
SK	Ordinance No. 478/2008 Coll. on the properties, specific operating conditions and ensuring regular inspection of the fire separation closures Ordinance No. 121/2002 Coll. on fire prevention	Competent person, best practice to outsource to specialist (fire protection specialist with accreditation).	Inspection every 12 months unless stated otherwise by operating instructions.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS EN 16034:2014 - Pedestrian doorsets, industrial, commercial, garage doors and openable windows. Product standard, performance characteristics. Fire resisting and/or smoke control characteristics	Weekly test by competent person, often the manager. Inspection by competent engineer.	Test functionality weekly if interfaced with the FAS. Inspected and serviced yearly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Smoke detectors
APM Object	CT.FIRE.SMOKEDETECT
APM Description	Fire (smoke and heat) detectors
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.DET.FIREALRM	**Related CT Areas:**	CT.FIRE.FAS		

Scope

Any site where smoke and heat detectors are installed to give early warning in the event of fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Every 3 months	Functional inspection and testing of 1 detector per area or transmission path.	Competent person, best practice to outsource (e.g. fire safety engineer).	Maintenance logbook Risk assessment Inspection records, report or certificate.	PM					EVID		
All	2	Every 6 months	Servicing of all smoke and heat detectors to ensure correct operation of the system.	Competent person, best practice to outsource (e.g. fire safety engineer).	Maintenance logbook Risk assessment Inspection records, report or certificate.	(PM)					(EVID)		
All	3	Every 12 months	Testing of all detectors.	Competent person, best practice to outsource (e.g. fire safety engineer).	Maintenance logbook Risk assessment Inspection records, report or certificate.	(PM)					(EVID)		
CZ	4	Every 6 months	Inspection as per [3]	No additional requirements	No additional requirements					CT			
FR	5	Every 6 months	Inspection as per [3]	No additional requirements	Fire/Security register					CT			

IT	6	Every 6 months	Inspection as per [3]	No additional requirements	No additional requirements					CT			
IT	7	Every 12 years.	Verification of the compliance of the installation.	No additional requirements	No additional requirements	(PM)					(EVID)		
SK	8	In case of a need to perform more frequent than annual inspection: Monthly (mechanical check, communication channels): or Quarterly (functional control, power supply, remote controls, data recording).	Inspection as per [3].	No additional requirements	No additional requirements	(PM)					(EVID)		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll. on Fire Protection. ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree No. 50/1978 Coll.	Monthly test trained by a worker from the device manufacturer Accredited company	Control of the control panel once a month Check fire sensors every 6 months. Inspection of the entire FAS (service) system annually.
DE	Arbeitsstättenverordnung (ArbStättV) DIN 14675 - Brandmeldeanlagen, Teil: 1 Aufbau und Betrieb und Teil 2: Anforderungen an die Fachfirma DIN 18232 - Rauch- und Wärmefreihaltung DIN VDE 0833-1 - Gefahrenmeldeanlagen für Brand, Einbruch und Überfall - Teil 1: Allgemeine Festlegungen.	Qualified electrician FAS	In accordance with manufacturer's recommendations. Functional inspection of 1 detector per transition path every 3 months according to DIN 14675 und DIN VDE 0833. Annual maintenance according to DIN 14675 and inspection. Replacing components with a limited service life (e.g. fire detectors, accumulators, devices and storage batteries) after expiry of technical useful life.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE 23007:2020. Fire detection and fire alarm systems.	Quarterly servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Routine checks (maintenance) every 3 months. Official maintenance operation every year. Fully inspections every 10 years.
FR	Labor Code Article R4227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Inspection of fire and smoke detectors every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11224:2019 (Maintenance)	Competent, qualified person, best practice to outsource to specialist	Periodic maintenance and inspections of all detectors every 6 months for conventional detection systems. Analogue addressed detection systems are subject to the inspection of 25% of the detectors every 6 months from the first year to the sixth year, from the seventh year to the twelfth year 50% of all detectors must be inspected every 6 months. Routine and extraordinary maintenance in the event of anomalies detected. Verification of the compliance of the installation every 12 years.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065)Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. 3218:2013 Fire Detection and Alarm Systems for Buildings - System Design, Installation, Commissioning, Servicing and Maintenance NSAI	Competent person, best practice to outsource to specialist.	Testing of 1 detector per zone every 3 months. Servicing of all detectors every 6 months. Testing of all detectors every 12 months.
SK	Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent person, best practice to outsource to specialist (e.g. fire protection technician)	Regular inspections. In case annual inspection is performed, more frequent inspections are not needed.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice	Competent person, best practice to outsource to specialist.	Testing of 1 detector per zone every 3 months. Servicing of all detectors every 6 months. Testing of all detectors every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Smoke vent systems
APM Object	CT.FIRE.SMOKEVENTS
APM Description	Smoke vent systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	FIRE.SUP.SMOKEHEATVENT - FIRE.SUP.SMOKEEXT	**Related CT Areas:**	Not Specified		

Scope

All site where smoke vent systems are used to provide an escape route for the smoke in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Every 3 months	If the smoke ventilation system is interfaced with the Fire Alarm System, regular testing when the alarm is tested.	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment						CT		
All	2	Every 3 months	Visual inspection of ventilation systems for obstructions and cleaning (regular maintenance)	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment						CT		
All	3	Every 3 months	Smoke control system to be simulated on all zones (area) fitted with a smoke vent.	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment						CT		
All	4	Every 12 months	Regular servicing of the entire smoke vent system to ensure correct operation (e.g. key features such as seals and actuator) .	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment	PM					EVID		
DE	5	Every 3 years	Additional inspection to assess compliance with building regulation.	expert according to building law	Inspection records								3Y CT

FR	6	Every 6 months	Inspection as per [3].	No additional requirements	Fire/Security register	(PM)					(EVID)		
IT	7	Every 6 months	Inspection as per [3].	No additional requirements	CE Declaration of Conformity.						(CT)		
PL	8	Every 6 months	Inspections as per [3] for buildings with an area greater than 2000 m2 or roof area greater than 1000 m2.	No additional requirements	No additional requirements					CT			

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Federal State building codes and building permit Arbeitsstättenverordnung (ArbStättV) DIN 18232 - Rauch- und Wärmefreihaltung DIN VDE 0833-1 - Gefahrenmeldeanlagen für Brand, Einbruch und Überfall - Teil 1: Allgemeine Festlegungen. Model Ordinance for Inspections (Muster-Prüfverordnung)	3 annual inspection by expert according to building la.	Visual inspection every 12 months. Functional and operational inspection in accordance with manufacturer's instruction, but at least yearly. In the case of particularly dirty or dusty operating sites, the maintenance intervals should be reduced accordingly. Additional inspection to assess compliance with building regulations every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA). UNE 23585:2017. Fire safety. Smoke and heat control systems. Requirements, calculation and design methods for temperature control systems and smoke exhaust systems projecting in case of stationary	Quarterly servicing by competent person Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular visual checks for obstructions or changes that might affect the effectiveness of the smoke vents every 3 months. Functional inspection (manual activation) and cleaning of the system every 6 months. Every year: Functional inspection of system positions, including manual and automatic signals. Smoke curtains testing, power supply testing. Inspection of smoke vents system every 10 years.
FR	Labor Code Article R47227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Regular inspections every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 9494-3:2014 (Maintenance)	Competent, qualified person, best practice to outsource to specialist	Regular maintenance and surveillance. Initial inspection and regularly every 6 months.
PL	Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	Regular inspections every 12 months, or every 6 months for buildings with an area of more than 2000 m2 or a roof area of at least 1000 m2.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 12101-2:2017 - Smoke and heat control systems. Natural smoke and heat exhaust ventilators	Weekly and quarterly inspections conducted by manager or owner. Service is best practice to outsource to specialist engineer.	If interfaced with alarm, testing of smoke vents weekly. Smoke control system to be simulated on all zones every 3 months. Annual service of smoke ventilation system.
SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 121/2002 Coll. on fire prevention Ordinance no. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of fuel appliances, electrothermal appliances and central heating equipment and in the construction and use of chimneys and flues and the deadlines for their cleaning and inspections	Competent person, best practice to outsource to specialist	Regular inspections every 12 months.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS EN 12101-2:2017 - Smoke and heat control systems. Natural smoke and heat exhaust ventilators	Weekly and quarterly inspections conducted by manager or owner. Service is best practice to outsource to specialist engineer.	If interfaced with alarm, testing of smoke vents weekly. Smoke control system to be simulated on all zones every 3 months. Annual service of smoke ventilation system.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Sprinkler systems
APM Object	CT.FIRE.SPRINKSERVICE
APM Description	Sprinkler systems, associated pipework and storage tanks
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP - FIRE.SUP.HDRNT - FIRE.SUP.PRESSWTR.VESSELS - MTR.FIRE-DSL - FIRE.SUP.PUMP.JP - FIRE.SUP.PUMP.CNTRL	**Related CT Areas:**	FIRE.SUP.FOAM		

Scope

Any site where a sprinkler system is used to prevent, extinguish and/or contain fire from spreading or occurring.
Fire pumps inspection requirements are covered under CT.FIRE.PUMP
Dry risers inspection requirements are covered under CT.FIRE.DRYRISERS
Fire hydrant inspection requirements are covered under CT.FIRE.HYDRANTS

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	Inspection of valves to ensure they are locked and open, water levels, water and air pressure gauges, water flow alarm, etc.	Competent person usually internal	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	PM					EVID		
All	2	Monthly	Regular checks of batteries and sprinkler tanks	Competent person usually internal	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	(PM)					(EVID)		
All	3	In accordance with risk assessment, but at least annually.	Regular inspections of sprinkler heads for obstructions	Competent person usually internal	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	(PM)					(EVID)		
All	4	Based on risk assessment and type of installation, but at least annually	Regular professional servicing of the sprinkler system	Competent person, best practice to outsource	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	(PM)					(EVID)		
All	5	Every 3 years	Draining and overhauling of sprinkler tanks and valves	Competent person	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.								3Y CT

All	6	Every 10 years	Internal and external examination of tanks for corrosion, deterioration or damage	Competent person	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.								10Y CT
All	7	Based on risk assessment and type of installation, but between 12 and 25 years.	Laboratory testing of sprinkler heads	Competent Person to sample. Analysis to be completed at UKAS accredited laboratory	Analysis results								12Y CT
DE	8	Monthly	Inspection as per [3]	No additional requirements	Inspection records and certificate			CT					
DE	9	Every 12.5 years for wet plants and 25 years for dry plants	Inspection as per [7]	No additional requirements	No additional requirements								12,5Y CT
DE	10	Every 25 years for wet plants and 12.5 years for dry plants	Inspection of pipe network	No additional requirements	No additional requirements								12,5Y & 25Y CT
DE	11	Every 3 years	Additional inspection to comply with building regulations	Expert according to building law	Inspection records								3Y
ES	12	Every 3 to 6 months	Inspection as per [4]	Accredited company or competent person.	No additional requirements	(PM)					(EVID)		
FR	13	No additional requirements	Inspection as per [1] to [7]	No additional requirements	Fire/Security register	(PM)					(EVID)		12Y CT
IT	15	Every 3 months	Hazard level reassessment, valves inspection, sprinklers inspection, inspection of piping and associated supports, inspection of water and electrical supplies, check of the number of spare sprinklers available.	No additional requirements	No additional requirements						CT		
IT	16	Every 6 months	Inspection of dry alarm valves, verification of the efficiency of escort equipment, inspection of the alarm reporting link with the fire station.	No additional requirements	No additional requirements					CT			
IT	17	Every 3 years	Inspection as per [6].	No additional requirements	No additional requirements								10Y CT
IT	18	Every 10 years	Cleaning and waterproofing interventions, examination of water reserves.	No additional requirements	No additional requirements								10Y CT
IT	19	Weekly (visual inspection, functionality check, control of pre-defined parameters/values) Monthly (visual inspection, functionality check) Annually (visual inspection, functionality check, control of metric systems, technical	In case frequency of inspections is not prescribed by manufacturer, following frequencies apply	No additional requirements	No additional requirements	(PM)					(EVID)		
UK	14	At least annually	Regular audits to ensure compliance with relevant regulations	Third party, independent from service provider	Audit records and actions.						CT		

Related Regional Legislation			
Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Decree no. 246/2001 Coll. Act. No. 133/1985 Coll	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit
DE	Federal State building codes and building permit Arbeitsstättenverordnung (ArbStättV) Betriebssicherheitsverordnung (BetrSichV) DIN 14464 Direktanschlussstationen für Sprinkleranlagen und Löschanlagen mit offenen Düsen – Anforderungen und Prüfung DIN 1988-600 Technische Regeln für Trinkwasser-Installationen – Teil 600: Trinkwasser-Installationen in Verbindung mit Feuerlösch- und Brandschutzanlagen DIN EN 12259-1 Ortsfeste Löschanlagen – Bauteile für Sprinkler- und Sprühwasseranlagen – Teil 1: Sprinkler	Accredited inspection body (ZÜS) for inspections according to BetrSichV Regular checks and controls conducted by internal personnel (trained). All maintenance, repair and modification work should be carried out by the company that built the installation. Inspections and examination conducted by external professional, qualified and authorised to undertake the task.	Inspections according to BetrSichV comprise inspections prior first use (vor Inbetriebnahme), after significant changes (vor Wiederinbetriebnahme nach prüfpflichtigen Änderungen); inner inspection of pressure devices every 5 years and strength testing every 10 years of pressure devices. Regular checks to ensure correct status and operation: - Weekly (e.g. test alarm at the valve station); - Monthly (e.g. functional readiness of the pumps and their drives, control of oil levels of pumps and diesel engines, checking the function of the proportioning device, checking the devices for operating and releasing fire doors and flaps in CO2 extinguishing systems); and - Quarterly (e.g. sprinklers and control valves for deposits(dirt))
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 12845:2016+A1:2021. Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance.	Quarterly and half-year servicing by competent person. Annual, triennial and quinquennial maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular maintenance of extinguishing agents and system components, including reading and checking manometers, checking signalling circuits and general cleaning every 3 months. Visual checks of pipes, tanks and hoses and their infrastructure every 6 months. Fully inspection every 1, 3 and 5 years. Intrusive Inspections every 10 years.
FR	Labor Code Article R47227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Regular sprinkler testing every 6 months. Inspections of sprinkler head obstructions every 6 months. Servicing of sprinkler system every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI EN 12845:2020 (Maintenance)	Weekly and monthly testing conducted by internal employee (trained) Inspections conducted by competent, qualified person, best practice to outsource to specialist.	Pressure check, water level inspection, valves inspection and start-up test of pump and diesel engine conducted weekly by trained employee. Batteries check and inspection of the electrolyte level every month by trained employee. Hazard level reassessment, valves inspection, sprinklers inspection, inspection of piping and associated supports, inspection of water and electrical supplies, check of the number of spare sprinklers available every 3 months. Inspection of dry alarm valves, verification of the efficiency of escort equipment, inspection of the alarm reporting link with the fire station every 6 months. Tests of pump flow rate, of the failure to start the engine, float valve tests, tests on suction chambers and pump filters every 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 24 July 2009 of the Minister of the Interior and Administration on fire water supply and fire routes (Journal of Laws 2009, number 124, item 1030) Regulation of the Minister of Interior and Administration of June 16, 2003 on the reconciliation of a	Competent person, usually a fire safety specialist.	Sprinkler testing in accordance with manufacturer's instructions, but at least yearly. Inspections of sprinkler head obstructions in accordance with manufacturer's instructions, but at least yearly. Servicing of the sprinkler system at least yearly
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 12845:2015+A1:2019 Fixed Firefighting Systems - Automatic Sprinkler Systems - Design, Installation and Maintenance NSAI	Weekly inspections of valves and inspections of sprinkler heads by internal employee (trained). Servicing of sprinkler system by competent specialist	Weekly inspection of all valves to ensure they are locked and fully open, water levels, water and air pressure gauges, water flow alarm test, etc.. Monthly checks of batteries and sprinkler tanks Regular servicing of sprinkler systems at least every 12 months. Additional inspection to ensure compliance (audit) every 12 months Internal and external examination of tanks every 10 years. Inspection of sprinkler heads for obstructions in accordance with fire risk assessment and manufacturer's instructions. Regular servicing of sprinkler systems at least every 12 months.
SK	Ordinance No. 169/2006 Coll. on the specific characteristics of fixed fire-fighting equipment and semi-stable fire-fighting equipment and on the conditions of their operation and ensuring their regular inspection	Qualified and certified person	Frequency of inspections prescribed by manufacturer.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS EN 12845: 2015 + A1: 2019 Fixed firefighting systems. Automatic sprinkler systems. Design, installation and maintenance	Weekly inspections of valves and inspections of sprinkler heads by internal employee (trained). Servicing of sprinkler system by competent specialist. Annual audit by independent third party	Weekly inspection of all valves to ensure they are locked and fully open, water levels, water and air pressure gauges, water flow alarm test, etc.. Monthly checks of batteries and sprinkler tanks Inspection of sprinkler heads for obstructions in accordance with fire risk assessment and manufacturer's instructions. Regular servicing of sprinkler systems at least every 12 months. Additional inspection to ensure compliance (audit) every 12 months Draining and overhauling of sprinkler tank every 3 years (unless classified as a 10 year tank). Internal and external examination of tanks every 10 years. Sprinkler head testing at laboratory at least every 25 years (unless manufacturer specifies earlier).

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Staircase pressurisation
APM Object	CT.FIRE.STAIRCASE
APM Description	Staircase pressurisation system.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	FIRE.SUP.SMOKEHEATVENT	**Related CT Areas:**	CT.FIRE.SMOKEVENTS		

Scope

Any site where fire dampers are used to prevent fire (when occurring) from escaping the room where it originated through ducting vents.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 12 months.	Regular inspection and servicing of staircase pressurisation system.	Competent person (e.g. fire safety engineer)	Inspection records, report or certificate	PM					EVID		
ES	3	Every 3 months.	Visual checks for obstructions or changes that might affects its effectiveness.	No additional requirements	Inspection records				CT				
IT	2	Every 6 months.	Visual inspection of ventilation systems for obstructions and cleaning (regular maintenance)	No additional requirements	CE Declaration of Conformity.					CT			
SK	4	Every 6 months in administrative buildings Every 3 months in companies.	Visual inspection of ventilation systems for obstructions and cleaning (regular maintenance)	No additional requirements	Inspection records				CT				

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Federal State building laws and building permit; (Muster-) Verwaltungsvorschrift Technische Baubestimmung MVV TB DIN EN 12101-6:2005-09 Smoke and heat control systems - Part 6: Specification for pressure differential systems	Expert (Sachverständiger) for inspections; Competent person for maintenance	Expert inspection before the first commencement of use of the building facilities, without undue delay after a technical modification of the building facilities, as well as immediately after a significant change to the technical installations, and within a period of three years (periodic inspections). Regular maintenance by competent persons according to manufacturer specifications, at least every 12 months.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA). UNE-EN- 12101-6: 2006. Smoke and heat control systems - Part 6: Specification for pressure differential systems – Kits.	Quarterly servicing by competent person Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular visual checks for obstructions or changes that might affect the effectiveness every 3 months. Functional inspection (manual activation) and cleaning of the system every 6 months. Every year: Functional inspection of system positions, including manual and automatic signals. Inspection every 10 years.
FR	Labor Code Article R4227-28 to 33: Firefighting and prevention means https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams	N/A	N/A
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI EN 12101-6:2005 (Pressure differential systems) UNI 9494-3:2014 (Maintenance)	Competent, qualified person.	Inspection every 6 months.
PL	Act of July 7, 1994 - Construction Law (Journal of Laws of 1994, No. 89, item 414) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Regulation of Minister of Interior and Administration of 7 June 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of the Minister of Internal Affairs and Administration of 24 July 2009 on firefighting water supply and fire roads (Journal of Laws of 2009, No. 124, item 1030)	Qualified or competent person, usually a fire safety specialist	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) BS EN 12101-6:2005 - Smoke and heat control systems. Specification for pressure differential systems	Weekly test by competent person, often the manager. Inspection by competent engineer	Test functionality weekly if interfaced with the FAS. Inspected and serviced yearly.
SK	Ordinance No. 94/2004 Coll. on technical requirements for fire safety during construction and use of buildings Ordinance No. 121/2002 Coll. on fire prevention	Qualified and certified person	Every 12 months in households, every 6 months in administrative buildings and every 3 months in companies.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999: 2017 - Fire safety in the design, management and use of buildings. Code of practice BS EN 12101-6:2005 - Smoke and heat control systems. Specification for pressure differential systems	Weekly test by competent person, often the manager. Inspection by competent engineer	Test functionality weekly if interfaced with the FAS. Inspected and serviced yearly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Suppression systems
APM Object	CT.FIRE.SUPPRESSION
APM Description	Fire suppression systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Foam Suppression System	**Related CT Areas:**	Not Specified		

Scope

Any site where fire suppression systems (e.g. foam, gas) are used to contain, extinguish and/or prevent fire from spreading or even occurring.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	If the fire suppressor system is interfaced with the fire alarm system (FAS), it is inspected with the FAS.	Competent person	Test log book						EVID		
All	2	Every 6 to 12 months	Routine servicing of suppression systems to ensure correct operation.	Competent person	Inspection records, report or certificate. Risk assessment								One Off EVID
All	3	Before the installation is used for the first time. Every 12 months, unless it is proven (documented) that no changes have been made to the protected enclosure. Following changes in materials.	Inspection and testing of room integrity and hold time calculation.	Competent person, best practice to outsource (e.g. fire safety engineer).	Inspection records, report or certificate. Risk assessment						EVID		
ES	4	Every 3 months	Regular maintenance of all suppression systems	Accredited company or competent person	No additional requirements						EVID		
FR	5	No additional requirements	Inspection as per [2].	No additional requirements	Fire/Security register						EVID		

IT	6	Daily, weekly or monthly depending on the categories of the systems.	Surveillance and check	No additional requirements	No additional requirements						EVID		
IT	7	Every 3 to 6 and 12 months depending on the categories of the systems.	Periodic maintenance of fire suppression systems.	No additional requirements	No additional requirements						EVID		
IT	8	Every 10 years for water based and water mist systems.	Review of the installation	No additional requirements	No additional requirements								10Y CT
SK	9	functionality). Monthly (test of functionality, cleanliness check, completeness check). Annually (visual check, test of functionality, check of parameters).	If inspection frequency is not specified by manufacturer or technical description, following frequencies apply.	No additional requirement	Inspection records						EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll. on Fire Protection. ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree No. 50/1978 Coll.	Monthly test trained by a worker from the device manufacturer Accredited company Review technician	Control of the control panel once a month Check fire sensors every 6 months. Inspection of the entire FAS (service) system annually.
DE	Federal State building codes and building permit Arbeitsstättenverordnung (ArbStättV) Betriebssicherheitsverordnung (BetrSichV) VdS 2496 - VdS-Richtlinien für die Ansteuerung von Feuerlöschanlagen, Planung und Einbau Foam extinguishing systems (Schaumlöschanlagen): VdS 2108 - VdS-Richtlinien für Schaumlöschanlagen, Planung und Einbau; DIN EN 13565-2 - Ortsfeste Brandbekämpfungsanlagen - Schaumlöschanlagen - Teil 2: Planung, Einbau und Wartung	Accredited inspection body (ZÜS) for inspections according to BetrSichV Internal inspections conducted by competent person, generally the manager Service by VdS approved vendor if plant is VdS certified. Leak inspection by VdS Prüfstelle. Building regulations inspection by expert according to building law	Inspections according to BetrSichV comprise inspections prior first use (vor Inbetriebnahme), after significant changes (vor Wiederinbetriebnahme nach prüfpflichtigen Änderungen); inner inspection of pressure devices every 5 years and strength testing every 10 years of pressure devices. Internal inspections daily, weekly and monthly. Routine maintenance programme (service) annually. Leak inspection every year. Additional inspection to comply with building regulations every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 15004. Fixed firefighting systems - Gas extinguishing systems. UNE-EN 12094. Fixed firefighting systems - Components for gas extinguishing systems	Quarterly and half-year servicing by competent person. Annual and quinquennial maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular maintenance every 3 and 6 months. Regular functional inspections and verifications every 12 months and every 5 years. Intrusive inspection every 10 years.
FR	Labor Code https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Inspection every 6 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11280:2020 (Gas systems maintenance) UNI EN 12416-2:2007 (Powder systems maintenance) UNI EN 13565-1:2019 (Foam systems) NFPA 25:2020 (Water based systems maintenance) UNI CEN/TS 14816:2009 (Water based systems maintenance) NFPA 750:2019 (Water mist systems maintenance)	Competent, qualified person. Surveillance and checks conducted by trained employee.	Gas systems: Surveillance every month. Inspection every 6 months and review of the installations every 10 years. Powder systems: Surveillance every day, inspection every month and maintenance every 6 months. Foam systems: Surveillance and check every week and month by trained employee, inspection every 3 and 6 months. Chemical analysis every 12 months. Check of the pre-mixer membrane every 5 years. Water based systems: Surveillance and check every week and month by trained employee, inspection every 3, 6 and 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	Regular inspection according to manufacturer's instruction but at least once per year.
ROI	Fire Services Act, 1981 (irishstatutebook.ie) ece4931c-46c0-44f7-88130ab7d78565d9.pdf (fia.uk.com)	Competent person, best practice to outsource to specialist	Inspected weekly if interfaced with fire alarm systems. Serviced 6 and 12 monthly. Room integrity Test (gaseous agents) every 12 months and when materials change takes place, unless evidence exists that no changes have been made to the protected enclosure.

SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 169/2006 Coll. on the specific characteristics of fixed fire-fighting equipment and semi-stable fire-fighting equipment and on the conditions of their operation and ensuring their regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent and qualified person	Regular inspection at least annually unless manufacturer prescribes different period. Inspection and functionality check are realized after every repair and at the beginning of use period.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) BS 9999:2017 Fire safety in the design, management and use of buildings. Code of practice (bsigroup.com) BS EN 15004-1:2019 Fixed firefighting systems. Gas extinguishing systems. Design, installation and maintenance (bsigroup.com) guidance on room integrity testing and interpretation (fia.uk.com)	Competent person, best practice to outsource to specialist.	Inspected weekly if interfaced with fire alarm systems. Serviced 6 and 12 monthly. Room integrity Test (gaseous agents) every 12 months and when materials change takes place, unless evidence exists that no changes have been made to the protected enclosure.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fixed Ladders
APM Object	CT.HEIGHT.LADDERS.F
APM Description	Fixed ladders.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LADDERS.FIXED	**Related CT Areas:**	Not Specified		

Scope

Any site with fixed ladders installed to access areas such as roofs, plants or machines.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Regularly every 12 months. More frequent inspections might be needed based on risk assessment.	Thorough inspection of fixed ladders. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person	Inspection records, report or certificate Risk assessment	PM					EVID		
FR	3	No additional requirements	No additional requirements	No additional requirements	Maintenance logbook Training records								NAR
IT	2	No additional requirements.	Check if the dimensions allow the passage of people and any work tools, and in any case with a width of not less than 60 cm. Protective cage required if the ladder's height exceeds 5 metres or an angle of 75°, the cage must be installed starting from 5 metres from the ground.	No additional requirements	No additional requirements						CT		
PL	5	No additional requirements	No additional requirements	No additional requirements	Inspection records must be kept for 5 years. Training records								NAR
ROI	4	No additional requirements	No additional requirements	No additional requirements	Inspection records must be kept for 5 years.								NAR

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist company.	Inspections carried out every 12 months.
DE	DGUV Information 208-032 - Auswahl und Benutzung von Steigleitern	Expert person (sachkundige Person).	Visual check by user prior to each use Inspection intervals according to manufacturer's stipulation, and based on risk assessment, but at least every 12 months is recommended.
ES	Royal Decree 486/1997, minimum prevention measures in working places. Prevention Technical Note NTP 404 (Fixed ladders) Prevention Technical Note NTP 408 (Service fixed ladders)	Competent person.	Periodic inspections depending on use and conditions. Recommended every 3 months. Recommended to have a checklist and maintain inspection records.
FR	Labour Code Art L. 4321-1 and Art R. 4322-1 (equipment maintenance) https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018531543/ Labour code Article R4323-81 to R4323-88 https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018531342/	Qualified person.	Inspections carried out every 12 months.
IT	UNI EN ISO 14122-4:2016 Legislative Decree 9.04.2008 n° 81 art. 113 UNI EN 353:2018 (If a fall arrest system is installed, as an alternative to the protective cage)	Competent and trained person.	Periodic inspections follow manufacturer's instructions.
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (OJ 2003 No 169 item 1650) as amended.	Competent person.	Periodic inspection in accordance with manufacturer's instructions or internal procedures.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent, trained person.	Frequency of inspection based on risk assessment and competency of the person conducting the inspection. Inspection records to be kept for at least 5 years.
SK	Ordinance No. 147/2013 Coll., laying down details for ensuring safety and health protection in construction work and work related to them and details on professional competence to perform certain work activities Government Regulation no. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment STN 74 3282: Steel ladders. Basic regulations.	Competent person, best practice to outsource to specialist company.	Visual check prior each use. Inspections must be carried out every 12 months.
UK	The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) The Work at Height Regulations 2005 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) The Work at Height Regulations (Northern Ireland) 2005 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent and trained person.	Visual check prior each use. Inspections should be conducted at least every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Mobile Ladders
APM Object	CT.HEIGHT.LADDERS.M
APM Description	Mobile ladders.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LADDER.MOBILE	**Related CT Areas:**	Not Specified		

Scope

Any site with mobile ladders being used.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Regularly, at least every 12 months. More frequent inspections might be needed based on risk assessment of use frequency, environmental conditions, etc.	Periodic inspection of mobile ladders to ensure correct and safe operation, including stiles, feet, rungs, locking mechanisms, platforms, etc. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person	Inspection records, report or certificates Risk assessment	PM					EVID		
IT	2	No additional requirements	Inspection as per [1].	No additional requirements	Declaration of Conformity (UNI EN 131/D.Lgs 81/08); Inspection records must be kept for at least 3 years	(PM)					EVID		
PL	3	No additional requirements	Inspection as per [1].	No additional requirements	Records must be kept for at least 5 years	(PM)					EVID		
ROI	4	No additional requirements	Inspection as per [1].	No additional requirements	Records must be kept for at least 5 years	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist.	Inspections carried out every 12 months
DE	Technische Regeln für Betriebssicherheit: TRBS 2121 Teil 2 - Gefährdung von Beschäftigten bei der Verwendung von Leitern TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen	Competent person (fachkundig) for general inspection, Qualified person (befähigte) for periodic inspections.	Frequency dependant on operating conditions, and risk assessment. Visual inspections before each use, and after installation of attachments and repairs.
ES	UNE EN 131 Standard (ladders) RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. Prevention Technical Note NTP 239 (Mobile ladders)	Competent person.	Periodic inspections depending on use and conditions. Maintenance is recommended every 6 months.
FR	Labour Code Art L. 4321-1 and Art R. 4322-1 (equipment maintenance) https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018531543/ Labour code Article R4323-81 to R4323-88 https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018531342/	Qualified person.	Inspections carried out every 12 months.
IT	UNI EN 131:2013 UNI EN 14183:2004 UNI 10401:2004 Legislative Decree 9.04.2008 n° 81 Annex XX	Competent and trained person.	Periodic maintenance follow manufacturer's instructions.
PL	Regulation of the Minister of Labour and Social Policy of September 26, 1997 on general provisions on health and safety at work (Journal of Laws of 1997, No. 129, item 844) Regulation of the Minister of Economy of 30 October 2002. On minimum requirements for health and safety in the use of machines by workers at work. (Journal of Laws of 2002, No. 191, item 1596)	Competent person.	Periodic inspection in accordance with manufacturer's instructions or internal procedures.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent and trained person.	Frequency based on risk assessment. Visual check prior use and recommended every month.
SK	Ordinance No. 147/2013 Coll., laying down details for ensuring safety and health protection in construction work and work related to them and details on professional competence to perform certain work activities Government Regulation no. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment STN EN 131-2+A2: Ladders. Part 2: Requirements, testing, marking.	Competent person, best practice to outsource to specialist company.	Visual check prior each use. Inspections must be carried out every 12 months.
UK	The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) The Work at Height Regulations 2005 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Safe use of ladders and stepladders: A brief guide (hse.gov.uk) The Work at Height Regulations (Northern Ireland) 2005 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent and trained person. Typically an insurance company.	Undertake visual check prior to each use. Inspection frequency should be based on risk assessment but should not exceed 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Mobile elevating working platforms
APM Object	CT.HEIGHT.MOBILEPLAT
APM Description	Mobile elevating working platforms (MEWP, cherry picker).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

Any site where mobile elevating working platforms (MEWP) are operated, such as cherry pickers and scissor lifts.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance (lubrication, replacing components, topping-up fluid levels, routine adjustments).	Competent person.	N/A						CT		
All	2	Before it is first used and/or assembled	Thorough inspection of the integrity and correct operation of the scissor lifts. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be organised by insurance company	Inspection records, report or certificate. Retain until equipment is no longer in use.								EVID one off
All	3	Regularly, at least every 6 months. More frequent inspections might be needed depending on operating and environmental conditions, or after modifications or events which could have caused damage	Thorough inspection of the integrity and correct operation of the scissor lifts. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be organised by insurance company	Inspection records, report or certificate. Retain until next report is made. Risk assessment					CT			
FR	5	Regular inspections every 3 to 6 months.	No additional requirements	No additional requirements	Maintenance logbook Training records					CT			
IT	6	Preliminary inspection if the equipment has not been used for more than 3 months.	No additional requirements	No additional requirements	CE Declaration of Conformity. Equipment control log, to be kept for at least 3 years								EVID on demand

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to accredited, H&S specialist	Inspections carried out every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV 100-500 – Betrieben von Arbeitsmitteln DGUV Grundsatz 308-002 - Prüfung von Hebebühnen	Expert (Sachkundige) according to DGUV Regel 100-500	Inspection before initial commissioning (or recommissioning) and every 12 months, based on risk assessment.
ES	UNE 58921:2017 Instructions for installation, handling, maintenance, revisions and examinations of mobile elevating work platforms (UNE Norms available for a fee). Directive 2006/42 / EC of the European Parliament and of the Council of 17 May 2006 on machines RD 1644/2008, of October 10, which establishes the rules for the marketing and commissioning of machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment	Competent person. Scissor lifts inspections by an accredited company certified under UNE-EN ISO/IEC 17020	Annual revisions by competent personnel that can be from the owner's equipment. Inspections every 3 years by a certified company under UNE-EN ISO/IEC 17020. In case of modifications, accidents or long time without use, an extraordinary inspection would be required.
FR	1 March 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 March 2004 Decree (modified) https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000439029/ Ministerial Order of March 1st 2004 relating to inspection https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000439029/ Ministerial Order of March 2nd 2004 relating to maintenance logbook. https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000252250/	Qualified person.	Inspections carried out every 3 to 6 months.
IT	UNI EN 1459-1:2020 Legislative Decree 9.04.2008 n° 81 Directive 2006/42/CE on machinery (Annex II A) UNI ISO 18893:2020 (Safety principles, inspection, maintenance and operation) UNI EN 1570:2015 (Safety requirements) UNI ISO 16653:2011 (Design, calculations, safety and test for special applications) UNI EN 280:2015 (Design, stability, construction, safety and test) UNI ISO 20381:2011 (Graphic symbols) DM 11/04/2011 (Periodic inspection)	Competent person.	Maintenance in accordance with manufacturer's instructions. Inspections every 12 months
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical supervision in the field of operation, repair and modernization of handling equipment. Regulation of the Minister of Economy of 30 October 2002. On minimum requirements for health and safety in the use of machines by workers at work. (Journal of Laws of 2002, No. 191, item 1596)	Government body (UDT - Technical Inspection)	Full periodic verification of integrity and operation at least every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource. Independent and INAB accredited company (BS EN ISO/IEC 17020:2004)	Through examination at least every 6 months and before it is first used. Regular maintenance (PPM).
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment Government Regulation no. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment	Competent person, best practice to outsource to specialist company.	Professional inspections every 12 months, professional examination (testing) every 24 months.
UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource. Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Thorough inspection of the integrity and correct operation of the equipment before it is first used / assembled and every 6 months. Planned maintenance programme in place.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Work at height Personal Protective Equipment
APM Object	CT.HEIGHT.PPE
APM Description	Work at height Personal Protective Equipment (PPE), such as harnesses, fall arrest systems and fall restraint lanyards.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with Personal Protective Equipment (PPE) aimed to prevent falls of employees working at height. This Compliance Standard covers harnesses, fall arrest systems and fall restraint lanyards.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	At least every 6 months. More frequent inspections (interim) might be needed based on site specific risk assessment.	Thorough inspection of work-at-height PPE, including cuts, abrasion, degradation or contamination. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement - do Not use. Report issue.	Competent, independent person, H&S specialist.	Inspection records, report or certificate. Retain records. Risk assessment					CT			
FR	3	No additional requirements.	No additional requirements	No additional requirements	Training records								NAR
IT	5	No additional requirements.	No additional requirements	No additional requirements	CE Declaration of Conformity								NAR
PL	2	No additional requirements.	No additional requirements	No additional requirements	No additional requirements.								NAR
ROI	4	No additional requirements.	If equipment is hired, ensure inspections have been conducted and the results of those are satisfactory.	No additional requirements	Maintenance logbook Records to be kept for at least 5 years.								As Needed EVID

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist company.	Inspections carried out every 12 months.
DE	PSA-Benutzungsverordnung (PSA-BV) DGUV Regel 112-198 - Benutzung von persönlichen Schutzausrüstungen gegen Absturz DGUV Grundsatz 312-906 - Grundlagen zur Qualifizierung von Personen für die sachkundige Überprüfung und Beurteilung von persönlichen Absturzschutzausrüstungen	Expert (sachkundige Person), DGUV 112-198.	Visual check prior to each use and inspection every 12 months, based on risk assessment.
ES	RD 2177/2004 for him that the minimum provisions are established safety and health for use by the workers of the work teams, in terms of temporary work at height. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. Prevention Technical Note NTP 682. Prevention Technical Note NTP 1,108 (Risk and Prevention measures) Prevention Technical Note NTP 1,109 (Installation techniques) Prevention Technical Note NTP 1,110 (Ropes) UNE EN 795:2012 (Personal fall protection equipment - Anchor devices) and UNE EN 353 Standards (Personal fall protection equipment - Guided type fall arresters including an anchor line - Part 1:)	Competent person.	Inspections every 12 months. For anchoring systems, resistance and reliability of the systems must be checked by a competent person before installing them. Registers of the inspection must be kept.
FR	19th March 1993 Decree "Dispositions de l'arrêté du 19 mars 1993 concernant ces équipements" Ministerial Order of March 19th 1993 – PPE list with periodic inspection https://www.legifrance.gouv.fr/jorf/id/JORFTEXT000000730566	Qualified person.	Inspections carried out every 12 months.
IT	Legislative Decree 9.04.2008 n° 81 annex VIII UNI EN 361:2003 (Harness) UNI EN 813:2008 (Belts with leg loops) UNI EN 365:2005 (Use instructions, maintenance, inspection, repair, labelling and packaging) UNI EN 363:2019 (Fall arrest systems) UNI EN 362:2005 (Connectors) UNI EN 360:2003 (Retractable type fall arrest systems) UNI EN 358:2019 (Positioning belts and lanyards) UNI EN 355:2003 (Fall arrest lanyards) UNI EN 354:2010 (Fall restraint Lanyards)	Competent, qualified person.	Inspections every 12 months following manufacturer's instructions.
PL	Regulation of the Minister of Labor and Social Policy of September 26, 1997 on general provisions on health and safety at work (Journal of Laws of 1997, No. 129, item 844)	Government body (UDT - Technical Inspection)	Periodic inspection in accordance with manufacturer's instructions.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Pre-use checks, inspection frequency based on risk assessment, but at least every 6 months
SK	Ordinance No. 147/2013 Coll., laying down details for ensuring safety and health protection in construction work and work related to them and details on professional competence to perform certain work activities	Competent person, best practice to outsource to specialist company.	Visual check by user, prior to its use. Periodic inspection in accordance with manufacturer's instructions, at least every 12 months and after each emergency event, in particular after the fall of a person and after extreme stress in conditions which impair its safe condition.
UK	The Personal Protective Equipment at Work Regulations 1992 The Work at Height Regulations 2005 The Provision and Use of Work Equipment Regulations 1998 BS EN 365:2004 Personal protective equipment against falls from a height. INDG367 - Inspecting fall arrest equipment made from webbing or rope (hse.gov.uk) BS 7883:2019, Personal fall protection equipment Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 The Work at Height Regulations (Northern Ireland) 2005	Competent person, best practice to outsource to specialist company. Can be an internal, impartial and trained person.	Visual check prior each use. Statutory thorough inspection every 6 months, or more frequently based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Work Restraint System					
APM Object	CT.HEIGHT.RESTRAINT					
APM Description	Work Restraint Systems (e.g. anchors)					
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template					
Last Update: (Version) ago-23	**Last Update Change Detail:** Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.		**Activities may be covered by No-Go restrictions:** Not Specified	**Special Certification Required:**	**Delivered By:**	
Evidenced part or full by PM: Not Specified	**Related BBM PM:** Not Specified		**Related CT Areas:** Not Specified			

Scope

Any site with Work Restraint Systems in place to protect employees working at height.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Thorough inspection frequency based on risk assessment, but not to exceed 12 months.	Periodic inspection to ensure correct and safe operation. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issues.	Competent person, typically outsourced	Inspection records, report or certificate Risk assessment						CT		
IT	4	No additional requirements	Inspection as per [1]	No additional requirements	CE Declaration of Conformity if installed on reinforced concrete; Manufacturer's mark						(CT)		
PL	2	No additional requirements	Inspection as per [1]	No additional requirements	Maintenance logbook Training records Inspection records to be kept for at least 5 years.						(CT)		
ROI	3	No additional requirements	Inspection as per [1]	No additional requirements	Inspection records to be kept for at least 5 years.						(CT)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist company.	Inspections carried out every 12 months.
DE	DGUV Regel 112-198 - Benutzung von persönlichen Schutzausrüstungen gegen Absturz DGUV Grundsatz 312-906 - Grundlagen zur Qualifizierung von Personen für die sachkundige Überprüfung und Beurteilung von persönlichen Absturzschutzausrüstungen	Expert (sachkundige Person), DGUV 112-198.	Visual checks before each use. Inspections every 12 months based on risk assessment.
ES	UNE EN 795:2012 (Personal fall protection equipment - Anchor devices) UNE EN 353 (Personal protective equipment against falls from a height) Prevention Technical Note NTP 809 on anchoring systems RD 2177/2004 for him that the minimum provisions are established safety and health for use by the workers of the work teams, in terms of temporary work at height. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment.	Competent person.	Periodic inspections depending on use and conditions. Recommended every 12 months.
FR	Labour Code Art L. 4321-1 and Art R. 4322-1 (equipment maintenance) https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018531543/ 19th March 1993 Decree "Dispositions de l'arrêté du 19 mars 1993 concernant ces équipements" Ministerial Order of March 19th 1993 – PPE list with periodic inspection https://www.legifrance.gouv.fr/jorf/id/JORFTEXT000000730566	Qualified person.	Inspections carried out every 12 months.
IT	Legislative Decree 9.04.2008 n° 81 UNI EN 363:2019 UNI EN 365:2005 UNI EN 795:2012 UNI 11578:2015 (Requirements and test) UNI 11560:2014 (Roof anchoring systems) UNI 11158:2015 (Inspections) UNI EN 516:2006 (Installations for safe access to the roof) UNI EN 517:2006 (Safety anchors for roofs)	Competent and trained person	Periodic maintenance follow manufacturer's instructions every 12 months for anchorages complying with the standard UNI EN 795:2012, every 48 months according to the standard UNI 11578:2015
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (OJ 2003 No 169 item 1650) as amended.	Competent person.	Periodic inspection in accordance with manufacturer's instructions.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent and trained person.	Based on risk assessment. Recommended pre-use checks and inspections at least every 6 months.
SK	Ordinance No. 147/2013 Coll., laying down details for ensuring safety and health protection in construction work and work related to them and details on professional competence to perform certain work activities	Competent person, best practice to outsource to specialist company.	Inspections must be carried out at least every 12 months.
UK	The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) The Work at Height Regulations 2005 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) BS 7883:2019, Personal fall protection equipment. Anchor systems. System design, installation and inspection. Code of practice Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) The Work at Height Regulations (Northern Ireland) 2005 (legislation.gov.uk)	Competent and trained person	Visual checks before each use. Inspections every 12 months, or more frequently based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Scaffold
APM Object	CT.HEIGHT.SCAFFOLD
APM Description	Scaffolding - any temporary structure used to support people or equipment for access to elevated work areas
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where scaffolding is used to work at height.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
FR	3	No additional requirements	Inspection as per [2].	No additional requirements	Training records			CT					
IT	5	No additional requirements	Inspection as per [1] and [2].	No additional requirements	Manufacturer's mark			CT					
IT	6	When modifications, long period without use, seismic episode or when any condition that could affect the stability or resistance	Inspection as per [2].	Competent person with university or professional degree or with more than 2 years of experience in scaffolders.	No additional requirements			CT					
PL	2	Regular inspection every 10 days by relevant engineer. Ad-hoc reviews - after 2 weeks of scaffold being unused and after each thunder with wind speed exceeding 12 meters/sec	Additional inspections according to Polish norm PN-M-47900-2:1996	No additional requirements	The scaffolding acceptance should be confirmed with an entry in the construction logbook or in the technical acceptance protocol, Scaftag								CT
ROI	4	Regular inspections every week.	Inspection as per [2].	No additional requirements	Inspection records to be kept for 5 years. Maintenance logbook.		CT						

UK	1	Weekly inspection. Additionally, following any circumstance liable to jeopardise the safety of the installation (e.g adverse weather conditions, impact)	Inspection as per [2].	No additional requirements	Inspection report. Tag system is recommended to signal people that scaffold has been inspected		CT						

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist company.	Inspections carried out every 12 months.
DE	Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen TRBS 2121 Teil 1 - Gefährdungen von Personen durch Absturz - Bereitstellung und Benutzung von Gerüsten DGUV Information 201-011 - Handlungsanleitung für den Umgang mit Arbeits- und Schutzgerüsten	Qualified person for acceptance inspection (befähigte Person). Competent person for general inspection.	Acceptance inspection after setting up, modifications and before initial operation. Visual inspections before each use and based on risk assessment.
ES	UNE-EN 12810 Standard on Scaffolders UNE-EN 12811 Standard on Performance requirements and general design RD 2177/2004 for him that the minimum provisions are established safety and health for use by the workers of the work teams, in terms of temporary work at height. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. Prevention Technical Note NTP 1015 Prevention Technical Notes NTP 1016	Competent person with university or professional degree or with more than 2 years of experience in scaffolders.	Inspections at start of each day and after exceptional weather. Recommended to inspect the area before the installation
FR	Art 6 Decree of 21 December 2004 "Arrêté du 21 décembre 2004 relatif aux vérifications des échafaudages et modifiant l'annexe de l'arrêté du 22 décembre 2000 relatif aux conditions et modalités d'agrément des organismes pour la vérification de conformité des équipements de travail" Arrêté du 21 décembre 2004 relatif aux vérifications des échafaudages et modifiant l'annexe de l'arrêté du 22 décembre 2000 relatif aux conditions et modalités d'agrément des organismes pour la vérification de conformité des équipements de travail - Légifrance (legifrance.gouv.fr)	Qualified person.	Inspections carried out initially, daily and quarterly.
IT	Legislative Decree 9.04.2008 n° 81 art. 122 UNI EN 12810:2004 (Specifications) UNI EN 12811:2004 (Performance requirements) UNI EN 74:2007 (Joints) UNI EN 16508:2016 (Coverage and encapsulation) UNI EN 13374:2019 (Temporary lateral protection)	Competent and trained person.	Depends on type of scaffold. Verification before and after assembly. Inspections at regular interval and after exceptional weather conditions or temporary interruption of work.
PL	Regulation of the Minister of Infrastructure of 6 February 2003 on occupational health and safety during construction works.	Competent person.	Acceptance inspection after placing the scaffolding. Periodically inspection, at least once a month (10 days after bad weather conditions)
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Inspection once erected and at least every week. Maintenance programme in place.
SK	Ordinance No. 147/2013 Coll., laying down details for ensuring safety and health protection in construction work and work related to them and details on professional competence to perform certain work activities Government Regulation no. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment Government Regulation no. 396/2006 Coll. on the minimum safety and health requirements for the construction site STN 73 8101/a: Scaffolding. Common provisions.	Competent person, best practice to outsource to specialist company.	Scaffolding must be inspected before its first use. Regular interval: Every 30 days for fixed scaffolding, every 14 days for mobile scaffolding, or exposed to the effects of mechanical vibration and always after temporary interruption of work or exceptional weather conditions.
UK	The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) The Work at Height Regulations 2005 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) The Work at Height Regulations (Northern Ireland) 2005 (legislation.gov.uk)	Competent person, best practice to outsource (scaffolder).	Inspection once erected and at least every week. Bad weather conditions might require more frequent inspections.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Compliance - Air Conditioning > 12kW
APM Object	CT.HVAC.12kW
APM Description	Air conditioning systems with an effective rated output of more than 12kW, with addition requirements if >12kW.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.RTU HVAC.CHILL HVAC.AC HVAC.CU	**Related CT Areas:**	Not Specified		

Scope

Any site with air conditioning systems with an effective rated output of more than 12 kW, when either an individual unit is ≥ 12 kW or multiple individual units of < 12 kW are connected in the same system to give ≥ 12 kW in total.
This applies to all refrigerants including non-fluorinated e.g Ozone Depleting Substances like R22. This is a sustainability-driven requirement to identify system defects that can lead to leaks.
Additional requirements are present for systems >70kW.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	At least every 5 years, at regular intervals. Defects and opportunities for improvement to be scheduled as required.	Intrusive inspections and condition assessment.	Qualified or Competent Person (e.g. energy assessor), registered with appropriate certification body	Retain records of most recent inspection.								5 Year CT
All	2	Annual	Maintenance of system (>12kW <70kW)	Qualified or Competent Person	Retain records of maintenance	PM					EVID		
All	3	Monthly	Maintenance of system (>70kW)	Qualified or Competent Person	Retain records of maintenance	PM					EVID		
ES	6	Every 2 years	For installations with power above 70 kW	No additional requirements	Cooling/refrigeration systems >70kW must be legalised through a project	PM					EVID	(CT)	
FR	5	Every 2 years	Inspection thermodynamic systems with an effective rated output of between 4 kW and 70 kW.	No additional requirements	No additional requirements	PM					EVID	(CT)	

IT	4	No additional requirements	Inspection as per [1].	No additional requirements	Installation logbook. CE Declaration of conformity.								N A R

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Energy management Act No. 406/2000 Coll., §6a Regulation No. 193/2012 Coll., on the inspection of air-conditioning systems	Authorised energy inspector.	First inspection 10 years after commissioning (12-100 kW), 4 years (>100 kW), then regular inspection every 10 years (12-100 kW, >100 kW with continual monitoring system), 4 years (>100 kW without continual monitoring system) Above mentioned are energy performance inspections, inspections of units/systems containing refrigerants are set independently (see 35&36 compliance standards).
DE	Gebäudeenergiegesetz - GEG – Abschnitt 3: Energetische Inspektion von Klimaanlagen Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln)	Expert (Fachkundiger), according to GEG.	Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Inspection in the 10th year after commissioning, and then at least every 10 years thereafter (for energy efficiency). When operating more than ten systems of the same type and output in comparable non-residential buildings, a sampling procedure will be permissible.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 2060/2008, of December 12, which approve the regulation on pressure equipment and its complementary technical instructions.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years. For installations with power above 70 kW, biannual inspections are legally required. Maintenance carried out annually. Inspections every 15 12 monthsyears (Pn>20KW heat, Pn>12kW cold)
FR	Environment Code : Art. R224-44 to R224-44-5 relating to maintenance on thermodynamic systems with an effective rated output of between 4 kW and 70 kW Paragraphe 1 : Entretien des systèmes thermodynamiques dont la puissance nominale est comprise entre 4 kW et 70 kW (Articles R224-44 à R224-44-5) - Légifrance (legifrance.gouv.fr) Arrêté du 24 juillet 2020 relatif à l'entretien des systèmes thermodynamiques dont la puissance nominale est comprise entre 4 kW et 70 kW - Légifrance (legifrance.gouv.fr) Environment Code : Art. R224-45 to R224-45-9 relating to maintenance on thermodynamic systems with an effective rated of > 70 kW Paragraphe 2 : Inspection des systèmes thermodynamiques et des systèmes de ventilation combinés à un chauffage par effet joule d'une puissance nominale supérieure à 70 kW (Articles R224-45 à R224-	Accredited person	Inspection every 2 years (thermodynamic systems with an effective rated output of between 4 kW and 70 kW). Inspection every 5 years (thermodynamic systems with an effective rated output of > 70 kW).
IT	Legislative Decree 9/04/2008 n.81 DPR n.74/13 Decree 10/02/2014 D.M. 37/2008 DPR n. 146/18 UNI EN 15218:2013 (Terms, definitions, test conditions and methods, requirements) UNI EN 14511-1:2018 (Terms and definitions) UNI EN 14825:2019 (Test methods and seasonal performance evaluation) UNI 11135:2004 (Seasonal performance evaluation) UNI EN 16798-17:2018 (Guidelines for inspections)	Competent and accredited person.	Inspections every 4 years.
PL	Regulation of Minister of Labor and Social Policy of 26 September 1997 on general health and safety regulations (Journal of Laws 2003, number 169, item 1650) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	N/A	N/A
ROI	S.I. No. 346/2006 - European Communities (Inspection and Assessment of Certain Air-Conditioning Systems) Regulations 2006 (irishstatutebook.ie)	Accredited energy inspector and assessor.	Regular inspections every 5 years after the unit has been commissioned.
SK	Act No. 286/2009 Coll. on fluorinated greenhouse gases Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems STN EN 378-2: Refrigerating systems and heat pumps. Safety and environmental requirements	Qualified and certified person.	Regular inspections every 5 years. Inspection of actual performance efficiency improvements proposal.
UK	The Energy Performance of Buildings (England and Wales) Regulations 2012 (legislation.gov.uk) Building (Scotland) Amendment Regulations 2006 SSI 534 Energy Performance of Buildings (EPB) (Certificates and Inspections) Regulations (Northern Ireland) 2008, as amended	Accredited energy assessor for TM44.	Regular Inspections, at least every 5 years.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Boilers
APM Object	CT.HVAC.BOILERS
APM Description	Gas-powered boilers and associated infrastructure (e.g pipework, flues etc).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.RTU HVAC.BLR HVAC.HTR HVAC.GHGAS	**Related CT Areas:**	CT.PRESSURE.SYS, CT.HVAC.GASINSTALL		

Scope

Any site with gas boilers designed to provide heating or hot water.
This Compliance Standard only covers the maintenance of boilers, inspections of expansion tanks and pressure vessels is covered in Compliance Standard CT.PRESSURE.SYS and gas installations in CT.HVAC.GASINSTALL

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all gas-fired boilers.	Competent Person (Accredited on Gas Safe Register).	Maintenance records, examination report or certificate.	PM					EVID		
All	2	Inspections to be carried out at least every 12 months, as best practice. Consider scheduling in summer.	Examination of safe operation, physical integrity and ensure performance of the boiler. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Maintenance records, examination report or certificate.	PM					EVID		
All	3	Slam shut-off valves to be inspected every 12 months	Regular checks of slam shut-off valves (if present) to ensure correct operation.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Maintenance records, examination report or certificate.	PM					EVID		
CZ	4	Slam shut-off valves to be inspected every 4 months.	Inspection as per [3].	Certified specialised gas equipment technician.	Maintenance logbook.	(PM)					EVID		
DE	5	Every 2 years for plant older than 12 years (≤12J) Every 3 years for plants of 12 years or less.	Monitoring measurements based on heating plant certificate.	Chimney sweeper	Records of monitoring measurements. Sweep logbook Heating Plant Certificate							CT	

FR	6	Every 2 years for systems > 400kW and <20MW	Inspection as per [2]	Certified specialised gas equipment technician.	Control Report	(PM)					EVID		
PL	7	Every 6 months	Inspection of shut-off valves in buildings of more than 2000 m2.	No additional requirements	No additional requirements	PM					EVID		
SK	8	Before first operation, during general maintenance or building reconstruction, during change of fuel, after 12 months of operation (at the beginning of every season in case of seasonal operation).	Inspections as per [2].	Qualified person for boilers above 100 kW.	Written report to be archived for 5 years.	(PM)					EVID		
UK	9	Schedule inspections if Written Scheme of Examination requires examination at greater frequency that RME standard in [1]	Inspections must be undertaken in line with a Written Scheme of Examination if steam boiler	Qualified or Competent Person.	Written Scheme of Examination.							CT	

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree No. 85/1978 Coll. Decree No.21/1979 Coll. Decree No. 34/2016 ČSN 69 0012, ČSN EN 12 186	Specialized technician of gas equipment. Chimney sweep.	Regular checks yearly. Operational inspection every 3 years. Inspection of shut-off valves every 4 months. Chimney inspection yearly.
DE	Betriebsicherheitsverordnung (BetrSichV) – Tabelle 12 Verordnung zum Bundesimmissionsschutzgesetz (1. BImSchV) §15 Kehr- und Überprüfungsordnung (KÜO) Anlage 1 Schornsteinfegerhandwerksgesetz (SchfHwG) Gesetz zur Einsparung von Energie und zur Nutzung erneuerbarer Energien zur Wärme- und Kälteerzeugung in Gebäuden (Gebäudeenergiegesetz - GEG)	Expert (Fachkundiger) according to GEG. Chimney sweep (Schornsteinfeger) according to KÜO Competent Person (befähigte Person) According to BetrSichV	Recurring inspections every 2 or 3 years depending on criteria outlined in BImSchV §15. Sweeps and inspections every 1 – 3 years depending on plant type according to KÜO- Anlage 1. Inspection frequency of 10 years for expansion vessels in heating and cooling systems with water or heating medium temperature of 120°C or less (integrity and strength inspection of pressure systems), risk assessment mandatory, according to BetrSichV. According to GEG § 72, gas boilers are no longer allowed to be used if installed before 1991. If installed after 1991 they must be decommissioned after 30 years.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 2060/2008, of December 12, which approve the regulation on pressure equipment and its complementary technical instructions.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years. For installations with power above 70 kW, biannual inspections are legally required.
FR	For boilers (400kW and <20MW): Environment Code: Art . R . 224-20 to 38 Sous-section 2 : Rendements, équipement et contrôle des chaudières (Articles R224-20 à R224-41-9) - Légifrance (legifrance.gouv.fr) For boilers (4kW and <40kW): Environment Code: Art . R . 224-41 Paragraphe 4 : Entretien annuel des chaudières dont la puissance nominale est comprise entre 4 et 400 kW (Articles R224-41-4 à R224-41-9) - Légifrance (legifrance.gouv.fr)	Accredited company or qualified person	Inspection every 2 years (for boilers (400kW and <20MW), maintenance every 12 months and quarterly performance check.
IT	Legislative Decree 9/04/2008 n.81 DM 11/04/2011 DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008) DPR 74/2013 Legislative Decree 4/07/2014 n.102 Legislative Decree 19/08/2005 n.92 Regulation 2016/426/EU Directive 2014/68/EU UNI 7129-1:2015 (Construction and improvements) UNI EN 15502-1:2015 (General requirements and test)	Competent and accredited person, considered best practice to outsource to specialist company.	Maintenance as per manufacturer instructions Every year. Inspection of operation every 5 years, and of integrity every 10 years. Inspection of boiler flue gases every 2 years (boilers >100KW) or every 4 years (boilers </= 100KW). Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used.
PL	Act of 7 July 1994 on construction law (Journal of Laws 1994 item 1333) Act of 27 April 2001 on environmental law (Journal of Law 2020, item 1219) Regulation of Minister of the Environment of August 24, 2012 on the levels of certain substances in the air (Journal of Laws 2021, item 845) Regulation of Minister of Environment of 2 July 2010 on the types of installations the operation of which requires notification (Journal of Laws 2019, item 1510) Regulation of the Minister of the Environment of 2 July 2010 on cases where the introduction of gases or dust into the air from the installation does not require a permit (Journal of Laws 2010, number 130, item 881) Regulation of the Minister of Development and Finance of August 1, 2017 on the requirements for	Qualified or competent person.	Every 12 months. For objects more than 2000m2, every 6 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person. Engineer on the Register of Gas Installers Ireland (RGII)	Regular maintenance of equipment in accordance with manufacturer's recommendations. Inspections at least every 12 months

SK	Act No. 124/2006 Coll. on safety and health at work Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Ordinance No. 25/1984 Coll. on ensuring work-safety in low-pressure boiler rooms Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment. Ordinance No. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of a fuel appliance, electrothermal appliance and central heating equipment and in the construction and use of chimneys and flues and on the deadlines for their cleaning and inspections	Qualified person	Every 12 months. The operating rules shall specify the method, procedure, scope and deadlines for cleaning the boilers.
UK	The Gas Safety (Installation and Use) Regulations 1998 (legislation.gov.uk) The Pressure Systems Safety Regulations 2000 Pressure Systems Safety Regulations (Northern Ireland) 2004	Competent person on the Gas Safe Register.	Routine maintenance carried out during regular examination, following manufacturer's recommendations. Inspections 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Combined Heat and Power
APM Object	CT.HVAC.COMBINEDHP
APM Description	Gas-powered Combined Heat and Power systems and associated infrastructure.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with gas-powered Combined Heat and Power (CHP) systems designed to provide power, heating and hot water.
This Compliance Standard only covers the gas installation of CHP systems, Inspections of gas installations, and pressure vessels are covered in Compliance Standards CT.HVAC.GASINSTALL and CT.PRESSURE.SYS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendations.	Routine maintenance and inspections of all appliances, equipment and gas systems, as per manufacturer's recommendation and instructions.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, report or certificate.	PM					CT		
All		Based on risk assessment, but at least every 12 months	Periodic inspection and testing CHP systems. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, report or certificate.	PM					CT		
All		Inspection at least every 12 months.	Regular checks of slam shut valves (if present) to ensure correct operation.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, report or certificate.	PM					CT		
CZ	4	Slam shut-off valves to be inspected every 4 months.	Inspection as per [3].	Certified specialised gas equipment technician.	APM Record								4M CT
DE	5	Every 2 years for plant older than 12 years (≤12J) Every 3 years for plants of 12 years or less.	Monitoring measurements based on heating plant certificate.	Authorised chimney sweeper.	Records of monitoring measurements. Sweep logbook Heating Plant Certificate							CT	

IT	8	Before first operation, during general maintenance or building reconstruction, during change of fuel, after 12 months of operation (at the beginning of every season in case of seasonal operation).	No additional requirements	Qualified person for boilers above 100 kW	Installation logbook. CE Declaration of Conformity Written report to be archived for 5 years.						CT		
PL	6	Every 6 months	Inspection of shut-off valves in buildings of more than 2,000 m2.	No additional requirements	No additional requirements					CT			
UK	7	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme.	PM					CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree No. 85/1978 Coll. Decree No.21/1979 Coll. Decree No. 34/2016 ČSN 69 0012, ČSN EN 12 186 ČSN 331600	Specialized technician of gas equipment. Inspection technician of electrical equipment. chimney sweep	Routine checks every year. Operational inspection every 3 years Inspection of shut-off valves every 4 months. Chimney inspection yearly.
DE	Gebäudeenergiegesetz – GEG § 60 Betriebssicherheitsverordnung (BetrSichV) Bundes-Immissionsschutzgesetz (BImSchG) §29a Technische Anleitung zur Reinhaltung der Luft (TA Luft) Verordnung zum Bundesimmissionsschutzgesetz (1. BImSchV) Kehr- und Überprüfungsordnung (KÜO) Schornsteinfegerhandwerksgesetz (SchfHwG)	Expert (Fachkundiger), according to GEG Authorised chimney sweeper.	Regular intervals determined by risk assessment, overall capacity and manufacturer specifications. Monitoring and inspections by chimney sweeper to be carried out every 1-3 years.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 2060/2008, of December 12, which approve the regulation on pressure equipment and its complementary technical instructions.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years. For installations with power above 70 kW, biannual inspections are legally required. Inspections every 12 months (Pn>20KW heat, Pn>12kW cold)
FR	Ministerial Order of November 2nd 2017 relating to monitoring of electricity generation facilities: Arrêté du 2 novembre 2017 relatif aux modalités de contrôle des installations de production d'électricité - Légifrance (legifrance.gouv.fr)	Accredited company.	Every 4 years during the initial phase.
IT	Legislative Decree 9/04/2008 n.81 DM 11/04/2011 DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008) Legislative Decree 3/04/2006 n.152 Decree 16/03/2017 Regulation 2402/2015/EU Legislative Decree 4/07/2014 n.102 DM 04/08/2011 Legislative Decree 3/03/2011 n.28 Legislative Decree 8/02/2007 n.20	Competent and accredited person, considered best practice to outsource to specialist company.	Operational inspection every 5 years. Maintenance as per manufacturer instructions. Generally, every 12 months. Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of 12 April 2002 of Minister of Infrastructure on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	Qualified or competent person.	According to manufacturer's instruction, but at least every 12 months. Slam shut-off valves inspection every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person. Must be a competent engineer on the Register of Gas Installers Ireland (RGII).	Routine maintenance in accordance with manufacturers recommendations. Inspections of CHP systems and shut-off valves at least every 12 months.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 309/2009 Coll. on the promotion of renewable energy sources and high-efficiency cogeneration Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Ordinance No. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of a fuel appliance, electrothermal appliance and central heating equipment and in the construction and use of chimneys and flues and on the deadlines for their cleaning and inspections Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified and certified person.	Periodic maintenance in accordance with manufacturer's instructions. Minimum period is 3 years but can be more frequent in specific cases. Inspections based on standardized testing of selected technical equipment.

UK	The Gas Safety (Installation and Use) Regulations 1998 Gas Safety (Installation and Use) Regulations (Northern Ireland) 2004	Competent person. Must be a competent engineer, accredited on the Gas Safe Register.	Routine maintenance carried out during regular examination, following manufacturer's recommendations. Inspections of system and shut-off valves at least every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	F-Gas Air-Conditioning
APM Object	CT.HVAC.FGAS
APM Description	All stationary refrigeration, air-conditioning, heat-pump (RAC), HV switchgear or fire protection equipment, fire extinguishers that contains F-Gas refrigerants
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Roof Top Units->Refrigeration Part Air Conditioning Units - inside unit AC Condenser Unit - outside unit Chillers	**Related CT Areas:**	CT.HVAC.ODS		

Scope

Any site with air conditioning systems containing fluorinated refrigerants listed in https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A32014R0517&qid=1608306002561, where the combination of type and mass gives a CO2 equivalent in the range of 50-500 te. CO2 equivalent values for various refrigerants are given here:
https://www.gov.uk/guidance/calculate-the-carbon-dioxide-equivalent-quantity-of-an-f-gas
Some fire suppression systems and medium/high voltage equipment may also contain fluorinated refrigerants.
Units containing Ozone Depleting Substances (ODS) are outlined in standard CT.HVAC.ODS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance of equipment containing F-gas.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Maintenance logbook	PM					EVID		
All	2	12 months without leak detection system. 24 months with leak detection system	Statutory requirement for leak inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 50 tonnes of CO2. Best practice to include units <5 tonnes CO2 equivalent.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.							CT*	
All	3	6 months without leak detection system. 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 50 to 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*			
All	4	3 months without leak detection system. 6 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*	CT*		
All	5	Every 12 months.	Leak detection system inspections.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT		

All	6	Within 1 month	In the event that a leak is identified and fixed. Reinspection is required.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.								On Demand EVID
PL	7	Every 12 months without leak detection system or every 24 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 10 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT	CT	
PL	8	Every 6 months without leak detection system or every 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 10 to 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT*			
PL	9	Every 6 months. Leak detection system mandatory.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT			
SK	10	Every 3 months without leak detection system or 6 months with leak detection system.	Leak inspection of units with more than 300 kg of fluid charge.	No additional requirements	No additional requirements.					CT*	CT*		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006 Act No. 73/2012 Coll., on substances depleting the ozone layer and F-gases (§4) Regulation No. 257/2012 Coll., on preventing ODS a F-gases emissions.	Third-party, independent vendor. Certified ECO specialist.	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted. Leak detection system inspections every 12 months.
DE	European Regulation (EU) No 517/2014 of the European Parliament and of the Council for F Gas Chemikalien-Klimaschutzverordnung (ChemKlimaschutzV)	Competent person (befähigte Person).	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if a leak-detection system is fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if a leak-detection system is fitted. Every 3 months for units with > 500 tonnes of CO2 equivalent, or 6 months if a leak-detection system is fitted.
ES	Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006 Roya Decree 115/2017 on commercialization, use and maintenance of equipment containing fluorinated gases.	Accredited company	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted.
FR	Arrêté du 29 février 2016 relatif à certains fluides frigorigènes et aux gaz à effet de serre fluorés - Légifrance (legifrance.gouv.fr)	Competent and qualified person.	No additional requirements
IT	DPR 146/2018 Legislative Decree 5/12/2019 n.163 Regulation 517/2014 of the European Parliament and of the Council for F Gas Regulation 303/2008/EC Regulation 1516/2007/EC DPR 43/2012 DPR 147/2006 UNI EN 15004-1:2019 (Fire protection equipment)	Competent and qualified person (Fgas register).	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. This doesn't apply to hermetically sealed systems of <10 tonnes CO2 equivalent. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted.
PL	Act of 15 May 2015 on the on substances that deplete the ozone layer and some fluorinated greenhouse gases (Journal of Laws 2020, item 2065)	Competent and qualified person certified by the Polish State Office of UDT.	Every 12 months for units with 5-10 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 10-50 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 6 months for units with more than 50 tonnes of CO2 equivalent.

ROI	S.I. No. 658/2016 - European Union (Fluorinated Greenhouse Gas) Regulations 2016. (irishstatutebook.ie)	Competent person, certified by the relevant body.	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge.
SK	Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Act No. 286/2009 Coll. on fluorinated greenhouse gases	Qualified and certified person.	Regular inspections every 5 years. Inspection of actual performance efficiency improvements proposal or upon the request from the state authority.
UK	The Fluorinated Greenhouse Gases Regulations 2015 (legislation.gov.uk) Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006 (Text with EEA relevance) (legislation.gov.uk) Fluorinated Greenhouse Gases Regulations (Northern Ireland) 2015 (as amended)	Accredited company certified by a DEFRA appointed certification body.	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Gas Appliances
APM Object	CT.HVAC.GASAPPLIANCE
APM Description	Gas-powered appliances and associated infrastructure.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.GH - GAS	**Related CT Areas:**	CT.SAFE.FLAMGASDETECT - CT.HVAC.GASDET		

Scope

Any site with gas appliances, such as kitchen equipment (e.g. gas stoves). This standard does not include boilers or Combined Heat and Power Stations which are covered under standards CT.HVAC.BOILERS and CT.HVAC.COMBINEDHP respectively.
Gas installations and pipework are covered in standard CT.HVAC.GASINSTALL.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all gas appliances.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Maintenance logbook	PM					EVID		
All		At least every 12 months, but more frequent inspections might be required based on use and site-specific environmental conditions.	Examination of safe operation, physical integrity and performance of all appliances, connections and associated infrastructure (e.g. flues) to ensure safe operation, examine physical condition and ensure correct performance. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Inspection records, report or certificate. Risk assessment	(PM)					(EVID)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A
CZ	Decree No. 85/1978 Coll., Decree No.21/1979 Coll., ČSN 69 0012, ČSN EN 12 186	Third party. Specialized technician of gas equipment.	Regular maintenance in accordance with the manufacturer's recommendations. Inspections of appliances and valves at least every 12 months.

DE	BetrSichV Anhang 3 (zu § 14 Abs. 4) Abschnitt 2 Flüssiggasanlagen DGUV Regel 110-003 - Branche Küchenbetriebe DVGW G 600 DVGW-TRGI 2018 - Technische Regel für Gasinstallationen Arbeitsstättenverordnung (ArbStättV) Niederdruckanschlussverordnung (NDAV) DVGW G 495 - Gasanlagen – Betrieb und Instandhaltung DVGW-Arbeitsblatt G 631 - Installation von gewerblichen Gasgeräten in Anlagen für Bäckereien und Konditoreien, Fleischereien, Gastronomie und Küche, Räuchereien, Reifung, Trocknung sowie Wäschereien	Competent Person (befähigte Person) according to DGUV 110-003 VIU/DVGW approved company.	Inspections to be carried out regularly, at least every 2 years for mobile gas installations and every 4 years for fixed gas installations. Visual inspection at least every 12 months.
ES	RD 919/2006, which approves the Technical Regulation for the distribution and use of gaseous fuels and its complementary technical instructions ICG 01 to 11. UNE 60670 on gas appliances	Accredited company, gas installers.	Maintenance as per manufacturer's recommendation. Inspection of appliances every 5 years, and installation every 2 years.
FR	No additional requirements Observe local site permit	N/A	No additional requirements
IT	Legislative Decree 9/04/2008 n.81 DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008) Decree 22/01/2008 n. 37 Decree 08/11/2019 UNI EN 1749:2020 (Gas appliance classification) UNI EN 1729:2015 (Gas installations) UNI EN 203:2014 (Gas kitchen equipment) Regulation 2016/426/EU DM 37/2008 ISO 23551-4:2018 (Valves)	Competent person, considered best practice to outsource to specialist	Maintenance as per manufacturer instructions. Inspections every 5 years (operation) and 10 years (integrity). Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of 12 April 2002 of Minister of Infrastructure on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065) Regulation of the Minister of Economy of 26 April 2013 on the technical conditions to be met by gas networks and their location (Journal of Laws 2016, item 640)	Qualified or competent person.	Inspections of appliances and shut-off valves in accordance with manufacturer's instruction, but at least every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person. Engineer on the RGII.	Regular maintenance in accordance with manufacturer's recommendations. Inspections of appliances and valves at least every 12 months
SK	Act No. 314/2001 Coll. on fire protection Ordinance No. 121/2002 Coll. on fire prevention Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment. Ordinance No. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of a fuel appliance, electrothermal appliance and central heating equipment and in the construction and use of chimneys and flues and on the deadlines for their cleaning and inspections	Qualified and certified person.	Periodic inspections in accordance with manufacturer recommendation and fire protection/prevention rules. Frequency of professional inspection: 12 months or less frequently, depending on the type of gas appliance. Frequency of Professional test: 3 years or less frequently, depending on the type of gas appliance.
UK	The Gas Safety (Installation and Use) Regulations 1998 (legislation.gov.uk) Safety in the installation and use of gas systems and appliances (hse.gov.uk) Gas Safety (Installation and Use) Regulations (Northern Ireland) 2004	Competent engineer on the Gas Safe Register.	Routine maintenance in accordance with manufacturer's recommendations. Inspections of appliance and valves every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Gas Detectors
APM Object	CT.HVAC.GASDET
APM Description	Gas detectors (mobile and permanent fixed)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Roof Top Units Air Conditioning Units Air Handling Units	**Related CT Areas:**	Not Specified		

Scope

Any site where fitted or portable gas detectors are used to identify potential leaks of, of accumulation of gases.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all gas detectors.	Competent Person.	Retain records of inspections and calibrations.						CT		
All	2	In accordance with manufacturer's recommendations and instructions, but at least every 4 months.	Functional inspection	Competent Person.	Retain records of inspections and calibrations.						CT		
All	3	Once per year	Calibration	Competent Person.	Retain records of inspections and calibrations.						CT		
IT	4	No additional requirements	No additional requirements	No additional requirements	CE Declaration of Conformity.								As Needed EVID

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	1.Routine maintenance of all gas detectors. 2.Functional control 3.Toalibism	Manufacturer or competent person determined by the manufacturer.	In accordance with manufacturer's instructions.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Information 213-056 - Gaswarneinrichtingen für toxische Gase/Dämpfe und Sauerstoff - Einsatz und Betrieb (Merkblatt T 021 der Reihe Sichere Technik) DGUV Information 213-057 - Gaswarneinrichtungen für den Explosionsschutz - Einsatz und Betrieb (Merkblatt T 023 der Reihe Sichere Technik)	Visual inspection by an instructed person (unterwiesene Person). Functional inspection by a qualified person (qualifizierte Person). System inspection by a competent person (befähigte Person).	Visual inspection once a month. Functional inspection every 4 months. If system has self-monitoring system only once a year. System inspections, including calibration and adjustment every 12 months.
ES	RD 919/2006, which approves the Technical Regulation for the distribution and use of gaseous fuels and its complementary technical instructions ICG 01 to 11. UNE-EN 60079-29-1 gas detectors industrial and commercial UNE-EN 60079-29-2, gas detectors industrial and commercial UNE 60601 gas detectors in machine room	Accredited company, gas installers	Maintenance as per manufacturer's recommendation. Inspection of appliances every 5 years, and installation every 2 years.
FR	N/A	N/A	N/A
IT	EN 50291:2010 (Test and performance requirements for carbon monoxide detectors) UNI CEI EN 50244:2001 (Maintenance) UNI CEI EN 50194-1:2010 (Test and performance requirements) EN 50271:2018 (Test and requirements) EN 50104:2019 (Test and requirements) EN 60079-29-1:2016 (Performance requirements; currently under review) UNI EN 14624:2020 (Mobile detectors) EN 50292:2013 (Carbon monoxide detectors) UNI 11522:2014 (Installation and maintenance)	Competent person.	Maintenance in accordance with manufacturer's instructions.
PL	Regulation of Minister of Interior and Administration of June 7, 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Economy of 28 December 2009 on occupational health and safety in the construction and operation of gas networks and the commissioning of natural gas installations (Journal of Laws 2010, number 2, item 6)	N/A	N/A
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, typically the entity undertaking the leak checking	Routine maintenance of gas detectors. Regular calibration in accordance with manufacturer's instructions, but at least 6-monthly
SK	Act No. 124/2006 Coll. on safety and health at work	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment.
UK	The Provision and Use of Work Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person	Monitoring equipment should be in good working order. Calibrated to relevant gas and tested at least in accordance with the manufacturer's recommendations, or in line with risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Gas Installations
APM Object	CT.HVAC.GASINSTALL
APM Description	Gas infrastructure, pipework and supply.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	GAS - HVAC.RTU - HVAC.CU - HVAC.CHILL - HVAC.GH - HVAC.BLR - HVAC.HTR	**Related CT Areas:**	CT.SAFE.FLAMGASDETECT - CT.HVAC.GASAPPLIANCE - CT.HVAC.ODS - CT.HVAC.FGAS - CT.HVAC.GASDET		

Scope

Any site with a gas supply and installations, including gas main supply and, or LPG tanks.
The standard excludes gas cylinders. It is also expected that where a gas main supply is incoming, the utility provider is responsible for the maintenance of that infrastructure.
Where agreed in writing, it is expected that the maintenance of LPG tanks would be the responsibility of the provider.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all gas installations and storage (where applicable).	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, examination and leak checking report or certificate. Risk assessment Maintenance strategy						CT		
All	2	In line with written maintenance strategy and risk assessment, but at least every 12 months, but more frequent inspections might be required based on use and site-specific environmental conditions.	Examination of safe operation, physical integrity and performance of all appliances, gas installations, labelling, telemetry, control valves and infrastructure to ensure safe operation, examine physical condition and ensure correct performance. This includes LPG supply tank (where not owned by the company that supplies the gas).	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, examination and leak checking report or certificate. Risk assessment Maintenance strategy	PM					EVID		
All	3	In line with written maintenance strategy and risk assessment, but at least every 12 months, but more frequent inspections might be required based on use and site-specific environmental conditions.	If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, examination and leak checking report or certificate. Risk assessment Maintenance strategy						CT		
All	4	Slam shut-off valves to be inspected every 12 months.	Regular checks of slam shut valves (if present) to ensure correct operation.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, examination and leak checking report or certificate. Risk assessment Maintenance strategy						CT		
All	5	In accordance with manufacturer's instructions and recommendations.	Specific components - Identify where manufacturer has stated an expiration date for any component – a PM task should be created for replacement.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, examination and leak checking report or certificate. Risk assessment Maintenance strategy						CT		

All	6	In line with written maintenance strategy and risk assessment with minimum of annual visual inspection and leak/pressure testing every 2 years (unless reason to suspect damage or leak).	Above ground pipework including supports valves, coupling, cathodic protection etc (visual inspection, leak testing in line with written maintenance strategy).	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, examination and leak checking report or certificate. Risk assessment Maintenance strategy	(PM)					(EVID)		
All	7	In line with written maintenance strategy and risk assessment. Dependent on pipework material (plastic or metal), depth, land use above and ground conditions. Suggest minimum of: -Excavation and visual inspection	Buried gas supply pipework including valves, coupling, cathodic protection, steel risers etc (periodic excavation, visual inspection, leak testing).	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, examination and leak checking report or certificate. Risk assessment Maintenance strategy							CT	5Y 12Y CT

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree No. 85/1978 Coll., Decree No.21/1979 Coll., ČSN 69 0012, ČSN EN 12 186	Third party. Specialised technician of gas equipment.	12 months inspection (routine checks), 36 months operational inspection. 4 months for shut-off valves.
DE	BetrSichV Anhang 3 (zu § 14 Abs. 4) Abschnitt 2 Flüssiggasanlagen DVGW G 600 DVGW-TRGI 2018 - Technische Regel für Gasinstallationen Arbeitsstättenverordnung (ArbStättV) Niederdruckanschlussverordnung (NDAV) DVGW G 495 - Gasanlagen – Betrieb und Instandhaltung	Competent Person (befahigte Person) according to DGUV 110-003. VIU/DVGW approved company.	Inspections to be carried out before first use (according to DVGW G 469) and then regularly, at least every 2 years for mobile gas installations and every 4 years for fixed gas installations. Visual inspection at least every 12 months of any pipe systems on plaster, and for piping systems with operating pressures up to 100 mbar, a serviceability test every 12 years.
ES	RD 919/2006, which approves the Technical Regulation for the distribution and use of gaseous fuels and its complementary technical instructions ICG 01 to 11.	Accredited company, gas installers.	Maintenance as per manufacturer's recommendation. Inspection of appliances every 5 years, and installation every 2 years.
FR	No additional requirements, observe local site permit Best practice: The NF EN 15001-2 standard defines the conditions for the installation of gas pipes in industrial establishments	N/A	No additional requirements
IT	Legislative Decree 9/04/2008 n.81 DM 11/04/2011 DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008) Decree 04/03/2014 Legislative Decree 11/02/1998 n.32 UNI EN 12186:2014 (Functional requirements) UNI EN 12327:2012 (Functional requirements) UNI EN 15399:2019 (Safety requirements) UNI 9165:2020 (Maintenance) UNI 9860:2020 (Maintenance)	Competent and accredited person, considered best practice to outsource to specialist.	Maintenance as per manufacturer instructions. Inspections every 5 years (operation) and 10 years (integrity). Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of 12 April 2002 of Minister of Infrastructure on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065) Regulation of the Minister of Economy of 28 December 2009 on occupational health and safety in the construction and operation of gas networks and the commissioning of natural gas installations (Journal of Laws 2010, number 2, item 6) Regulation of the Minister of Economy of April 26, 2013 on the technical conditions to be met by gas networks and their location (Journal of Laws 2016, item 640) Regulation of Minister of Interior and Administration of June 7, 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719)	Qualified or competent person.	Inspections of appliances and shut-off valves in accordance with manufacturer's instruction, but at least every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person. Engineer on the RGII.	Regular maintenance in accordance with manufacturer's recommendations. Inspections of appliances and valves at least every 12 months.
SK	Act No. 314/2001 Coll. on fire protection Act No. 124/2006 Coll. on safety and health at work Ordinance No. 121/2002 Coll. on fire prevention Ordinance No. 401/2007 Coll. on the technical conditions and requirements for fire safety during installation and operation of fuel appliances, electro thermal appliances and central heating equipment, and the construction and use Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment.	Qualified and certified person	Inspections in accordance with manufacturer recommendation and fire protection/prevention rules. Frequency of professional inspection: 6 months or less frequent, depending on the type of gas installation; Frequency of Professional test: 3 years or less frequently, depending on the type of gas installation.

UK	The Gas Safety (Installation and Use) Regulations 1998 (legislation.gov.uk) Safety in the installation and use of gas systems and appliances (hse.gov.uk) Gas Safety (Installation and Use) Regulations (Northern Ireland) 2004	Competent engineer on the Gas Safe Register.	Routine maintenance in accordance with manufacturer's recommendations. Inspections in accordance with written maintenance strategy.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	ODS Air-Conditioning
APM Object	CT.HVAC.ODS
APM Description	All stationary refrigeration, air-conditioning, heat-pump (RAC) or fire protection equipment, fire extinguishers that contain ozone-depleting substances. HV switchgear may also contain such substances such as SF
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.RTU HVAC.CU HVAC.CHILL	**Related CT Areas:**	CT.HVAC.FGAS		

Scope

Any site with air conditioning systems containing Ozone-Depleting Substances (ODS), where the fluid charge of controlled substances is greater than 3 kg.
Cooling units containing Fluorinated Gas are outlined in Compliance Standard CT.HVAC.FGAS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance of equipment containing ODS.	Competent person.	Maintenance logbook	PM					EVID		
All	2	At least every 12 months.	Statutory requirement for leak inspection of all ODS containing equipment with a fluid charge of 3 to 30 kg, with the exemption of hermetically sealed systems (labelled) that contain <6 kg of controlled substances. Best practice to include units <3 kg.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.						CT*		
All	3	At least every 6 months.	Statutory requirement for leak inspection of all ODS containing equipment with a fluid charge of 30 to 300 kg.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.					CT			
All	4	At least every 3 months.	Statutory requirement for leak inspection of all ODS containing equipment with a fluid charge of more than 300 kg.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.						CT		
All	5	As soon as possible, but not later than 14 days from detection.	Repair of any leakage detected during inspections	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.								One off EVID

All	6	Within 1 month	In the event that a leak is identified and fixed. Reinspection is required.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.									One off EVID
PL	7	Every 12 months without leak detection system or every 24 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 10 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".								CT*	

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation (EC) No 1005/2009 of the European Parliament and of the Council of 16 September 2009 on substances that deplete the ozone layer Act No. 73/2012 Coll., on substances depleting the ozone layer and F-gases (§4) Regulation No. 257/2012 Coll., on preventing ODS a F-gases emissions	Competent person, certified by the relevant body	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge. Units with more than 300 kg of fluid charge must have been fitted a leakage detection system, the system must be inspected by a competent person (operator) every 12 months at least.
DE	Verordnung (EG) Nr. 1005/2009 Chemikalien-Ozonschichtverordnung (ChemOzonSchichtV) § 4	Competent Person (befähigte Person)	Regular tightness checks as follows: Equipment without hermetically sealed systems, with fluid charge of 3 kg or more, at least every 12 months. Equipment with fluid charge of 30 kg or more, at least every 6 months. Equipment with fluid charge of 300 kg or more, at least every 3 months. Tightness must be re-checked 1 month after any leakage repairs have been conducted.
ES	Regulation EC/1005/2009 of the European Parliament and of the Council of September 2009 on substances that deplete the ozone layer.	Competent person, certified by the relevant body	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charg
FR	No additional requirements	N/A	No additional requirements
IT	Regulation 1005/09/EU	N/A	With some special exceptions (critical uses, laboratory uses, process agents and raw materials) described in Regulation 1005/2009/EU, the production, placing on the market and use of all controlled ODS, new ODS and products and equipment containing or relying on such substances are prohibited in the European Community.
PL	Regulation EC/1005/2009 of the European Parliament and of the Council of September 2009 on substances that deplete the ozone layer. Act of 15 May 2015 on substances that deplete the ozone layer and on certain fluorinated greenhouse gases (Journal of Laws 2020, item 2065) Act of 29 August 2014 on the energy performance of buildings (Journal of Laws 2021, item 497) Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333)	Competent person, certified by the relevant body.	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge. Tightness must be re-checked 1 month after any leakage repairs have been conducted.
ROI	Regulation (EC) No 1005/2009 of the European Parliament and of the Council of 16 September 2009 on substances that deplete the ozone layer (europa.eu) (as amended)	Competent person, certified by the relevant body.	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge.
SK	Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Act. No. 321/2012 Coll. on the Protection of the Earth's Ozone Layer and on Amendments to Certain Acts	Qualified and certified person.	Inspection is realized upon request from the side of the state authority. Otherwise, the minimum inspection period is 5 years.

UK	Regulation (EC) No 1005/2009 of the European Parliament and of the Council of 16 September 2009 on substances that deplete the ozone layer (as amended) The Ozone-Depleting Substances Regulations 2015 The Environmental Protection (Controls on Ozone-Depleting Substances) Regulations 2011 The Controls on Ozone-Depleting Substances Regulations (Northern Ireland) 2011	Competent person with the appropriate certification (eg. City & Guilds, CITB).	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Lifting Accessories
APM Object	CT.LIFT.ACCESSORIES
APM Description	Lifting accessories (e.g. chains, ropes, shackles, slings/straps, etc.)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Lifting Equipment	**Related CT Areas:**	Not Specified		

Scope

Any site where lifting accessories are used as part of lifting equipment.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of the equipment (lubrication, parts replacement, etc.).	Competent, trained person.	Inspection and maintenance records, reports or certificates. Risk assessment Register of lifting equipment.	PM							
All	2	Once assembled, before first use	Acceptance inspection before it is first used.	Independent, accredited or authorised to undertake the inspection.	Inspection and maintenance records, reports or certificates. Risk assessment Register of lifting equipment.								CT
All	3	Based on risk assessment, but at least every 6 months. More frequent inspections might be conducted based on site and environmental conditions.	Regular thorough inspection of safety-critical parts to ensure safe use. If defects are identified, prevent subsequent use through quarantine prior repair or disposal and replacement - do Not use. Report issue	Independent, accredited or authorised to undertake the inspection.	Inspection and maintenance records, reports or certificates. Risk assessment Register of lifting equipment.					CT			
DE	4	Thorough inspection at least every 3 years	Round steel chains used as slings must be subjected to an additional special inspection for cracks	Competent person (befähigte Person)	No additional requirements								3Y CT
DE	5	Thorough inspection at least every 3 years	Lifting straps/slings with vulcanized-on coating must be inspected for wire breaks and corrosion	Competent person (befähigte Person)	No additional requirements								3Y CT

FR	8	Inspections before it is first used and at least every 6 or 12 months.	6 months: - tail lifts; - furniture lifts; - construction hoists; - earthmoving equipment equipped for lifting; - self-propelled or carrier vehicle mounted mobile cranes, not requiring assembly or disassembly of major parts;	Qualified person	Maintenance logbook				CT				
IT	7	Inspections at least every 3 months	Inspections as per [3].	No additional requirements	CE Declaration of Conformity. Records to be kept for at least 3 years.				CT				
SK	6	Every month in metallurgical plants and aggressive environments. Every 3 months in other operations, including in outdoor areas. Every 6 months when rarely used.	The binding system and its components must be checked more regularly depending on the task/industry.	No additional requirements	No additional requirements				CT				

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	ČSN 270142 ČSN 9927-1 ČSN 12482-1, 19/79; ČSN EN 1492-1 + A1, ČSN EN 1492-2 + A1 ČSN 4309 ČSN 8792 (steel ropes)	Competent person. Lift equipment technician.	Checks on steel ropes carried out every 6 months. Checks on chains, links and hinges carried out at least every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: DGUV Regel 100-500 Kap. 2.8 Betreiben von Lastaufnahmeeinrichtungen im Hebezeugbetrieb DGUV Regel 109-017 - Betreiben von Lastaufnahmemitteln und Anschlagmitteln im Hebezeugbetrieb TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Regel 109-004 Rundstahlketten als Anschlagmittel in Feuerverzinkereien DGUV Regel 109-005 Gebrauch von Anschlag-Drahtseilen DGUV Regel 109-006 Gebrauch von Anschlag-Faserseilen	Competent person (befähigte Person).	Inspection before its first use and at least every 12 months.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. UNE-EN 818: 2008 Standard (7 PARTS) Chain slings. Prevention Technical Note 861 (Sling chanins). Prevention Technical Note 824 (equipment for lifting goods).	Competent person.	Maintenance and inspection frequency depend on the use of equipment and the service conditions. Daily inspections on slings and a thorough inspection every 12 months (recommendation according to NTP861).
FR	Art. 1 à 7 Decree of 29th December 2010 "Arrêté du 29 décembre 2010 relatif aux vérifications générales périodiques portant sur les ascenseurs et les monte-charges ainsi que sur les élévateurs de personnes n'excédant pas une vitesse de 0,15 m/s, installés à demeure, et modifiant l'arrêté du 1er mars 2004 modifié relatif aux vérifications des appareils et accessoires de levage" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023386810/ 21. january 2011 decision 1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified)	Qualified person	Inspections before it is first used and at least every 6 or 12 months. (6 months: - tail lifts; - furniture lifts; - construction hoists; - earthmoving equipment equipped for lifting; - self-propelled or carrier vehicle mounted mobile cranes, not requiring assembly or disassembly of major parts; - fork-lift trucks; - pipelaying tractors;
IT	UNI EN 818:2008 (Short link chains for lifting) UNI ISO 4309:2019 (Ropes: care, maintenance, inspection and waste) UNI EN 1492:2009 (Fabric slings) UNI EN 1677:2009 (Sling's components) UNI EN 13001:2018 (Lifting equipment) UNI EN 13155:2021 (Removable load carrying equipment) UNI EN 13411:2009 (Steel rope ends) UNI EN 13414:2009 (Steel rope slings) UNI EN 13889:2009 (Lifting shackels) UNI EN ISO 3266:2016 (Lifting eyelets)	Competent, authorised person.	Regular maintenance in accordance with manufacturer's instructions. Inspection at least every 3 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Minister of Development of 3 June 2016 on the requirements for lifts and safety components for lifts (Journal of Laws 2016, item 811) Regulation of the Minister of Infrastructure of 12 April 2002 on on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	Competent person. UDT technical inspection, government body.	Inspection according to manufacturer's instructions or internal procedures, but at least once every 12 months. Some accessories must be inspected more regularly depending on the conditions and task.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 232/2017 - European Union (Lifts and Safety Components for Lifts) Regulations 2017. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months. Planned maintenance programme in place.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN EN 27 0142: Cranes and hoists. Testing	Competent person, best practice to outsource to specialist company.	Inspection before its first use, and at least every 12 months. Technical inspection of chains every 12 months and technical examination (testing) every 24 months. GENERAL: Inspections in accordance with manufacturer's instructions.

UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource. Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before it is first used and every 6 months. Planned maintenance programme in place.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Escalator
APM Object	CT.LIFT.ESCALATOR
APM Description	Escalators.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

Any site where escalators are operated (moving staircase for people).
Passenger lifts are covered under Compliance Standard CT.LIFT.PASSENGER and goods lifts are covered under Compliance Standard CT.LIFT.GOODS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	- tail lifts;	Competent person.	Maintenance logbook Declaration of Conformity (upon purchase) - retain for as long as the escalator is in service.								
All	2	Inspection frequency based on risk assessment, but at least every 6 months.	- furniture lifts;	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records, report or certificates. Risk assessment					CT			
CZ	3	Inspections conducted every 3 months. Testing conducted every 3 years. Accredited inspections every 6 years.	- construction hoists;	No additional requirements	Protokol o urceni vnejsich vlivu						CT		3, 6 Year
DE	7	Inspection prior to first use as per BetrSichV, DGUV Information 208-028 and DIN EN 115-1:2018-01.	- fork-lift trucks;	No additional requirements	No additional requirements								
PL	4	Technical maintenance of elevators to be conducted at least every month.	- earthmoving equipment equipped for lifting;	No additional requirements	No additional requirements			CT					

ROI	6	No additional requirements	disassembly of major parts;	No additional requirements	Keep inspection records for at least 5 years. Register of lifting equipment					(CT)			
SK	5	Professional inspections at least every 3 months. Professional examination every 3 years.	- self-propelled or carrier vehicle mounted mobile cranes, not requiring assembly or	No additional requirements	No additional requirements						CT		3 Year

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 EN 81-1 EN 81-2 ČSN 274007- ČSN 274002 EN 81 - 80	Competent person. Lift equipment technician.	Inspections before first use and at regular intervals of at least 3 months. Equipment testing every 3 years. Accredited inspections every 6 years.
DE	DIN EN 115-1:2018-01 Section 7.3.1- Sicherheit von Fahrtreppen und Fahrsteigen DGUV 208-028 - Fahrtreppen und Fahrsteige; Teil 1: Sicherer Betrieb BetrSichV §3 VdTÜV Merkblatt 1504 "Grundsätze für die Prüfung von Fahrtreppen und Fahrsteigen Technische Regeln für Arbeitsstätten: ASR A1.8 – Verkehrswege	Accredited inspection body or competent person (befähigte Person)	Inspection before first use and after significant changes (DIN EN 115-1) by an accredited inspection (ZÜS) such as TÜV, DEKRA, etc or a competent person (befähigte Person). Regular recurrent inspection to be determined by risk assessment. Annual basis is common
ES	RD 2291/1985, approving regulation for lifting machines and their maintenance. RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. EN-115. Safety in escalators and mobile platforms. ISO 14798:2009. Lifts (elevators), escalators and moving walks - Risk assessment and reduction methodology.	Competent person.	Technical maintenance at least every month. Inspections at least every 12 months
IT	UNI EN 115:2017 (Safety requirements) Directive 2006/42/CE on machinery UNI EN 13015:2008 (Maintenance) Decree 22/12/17	Competent person.	Technical maintenance at least every month. Inspections at least every 12 months
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	UDT technical inspection, government body.	Technical maintenance at least every month. Inspections at least every 12 months
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Regular inspections conducted at least every 6 months.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN 27 4802: Escalators. Assembly, tests, operation, maintenance and repairs	Competent person, best practice to outsource to specialist engineer.	Professional inspections to be conducted every 3 months. Professional examination at least every 3 years. Repeated official test every 10 years.
UK	The Provision and Use of Work Equipment Regulations 1998 The Workplace (Health, Safety and Welfare) Regulations 1992 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Regular planned maintenance in accordance with manufacturer's recommendations. Thorough inspections at least every 6 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Goods lift
APM Object	CT.LIFT.GOODS
APM Description	Goods lifts.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LIFTS.GOODS	**Related CT Areas:**	Not Specified		

Scope

Any site which uses goods lifts to transfer loads in working environments (e.g. between different levels).
This only applies to lifts used to transport goods e.g. service lift, gantry cranes and heavy lifting equipment etc. For passenger lifts refer to Compliance Standard CT.LIFT.PASSENGER

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	- pipelaying tractors;	Competent person.	Maintenance records	PM					EVID		
All	2	Once assembled, before it is first used.	- mobile elevating work platforms.)	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records. Retain until employer ceases to use equipment.								ON off EVID
All	3	At least every 12 months. More frequent examinations might be conducted based on site specific risk assessment.	Regular thorough (technical) examination of safety-critical parts to ensure safe use. This includes lifting (e.g. ropes, chains) and non-lifting (e.g. electrical devices, safety gear, load detectors) parts of the equipment. If defects identified, prevent subsequent use through quarantine prior to repair or disposal and replacement - do Not use. Report issue.	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records, reports or certificate. Retain until next report is made. Risk assessment Marking, e.g. inspection test sticker to be placed inside elevator/permit for use	(PM)					EVID		
CZ	4	Inspection every 6 months. Equipment testing every 6 years.	No additional requirements	Independent, accredited or authorised to undertake inspections.	Inspection records	(PM)					EVID		
FR	6	No additional requirements	No additional requirements	No additional requirements	Security register								NAR

IT	5	Thorough inspection of safety critical lifting components every 3 months (visual testing and cleaning).	No additional requirements	Independent, accredited or authorised to undertake inspections.	Inspection records. CE Declaration of Conformity.	(PM)					EVID		
ROI	7	Regular inspections every 6 months.	No additional requirements	No additional requirements	Inspection and maintenance records	(PM)					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 Government Regulation No. 378/2001 Coll., EN 81-1 EN 81-2 ČSN 274007 – ČSN 274002 EN 81 - 80	Competent person. Lift equipment technician.	Inspections carried out every 6 months. Testing undertaken every 6 years.
DE	BetrSichV – Betriebsicherheitsverordnung, §3, §15 & §16 and Annex 2 Section 2 Technische Regeln für Betriebssicherheit: TRBS 1201 Teil 4 - Prüfung von überwachungsbedürftigen Anlagen - Prüfung von Aufzugsanlagen TRBS 3121 - Betrieb von Aufzugsanlagen	Accredited inspection bodies (zugelassenen Überwachungsstellen) according to BetrSichV	Inspection before first use, after changes subject to inception and recurrent inspections. Recurrent inspections include main inspection (every 2 years) and intermediate inspection (between the main inspection) PPM in place.
ES	RD 2291/1985, approving regulation for lifting machines and their maintenance. RD 1314/1997, pronouncing about the applicable regulation related to European Parliament Directive 95/16/CE, aboutlifts. RD 88/2013, approving the Complementary Technical Instruction AEM 1 "Lifts". RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD 203/2016, establishing essential safety requirements for the commercialisation of lifts and their security components.	Competent person.	Maintenance according to manufacturer's instructions. Inspection frequency depends on operating conditions.
FR	Art. 1 à 7 Decree of 29th December 2010 "Arrêté du 29 décembre 2010 relatif aux vérifications générales périodiques portant sur les ascenseurs et les monte-charges ainsi que sur les élévateurs de personnes n'excédant pas une vitesse de 0,15 m/s, installés à demeure, et modifiant l'arrêté du 1er mars 2004 modifié relatif aux vérifications des appareils et accessoires de levage" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023386810/ 21. january 2011 decision 1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified)	Qualified person	Inspections at least every 12 months.
IT	D.Lgs 81/2008, annex VI, p.to 3.1.2 DM 11/04/2011 CEI EN 60947-5-1:2019 (Control circuits) CEI EN 60529:2009 (Protection degrees of enclosures) UNI EN 12159:2013 (Constructions lift) UNI EN 81-20:2020 (Safety requirements for the construction and installation of lifts) UNI EN 294:1993 (Safety requirements) UNI EN 953:2009 (Safety requirements - General requirements for the design and construction of fixed and mobile shelters) UNI EN 349:2008 (Safety requirements- Minimum spaces to avoid crushing body parts)	Competent person, outsource to specialist company.	Regular maintenance as per manufacturer's instructions. Inspection of lifting components (slings, ropes) every 3 months. Periodic inspection every 12 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Minister of Development of 3 June 2016 on the requirements for lifts and safety components for lifts (Journal of Laws 2016, item 811) Regulation of the Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	UDT technical inspection, government body.	Inspections at least every 12 months
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 426/1981 - Safety in Industry (Vehicle Lifting Tables and Other Lifting Machines) (Register of Examinations) Regulations, 1981. (irishstatutebook.ie) S.I. No. 232/2017 - European Union (Lifts and Safety Components for Lifts) Regulations 2017. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months. Planned maintenance programme in place
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment	Competent person, outsource to specialist company.	Professional inspections of goods lifts to be conducted at least every 6 months. Professional examination at least every 6 years. Repeated official test by Technical Inspection (or any other authorized legal entity) every 10 years.

UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before first use and every 12 months. PPM must be in place.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Hoists
APM Object	CT.LIFT.HOIST
APM Description	Hoists.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	BLDG.CRANES	**Related CT Areas:**	Not Specified		

Scope

Any site where engine hoists and other types of hoists are used to move, install or remove heavy loads.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of the equipment (lubrication, parts replacement, etc.).	Competent person	Inspection records, reports or certificates. Risk assessment Marking, e.g. inspection test sticker to be placed on equipment/permit for use	PM					EVID		
All	3	Based on risk assessment, but at least every 6 months. More frequent inspections might be conducted based on site and environmental conditions.	Regular thorough inspection of safety-critical parts and operation to ensure safe use. This include lifting (e.g. chain, slings) and non-lifting (e.g. brakes, lights, fall-over protection) parts of the equipment If defects are identified, prevent subsequent use through quarantine prior to repair or disposal and replacement - do Not use. Report issue	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records, reports or certificates. Risk assessment Marking, e.g. inspection test sticker to be placed on equipment/permit for use					CT			
CZ	4	Every 6 to 60 months, depending on the electrical environment.	Inspection of electrical components	Certified electrician	No additional requirements	PM					EVID		
CZ	5	Once a year	Inspection of other components	As [2], [3]	No additional requirements	PM					EVID		
FR	6	Thorough inspections of engine hoists every 3 to 6 months and annually	No additional requirements	Competent, trained person	Maintenance logbook Security register					CT			

IT	7	Thorough inspections at least every 3 months, unless risk assessment identifies further inspection requirements.	No additional requirements	External competent person	CE Declaration of Conformity. Inspection records to be kept for 3 years.				CT				

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Government Regulation No. 378/2001 Coll., Decree No. 73/2010 Coll., ČSN 331500	Competent person. H&S specialist / electrician.	Inspections carried out every 12 months. Electrical parts every 6-60 months.
DE	Technische Regeln für Betriebssicherheit: DGUV Vorschrift 52 - Krane DGUV Grundsatz 309-001 - Prüfung von Kranen DGUV Grundsatz 309-008 Hinweise für die Prüfung von Winden, Hub- und Zuggeräten	Competent person (befähigte Person) according to DGUV 309-001.	Inspection before its first use if cranes are not delivered ready for operation, after any major modifications, and at least every 12 months. Electrical parts as part of hoists every 6-60 months. Power-operated wire rope and chain hoists for lifting loads as well as power-operated crane hoists must be inspected at least every 48 months, with exceptional case requirements outlined in §27 4 & 5.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. NTP 78. Hands-operated pulley blocks.	Competent person.	Maintenance according to manufacturer's instructions. Inspection frequency depends on operating conditions.
FR	Art. 1 à 7 Decree of 29th December 2010 "Arrêté du 29 décembre 2010 relatif aux vérifications générales périodiques portant sur les ascenseurs et les monte-charges ainsi que sur les élévateurs de personnes n'excédant pas une vitesse de 0,15 m/s, installés à demeure, et modifiant l'arrêté du 1er mars 2004 modifié relatif aux vérifications des appareils et accessoires de levage" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023386810/ 21. january 2011 decision 1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified)	Qualified person	Annual inspections for all hoists. Additional Inspections once the equipment is back in service and every 3 to 6 months for engine hoists
IT	D.Lgs 81/2008, annex VI, p.to 3.1.2 DM 11/04/2011 UNI EN 12644:2008 (Use and testing) UNI EN 12077:2008 (Safety requirements) UNI EN 13557:2008 (Controls) UNI EN 13135:2018 (Safety requirements) UNI EN 14492:2009 (Hoists) UNI ISO 9927:2016 (Inspections) UNI ISO 23814:2012 (Requirements for inspectors) UNI ISO 4306:2010 (Lifting equipment - Vocabulary)	Competent, authorised person.	Regular maintenance in accordance with manufacturer's instructions. Inspection at least every 3 monthsfor lifting components. Periodic inspection every 12 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Council of Ministers of 7 December 2012 on the types of technical devices subject to technical inspection (Journal of Laws 2012, 1468)	UDT technical inspection, government body.	Inspections of engine hoists every 2 years and other hoists every 3 years. Accessories must be checked more regularly depending on the conditions/task.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 426/1981 - Safety in Industry (Vehicle Lifting Tables and Other Lifting Machines) (Register of Examinations) Regulations, 1981. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months. Planned maintenance programme in place.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN EN 27 0142: Cranes and hoists. Testing	Competent person, best practice to outsource to specialist company.	Inspections in accordance with manufacturer's instructions.
UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before it is first used and at least every 12 months. Planned maintenance programme in place.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Passenger lifts
APM Object	CT.LIFT.PASSENGER
APM Description	Passenger (people)carrying lifts.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Passenger lifts	**Related CT Areas:**	Not Specified		

Scope

Any site with passenger carrying lifts.
Goods lifts are covered under Compliance Standard CT.LIFT.GOODS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Planned regular maintenance of the equipment (lubrication, parts replacement, etc.).	Competent person.	Register of lifting equipment, inspection and maintenance records, report or certificates. Risk assessment	PM					EVID		
All	2	Once assembled, before it is first used.	Installation inspection – upon first assembly	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Register of lifting equipment, inspection and maintenance records, report or certificates. Risk assessment								One Time
All	3	Inspection frequency based on risk assessment, but at least every 6 months.	Professional thorough inspection of safety-critical parts to ensure safe use. This includes lifting parts (e.g. chains, slings) and non-lifting parts (electrical devices, brakes, lights, detectors) of the lift. If defects are identified, prevent subsequent use through quarantine prior repair or disposal and replacement - do Not use. Report issue	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Register of lifting equipment, inspection and maintenance records, report or certificates. Risk assessment	PM					EVID		
CZ	5	Internal checks on passenger lifts are carried out every 14 days. Professional inspections of passenger carrying lifts to be conducted at least every 4 months (if no public access). Every 3 years - professional	Check the "Protokol o urceni vnejsich vlivu", which defines the environmental conditions, use and maintenance requirements of electrical equipment.	No additional requirements	"Protokol o urceni vnejsich vlivů" Inspection records, report or certificates. Risk assessment	(PM)					EVID		4Mo CT 3Yr CT 6Yr CT 9YR CT
FR	8	6 weeks	Inspections as per [1].	Independent, accredited or authorised to undertake the inspection and maintenance or competent, trained person.	Maintenance logbook and Security register Inspection report	(PM)					EVID		

FR	9	6 months	Inspections as per [3].: Brakes, cables or chain, anti-drift device	Accredited company	Maintenance logbook and Security register Inspection report	(PM)				CT	EVID		
FR	10	12 months	Inspections as per [3].: bowl, cab roof, machinery, pulley, speed limiter, parachute, means of protection against uncontrolled movements, safety out-of-travel devices, hand pump, manually operated drop valve	Accredited company	Maintenance logbook and Security register Inspection report	(PM)					CT EVID		
FR	11	5 years	Technical exam on full equipment	Accredited company	Maintenance logbook and Security register Inspection report								5 Yr CT
IT	12	No additional requirements	No additional requirements.	No additional requirements	CE Declaration of Conformity.								NAR
PL	6	Technical maintenance of elevators to be conducted at least every month.	Inspections as per [3].	No additional requirements	Book of revision and maintenance logbook.	(PM)					EVID		
SK	7	Internal inspections passenger carrying lifts to be conducted weekly. Professional inspections of passenger carrying lifts to be conducted at least every 3 months. Professional examination at least	Inspections as per [3].	No additional requirements	Inspection records, report or certificates. Risk assessment	(PM)					EVID		
UK	4	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme.	(PM)							

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 ČSN EN 81-1 ČSN EN 81-2 ČSN EN 274007 ČSN EN 274002 ČSN EN 81 – 80	Competent person, outsource to specialist company.	Maintenance every week. Professional inspection every 4 months (if no public access), and examination every 3 years. Official test every 6 years (after lift has been installed for 9 years).
DE	BetrSichV – Betriebssicherheitsverordnung, §3, §15 & §16 and Annex 2 Section 2 Technische Regeln für Betriebssicherheit: TRBS 1201 Teil 4 - Prüfung von überwachungsbedürftigen Anlagen - Prüfung von Aufzugsanlagen TRBS 3121 - Betrieb von Aufzugsanlagen	Accredited inspection bodies (zugelassener Überwachungsstelle – ZÜS) according to BetrSichV	Before its first use, after Recommissioning, and main periodic inspections (including electrical parts) at least every 2 years. Intermediate inspections must be carried out in the time between the main inspections. PPM in place.
ES	RD 2291/1985, por el que se aprueba el Reglamento de Aparatos de Elevación y Manutención de los mismos. RD 1314/1997, por el que se dictan las disposiciones de aplicación de la Directiva del Parlamento Europeo y del Consejo 95/16/CE, sobre ascensores. RD 57/2005, por el que se establecen prescripciones para el incremento de la seguridad del parque de ascensores existente. RD 1644/2008, por el que se establecen las normas para la comercialización y puesta en servicio de las máquinas. RD 88/2013, por el que se aprueba la Instrucción Técnica Complementaria AEM 1 “Ascensores”. RD 203/2016, por el que se establecen los requisitos esenciales de seguridad para la comercialización	Accredited company by ENAC (Entidad Nacional de Acreditación)	Maintenance of all lifting equipment at least monthly. Inspections carried out: - every 24 months in industries and publicly used buildings. - every 48 months in dwelling buildings withs more than 20 apartments or more than 4 floors. - every 72 months in other cases.
FR	Ministerial Order 18 November 2004 to lifting equipment maintenance "Arrêté du 18 novembre 2004 relatif à l’entretine des installations d’ascenseurs” https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000254219/ Construction Code Article R125-1 relating to Lifting equipment periodic technical exam “Code de la construction article R125-2-4 relatif à l’entretien at au contrôle technique des ascenseurs” https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000032499015/ Labour Code Art. R. 4323-22 à R. 4323-28 relating to the periodic verification of work equipment. “Code du travail Article R4323-22 à R4323-28 relatifs à la vérification périodique des équipements de travail” https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489757/#L	Qualified person Accredited company	Maintenance of all lifting equipment at least every 6 weeks Inspections at least every 6 months and 12 months. Technical exam every 5 years.
IT	D.Lgs 81/2008, annex VI, p.to 3.1.2 DM 11/04/2011 Presidential Decree of 10 January 2017, n. 23 - Regulation laying down the provisions on the implementation of Directive 2014/33/EU concerning lifts UNI 10411:2014 (Modifications to electric lifts not in conformity with Directive 95/16/EC) UNI EN 81-80:2019 (Safety requirements - methodology for improving the safety of existing lifts) UNI EN 14502-1:2010 (Cradles) EC 1-2010 UNI EN 14502-2:2008 (People lifting equipment) UNI EN 81-43:2009 (Lifters for cranes) UNI EN 81-50:2020 (Safety requirements - Checks and tests)	Competent person, outsource to specialist company.	Regular maintenance according to manufacturer’s instructions. Inspection every 24 months (verification). Inspection of lifting components (ropes, slings) every 3 months.

PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Minister of Development of 3 June 2016 on the requirements for lifts and safety components for lifts (Journal of Laws 2016, item 811)	UDT technical inspection, government body.	Maintenance at least every month. Inspections at least every 12 months. It includes escalators.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 426/1981 - Safety in Industry (Vehicle Lifting Tables and Other Lifting Machines) (Register of Examinations) Regulations, 1981. (irishstatutebook.ie) S.I. No. 232/2017 - European Union (Lifts and Safety Components for Lifts) Regulations 2017. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN EN 27 4002: Lifts. Installation, testing and operation of electric lifts	Competent person, outsource to specialist company.	Weekly check recommended by STN 27 4002. Professional inspection every 3 months, and professional examination every 3 years. Repeated official test every 6 years.
UK	The Lifting Operations and Lifting Equipment Regulations 1998 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before first use and at least every 6 months. PPM in place. Escalators must be thoroughly inspected every 6 months. Written Scheme of Examination required for each asset.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Vacuum
APM Object	CT.LIFT.VACUUM
APM Description	Vacuum lifting equipment.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site that uses vacuum lifting equipment to transport heavy loads. If they vacuum lifting machine is permanently attached to a crane or other lifting equipment it should be thoroughly examined as an integral part of such equipment. In any other instance, it is considered to be a lifting accessory.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Regular maintenance	Based on risk assessment and/or manufacturer's instructions.	Competent, trained specialist.	Inspection records, reports or certificates. Risk assessment						CT		
All	2	Installation inspection - upon first assembly, or when has been moved and reconstructed	Once assembled, before it is first used	Competent, trained specialist.	Inspection records, reports or certificates. Risk assessment								As Needed EVID
All	3	Regular thorough inspection of safety-critical parts to ensure safe use, including the structure, connections, damage, pipes/hoses, motor and pump, controls, lights, etc. If defects are identified, prevent subsequent use through	At least every 12 months IF the vacuum machine is permanently attached to a crane/lifting equipment. More frequent inspections might be conducted based on use, environmental conditions and site-specific risk assessment. At least every 6 months if the vacuum machine is not permanently attached to a crane/lifting equipment, and therefore considered a lifting accessory	Competent, trained specialist.	Inspection records, reports or certificates. Risk assessment						CT		
IT	4	Every 3 months if the vacuum machine is considered a lifting accessory, every 12 months if attached to a crane/lifting equipment.	No additional requirements.	No additional requirements	CE Declaration of Conformity.			CT*			CT*		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	ČSN EN 13155	Competent person, according to the relevant instructions for the device	Inspection before first use and at least every 12 months.
DE	DIN EN 13155:2009-08 BetrSichV, §3 DGUV Regel 100-500 Betreiben von Arbeitsmitteln, Section 2.8 DGUV Regel 109-017 - Betreiben von Lastaufnahmemitteln und Anschlagmitteln im Hebezeugbetrieb	Expert (zur Prüfung befähigte Person) according to DGUV Regel 109-017	Inspection before first use and recommissioning, and at least every 12 months.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment.	Competent person.	Maintenance according to manufacturer's instructions. Inspection frequency depends on operating conditions.
FR	N/A	N/A	N/A
IT	If used individually: D.Lgs 81/08 Directive 2006/42/EU on machinery UNI EN 13155:2021 (Removable load carrying equipment) UNI EN ISO 9712:2012 (Non-destructive testing) UNI ISO 23815:2011 (Maintenance) UNI EN 14238:2009 (Manually controlled load handling devices) If permanently attached to a lifting equipment: D.Lgs 81/08 Directive 2006/42/EU on machinery	Competent person	Inspection every 12 months. Inspection of lifting components every 3 months.
PL	Regulation of the Minister of Economy of October 21 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228)	N/A	N/A
ROI	N/A	N/A	N/A
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment	Competent person, outsource to specialist company.	Inspections in accordance with manufacturer's instructions.
UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource. Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before first use and at least every 12 months. Planned maintenance programme in place.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Pressure systems
APM Object	CT.PRESSURE.SYS
APM Description	Pressure systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	COMPR - HVAC.CHILL - HVAC.HS - HVAC.HTR - FIRE.SUP - FIRE.SUP.PUMP.JP - HVAC.CU - WTR.SUPPLY	**Related CT Areas:**	Not Specified		

Scope

Any site that operates pressure systems and vessels, such as boilers, condensers, heating and air conditioning devices (vapor compressing), etc associated pipework in which a breach may give rise to danger, primary shut off valves and protective devices. Typically, equipment with steam at any pressure, gases which exert a pressure in excess of 0.5 bar above atmospheric pressure and fluids which may be mixtures of liquids, gases and vapours where the gas or vapour phase may exert a pressure in excess of 0.5 bar above atmospheric pressure.
Inspection requirements for boilers are covered in CT.HVAC.BOILERS.
Note this standard excludes hired plant e.g. mobile compressors as some responsibilities will fall to the provider.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all air compression systems (topping up fluids, filters, etc.)	Competent person, generally sourced internally.	Maintenance logbook.	PM					EVID		
All	2	Before the pressure system is first put into service.	Initial assessment to identify all pressure systems, verify conformity (CE Marking), the risk associated with them, and any examination identified in risk assessment/written scheme of control.	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate								One off EVID
All	3	Based on risk assessment and manufacturer's instructions, but at least every 12 months.	Examination of air steam boilers, associated pipework and protective devices and steam heating devices of more than 100°C	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate						CT		
All	4	Based on risk assessment, but at least every 12 months.	Inspection and servicing of all air compression systems.	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate	(PM)					(EVID)		
All	5	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of air receivers and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres.	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	

All	6	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of refrigeration and air conditioning systems (vapor compression) where the installed power exceeds 25kW	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	
All	7	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of steam receiving plants	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	
All	8	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of other pressure systems (e.g. LPG storage systems to supply fuel)	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	
CZ	9	Every year	Operational inspections of all pressure equipment (items [2], [3], [4], [5] and [6]).	No additional requirements	Passport protocol of the vessel	(PM)					(EVID)		
ES	10	Every 2 - 12 years depending on Inspection type and Class of equipment	Operational inspections of all pressure equipment	Level A - installer company. Levels B and C - accredited external inspector	Inspection reports and repair records (where required)	(PM)					(EVID)		
IT	1	Usually every 10 years	Integrity verification	No additional requirements	No additional requirements								10Y CT
IT	13	Every 2, 3, 4 and 5 years depending on the categories of systems and fluids involved (see comment on Italy's section of table 2)	Functional inspection of all systems	No additional requirements	CE Declaration of Conformity	(PM)					(EVID)		
SK	11	Every 6 months to 15 years, depending on inspection type and pressure equipment type	Operational inspections of all pressure equipment	Competent and authorized person	Inspection reports and repair records (where required)	(PM)					(EVID)		
UK	12	No additional requirements	Inspections as per [2], [3], [4], [5] and [6].	No additional requirements	Written scheme of examination	(PM)					(EVID)	(CT)	(One off EVID)

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 18/1979 Coll. ČSN 69 0012 EN 286	Technician of specialized pressure equipment certified by the national authority	Initial assessment to identify all pressure systems and the risk associated with them. Air receivers and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres to be inspected every year to assess operation, 5 years to check internal condition and conduct a pressure test every 9 years or whenever the vessel has been opened. Air steam boilers associated pipework and protecting devices and steam heating devices of more than >100°C to be inspected every year to assess operation, 5 years to check internal condition and conduct a pressure test every 9 years. Refrigeration and air conditioning systems where the installed power exceeds 25kW to be inspected every year to assess operation, 5 years to check internal condition and conduct a pressure test every 9 years. Steam receiving plants at least every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen TRBS 1203 - Befähigte Personen	Competent person (befähigte Person) OR Approved inspection agency (ZÜS Zugelassene Überwachungsstelle) Depending on type of pressure device/system	Before first use and after modifications and in regular intervals subject to mandatory inspection. Regular and periodic inspection of pressure systems and vessels consists of outer inspection (äußeren Prüfung), inner inspection (innere Prüfung) and resistance inspection (Festigkeitsprüfung). Outer inspections at least every 1- 5years depending on type and specification of pressure device/system. Inner inspections at least every 3 -5 years depending on type and specification of pressure device/system. Inner inspections at least every 3 -5 years depending on type and specification of pressure device/system. Resistance / Strength inspections at least every 5 - 10 years depending on type and specification of pressure device/system.
ES	RD 2060/2008, approves the Equipment Regulation to pressure and its complementary technical instructions.	Level A inspection: installer company. Level B inspection: accredited company (OCA). Level C inspection: accredited company (OCA).	Categories I-2 and II-2: 4 years. Level A Inspection. 8 years. Level B Inspection. Categories I-1, II-1, III-2, and IV-2. 3 years. Level A Inspection. 6 years. Level B Inspection. 12 years. Level C Inspection. Categories III-1, IV-1. 2 years. Level A Inspection. 4 years. Level B Inspection.

FR	Labor Code - Ministerila Order of 20 november 2017 concerning pressure equipment. https://www.legifrance.gouv.fr/loda/id/JORFTEXT000036128632/	Competent and authorised person	Inspection of pressure heat and refrigeration systems every 2 years Vessels inspected every 2 years. Compressed air systems inspected before use then every 3 years (4 years for equipment inspected during the commissioning) Fluid pipes re-qualification every 6 years if toxic/very toxic gas Vessels re-qualification every 10 years
IT	Legislative Decree 25/02/2000 n.93 Legislative Decree 9/04/2008 n.81 Decree 11/04/2011 (Inspection criteria for equipment in annex vii of Legislative Decree 9/04/2008 n.81) Decree 1/12/2004 n. 329 Directive 2014/68/EU Directive 2014/29/EU UNI 11325-12:2018 (Maintenance)	Competent and accredited person (under UNI CEI EN ISO/IEC 17020:2012 in accordance with Decree 11/04/2011)	Equipment containing fluids of class 1 in accordance with Legislative Decree 25/02/2000 n.93: -Vessels of categories 3 and 4 and vessels containing unstable gases of categories 1 to 4: functional inspections every 2 years and integrity verification every 10 years -Vessels of categories 1 and 2: functional inspections every 4 years and integrity verification every 10 years -Pipework for gases, liquids and steams of categories 1, 2 and 3: functional inspections every 5 years and integrity verification every 10 years -Vessels for liquids of categories 1, 2 and 3: functional inspections every 5 years and integrity verification every 10 years Equipment containing fluids of class 2 in accordance with Legislative Decree 25/02/2000 n.93: -Vessels containing gases of categories 3 and 4 and vessels for water steam or heated water belonging to
PL	Regulation of the Minister of Economy, Labor and Social Policy of 9 July 2003 on technical conditions of technical inspection in the field of operation of certain pressure equipment (Journal of Laws 2003, number 135, item 1269) Act of 21 December 2000 on technical inspection (Journal of Laws 2021, number 272) Regulation of The Council of Ministers of 7 December 2012 on types of technical devices subject to technical inspection (Journal of Laws 2012, item 1468) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	Government Authority for the Technical Inspection (Polish UDT - Urząd Dozoru Technicznego)	
ROI	Safety, health and welfare at work (general application) amendment Regulations 2012 SCHEDULE 12 Part 10 Part B Regulations 191 and 192. The period for any particular piece of equipment maybe subject to change pursuant to the application of Regulation 191(3) S.I. No. 400/1999 - European Communities (Pressure Equipment) Regulations, 1999 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company or person, usually accredited under BS EN ISO/IEC 17020: 2004	Initial assessment to identify all pressure systems and the risk associated with them. Steam rand hot water boilers, water tube boilers, cast iron sectional boilers, superheaters and economisers, associated pipework, self-generating autoclaves, etc. to be inspected at least every 14 months. Air receivers, steam receivers, autoclaves, jacketed pans and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres to be inspected at least every 26 months. Refrigeration and air conditioning systems (vapor compression) where the installed power exceeds 25kW at least every 26 months. Other pressure systems (e.g. LPG storage systems) based on risk assessment. Generally, inspections every
SK	Act No. 17/2007 Coll. on the regular inspection of boilers, heating systems and air-conditioning systems and on the amendment of certain laws Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection when working with technical pressure, lifting, electric and gas equipment and laying down technical equipment which is considered to be the reserved technical equipment Ordinance No. 25/1984 Coll. on ensuring work safety in low-pressure boiler rooms	Competent and authorized person	Pressure vessels - repeated inspection of exterior: Annually Internal space inspection: 1x 5 years Pressure testing: 1x 10 years Steam and hot water boilers Repeated inspection of exterior and internal space: Annually Pressure testing: 1x 10 years Steam and hot water boiler rooms Inspection at least annually Gas atmospheric pressure systems Inspection: Annually
UK	The Pressure Systems Safety Regulations 2000 (legislation.gov.uk) Pressure Systems Safety Regulations (Northern Ireland) 2004 (legislation.gov.uk) Safety of pressure systems: Pressure Systems Safety Regulations 2000. Approved Code of Practice L122 (hse.gov.uk) The law - Pressure systems (hse.gov.uk)	Competent person, best practice to outsource to specialist company or person, usually accredited under BS EN ISO/IEC 17020: 2004	Initial assessment to identify all pressure systems and the risk associated with them. Employers are required to have a written scheme of examination with defined inspection periodicities, in accordance with the Safety Assessment Federation (SAFed): - Air receivers and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres at least every 26 months. - Air steam boilers, associated pipework and protecting devices and steam heating devices of more than >100oC at least every 14 months. - Refrigeration and air conditioning systems where the installed power exceeds 25kW at least every 48 months. - Steam receiving plants at least every 26 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Microwave ovens
APM Object	CT.RAD.MICROWAVES
APM Description	Microwave ovens
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where microwave ovens are used. This Compliance Standard does not cover the electrical inspections of microwaves, which are covered under "Portable Appliance Testing".

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance of equipment.	Competent person, usually sourced internally	Maintenance logbook.						CT		
All	2	Not statutory requirements, but can be checked during PAT examination	Regular inspections of radioactive leaks from microwave ovens.	Competent person	Inspection records, report or certificate. Risk assessment						CT		
FR	3	Every 12 months	Inspection as per [2].	Accredited company	No additional requirements						CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978 Coll.	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6and 60months.

DE	N/A	Competent person (befähigte Person)	Before the first use and after any modifications or alterations. Frequency of inspections in accordance with risk assessment, and manufacturer's recommendations and instructions.
ES	RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. Prevention Technical Note 234. Exposition to radiofrequencies and microwaves. Evaluation. RD 486/2010, of April 23, about health and safety on workers against risks related to the exposure of artificial optic radiations. RD 1644/2008, of October 10, which establishes regulation for the commercialization and commissioning of machines (annex I: 1.5.10 to 12).	Qualified expert according to RD 39/1997	Inspection frequency not stipulated, based on risk assessment according to RD486/2010 – art. 6.
FR	Labor Code R. 4453-6 to R. 4453-12 : Electromagnetic exposition – risk assessment https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018491265/	Accredited company	Electromagnetic waves exposition has to be assessed
IT	Legislative Decree 9.04.2008 n° 81 CEI EN 60335-2-25/A1/A2 (Safety requirements)	Competent person.	Inspection frequency not stipulated, based on risk assessment and manufacturer's instructions.
PL	Act of 29 November 2000 on Atomic Law (Journal of Laws 2021, item 623)	N/A	N/A
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Regular maintenance. Frequency of inspection not regulated, based on risk assessment.
SK	Ordinance No. 209/2016 Coll. on the minimum health and safety requirements for the protection of workers from the risks related to exposure to electromagnetic fields Ordinance No. 533/2007 Coll. on details of requirements for mass caterers	Qualified expert	Frequency of inspection not regulated, based at manufacturer recommendation
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk)	Competent person, usually a trained employee	Regular maintenance. Frequency of inspection not regulated, based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Rainwater pumping Stations
APM Object	CT.RAINWATERPUMP
APM Description	Pumping stations / pumps, in take filters, operation panels, telemetry/sensors and alarms.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Rainwater drainage Systems Waste water pumps (including pressure pipe system)	**Related CT Areas:**	Not Specified		

Scope

Any site where pumping stations are operated to pump rainwater into the surface water or combined drainage network or to the environment.
Drainage surveys and silt trap/interceptor maintenance are covered in separate standards (CT.ENVIRO.INTERCEPTOR)

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In line with manufacturers requirements but at least monthly.	Regular inspection and maintenance of pumps and clearance of any filters and telemetry/sensors to ensure correct operation. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person.	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	2	In line with manufacturers requirements but at least every 3 months	Regular maintenance (cleaning and testing) of other associated assets e.g. operational panel, alarms etc.	Competent person.	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	3	In line with drainage survey findings.	Regular flushing of the system to remove deposits.	Competent person.	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	4	As per PM maintenance unless stated in the Permit.	If pump is used to discharge surface water to a water course, a permit might be required or in place. The permit may determine the frequency of inspections and maintenance. Ensure current permit or discharge consent stored on Document Management System.	Competent person.	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)						Doc Check		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Water Act No. 254/2001 Coll., §5, §8	N/A	There are no special legal provisions for rainwater pumping stations, requirements could be set by the local authority or a manufacturer.
DE	Wasserhaushaltsgesetz (WHG) §60 DIN 1986 - Entwässerungsanlagen für Gebäude und Grundstücke DIN EN 12050-2 Abwasserhebeanlagen für die Gebäude- und Grundstücksentwässerung - Bau- und Prüfgrundsätze - Teil 2: Abwasserhebeanlagen für fäkalienfreies Abwasser entsprechen.	Competent person (befähigte Person).	Prior first use, the tightness of the facility has to be checked. Regular visual inspections of structural condition of the system. Monthly checks of the operational capability should be conducted by the operator, by observing at least two system cycles. Regular maintenance at least every 3 months. Regular flushing of the system at least every 2 years.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	No additional requirements Observe local site permit	N/A	No additional requirements
IT	UNI 10724:2004 (Rainwater disposal installations)	Competent person.	Maintenance in accordance with manufacturer's instructions. The periodicity of the maintenance activities is not set by Italian legislation.
PL	Act of 20 July 2017 on water law (Journal of Laws 2021, item 624) Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065) Act of 7 June 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028) Regulation of the Minister of Maritime Economy and Inland Navigation of 12 July 2019 on substances particularly harmful to the aquatic environment and the conditions to be met when discharging sewage into waters or soil, as well as when discharging rainwater or meltwater into waters or into devices aquatic (Journal od Laws 2019, item 1311)	N/A	N/A
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Based on risk assessment (use and environment) and manufacturer's recommendations.
SK	Act No. 124/2006 Coll. on safety and health at work	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment.
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person.	Based on risk assessment (use and environment) and manufacturer's recommendations.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Conveyors and machine guarding and e-stops
APM Object	CT.SAFE.CONVGUARDING
APM Description	Conveyors and machine guarding
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with conveyors and other machinery are required to ensure they are used safely, which may include the provision of guarding and/or emergency stops and interlocks.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance of all guarding, including hinges and slides, replacement of damaged or worn parts, lubrication, etc.	Competent person. Can be internally or externally sourced	Maintenance logbook						CT		
All	2	Based on risk assessment, but at least annually (it is assumed supervisors will check for unauthorised modifications more frequently)	Regular inspection and servicing of all guarding to ensure correct operation, including damage, unauthorised modification, missing or damaged fasteners, etc. to avoid unsafe conditions for employees	Competent person. Can be internally or externally sourced	CE Marking/ CE declaration of conformity Risk assessment Inspection records, report or certificate						CT		
All	3	Based on risk assessment and manufacturer's instructions, but at least monthly	Regular inspection and maintenance of interlocks and emergency stops.	Competent person. Can be internally or externally sourced	CE Marking/ CE declaration of conformity Risk assessment Inspection records, report or certificate			CT					
CZ	4	Between 6 - 36 months	Inspection and maintenance of equipment (depending on type and environment)	Competent person.	Inspection records						CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll. Decree No. 50/1978 Coll. ČSN 33 1600 ed.2.	Competent person, best practices for outsourcing to a specialist.	Inspection every 12 months. Inspection and maintenance of equipment (depending on type and environment) between 6 - 36 months
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen TRBS 1203 - Befähigte Personen DGUV 2018-018 - Stetigförderer	Competent person (befähigte Person) according to TRBS 1203	Before initial commissioning and after any modifications or repairs. Periodic inspection of conveyors and machine guarding based on risk assessment, but at least annually. Additional intermediate inspection in accordance with the operating conditions. Regular inspection of emergency stops in line with risk assessment.
ES	Directive 2006/42 / EC of the European Parliament and of the Council of 17 May 2006 on machines. RD 1644/2008, of October 10, which establishes the rules for marketing and commissioning of the machines. RD 1215/1997, of July 18, establishing minimum security provisions and Health for the use by workers of work equipment. RD 1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	Labor Code Art. R4322-1 to R4322-3 relating to Maintaining compliance Code du travail article R4322-1 à 3 relatifs au maintien en état de conformité https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489696/#LEGIARTI000018531541	Qualified person	Periodic inspection of conveyors and machine guarding based on risk assessment, but at least annually
IT	Legislative Decree 9.04.2008 n° 81 Directive 2006/42/CE on machinery	Competent person.	Regular inspections and maintenance in accordance with manufacturer's instructions and risk assessment.
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, number 169, item 1650) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228) Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Dz.U. 2008 nr 199 poz. 1228)	Qualified or competent person	Regular maintenance. Before initial commissioning and after any modifications or repairs. Periodic inspection of conveyors and machine guarding based on risk assessment, but at least annually. Regular inspections of emergency stops in accordance with manufacturer's instructions and risk assessment.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, trained to undertake the tasks	Regular maintenance. Frequent inspections of all guarding in line with risk assessment, but at least annually. Regular inspection and maintenance of e-stops and interlocks in line with risk assessment and manufacturer's instructions
SK	Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified and certified person	Electric installation of guardings: Annual inspection and testing Guardings: Annual inspection
UK	The Provision and Use of Work Equipment Regulations 1998 The Supply of Machinery (Safety) Regulations 2008 The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 PUWER White Paper ed1 v2.doc (machinesafety.co.uk) BS EN ISO 12100:2010 Safety of machinery. General principles for design. Risk assessment and risk reduction BS EN 953:1997+A1+2009 Safety of machinery. Guards. General requirements for the design and construction of fixed and movable guards *	Competent person, trained to undertake the tasks	Regular maintenance. Frequent inspections of all guarding in line with risk assessment, but at least annually. Regular inspection and maintenance of e-stops and interlocks in line with risk assessment and manufacturer's instructions, but at least monthly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Flammable gas detectors
APM Object	CT.SAFE.FLAMGASDETECT
APM Description	Flammable gas detectors
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	GAS - FIRE.DET.HYDRO	**Related CT Areas:**	CT.HVAC.GASDET - CT.HVAC.GASAPPLIANCE		

Scope

Any site where flammable gas detectors (e.g. methane gas detectors, hydrogen gas detectors, etc.) are used to provide early warning of high concentrations of potentially explosive or flammable gases.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and planned maintenance programme.	Routine maintenance of all flammable gas detectors to ensure correct integrity, including potential damage, loose parts, connections, etc.	Competent person, usually internal	Maintenance logbook	PM					EVID		
All	2	In accordance with manufacturer's instructions and the site risk assessment, but at least monthly.	Routine inspection and testing of all flammable gas detectors. A "bump test" should be performed, which consists of exposing the gas detector to a high concentration of a gas to ensure the sensors respond and the alarms are functioning.	Competent person, best practice to outsource	Inspection records, report or certificate. Risk assessment CE Declaration of Conformity.			CT					
All	3	In accordance with manufacturer's instructions and the site risk assessment, but at least every 6 months. A calibration should also follow any failed bump test.	Routine calibration of all sensors	Competent person, best practice to outsource	Inspection records, report or certificate. Risk assessment					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A

CZ	Decree No. 246/2001 Coll. Act No. 133/1985 Coll. on Fire Protection. ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree No. 50/1978 Coll.	Accredited company Review technician	Once a year, unless the manufacturer establishes a shorter Revision of equipment 6 - 36 months depending on the type of environment
DE	Betriebssicherheitsverordnung – BetrSichV DGUV Information 213-057 - Gaswarneinrichtungen und -geräte für den Explosionsschutz DGUV Information 213-056 - Gaswarneinrichtungen und -geräte für toxische Gase/Dämpfe und Sauerstoff	Trained person (unterwiesene Person) for the visual inspection OR A qualified person (Fachpersonal) for the functional check. OR Competent person (befähigte Person) for the system check and maintenance record check.	After installation, gas warning devices must be tested for their function by a competent person. Visual inspection once a month, a functional inspection at least every 4 months, and a system inspection at least every year. For devices with a self-monitoring system, functional inspections can be conducted at least once a year. For portable devices the visual inspection must also include a display test, and must be conducted before each shift, or every working day if the device is used over the course of a shift change.
ES	RD 919/2006, of July 28, which approves distribution and usage of gas fuel and its Complementary Technical Instructions ICG 01 to 11. RD 681/2003, of June 12, which approves the protection of the health and safety of workers exposed to the risks derived from explosive environments in the workplace. RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. Technical Instruction ITC-BT-29.	Accredited company (OCA) by ENAC for low-voltage related inspections and authorised company for fuel gas install inspections.	At least every 5 years within official low-voltage inspections At least every 5 years within official gas fuel install inspections.
FR	Labor Code Article R4227-39 relating to safety equipment Code du travail article R4227-39 relatif aux consignes de sécurité incendie https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	Competent person, best practice to outsource to specialist company.	Routine maintenance of gas detectors. Bump testing to ensure correct operation of detector and alarm in accordance with manufacturer's instructions. Regular calibration of flammable gas detectors in accordance with manufacturer's instructions, but at least 6-monthly. Additionally, following any failed bump test.
IT	Legislative Decree 9/04/2008 n.81 CEI EN 60079-29-2:2016 (Maintenance) CEI EN 60079-29-1:2017 (Performance requirements and test methods) UNI 11522:2014 (Flammable gas detectors for domestic use-Maintenance)	Competent person.	Bump testing, regular calibration and maintenance of flammable gas detectors in accordance with manufacturer's instructions, but at least every 6 months.
PL	Regulation of Minister Of Interior and Administration of June 7, 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Dz.U. 2008 nr 199 poz. 1228)	Competent person, best practice to outsource to specialist company.	Routine maintenance of gas detectors. Bump testing to ensure correct operation of detector and alarm in accordance with manufacturer's instructions. Regular calibration of flammable gas detectors in accordance with manufacturer's instructions, but at least once a year. Additionally, following any failed bump test.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) BS EN 60079-29-1:2016 – Explosive atmospheres. Gas detectors. Performance requirements of detectors for flammable gases	Competent person, best practice to outsource to specialist company.	Routine maintenance of gas detectors. Bump testing to ensure correct operation of detector and alarm in accordance with manufacturer's instructions.
SK	Ordinance No. 140/2018 Coll. on details in the field of installation of gas equipment STN EN 61779 Electrical apparatus for the detection and measurement of flammable gases	Qualified and certified person (producer or dealer of equipment)	Annual inspection of stationary and portable gas detectors.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) BS EN 60079-29-1:2016 – Explosive atmospheres. Gas detectors. Performance requirements of detectors for flammable gases	Competent person, best practice to outsource to specialist company.	Routine maintenance of gas detectors. Bump testing to ensure correct operation of detector and alarm in accordance with manufacturer's instructions, but at least monthly. Regular calibration of flammable gas detectors in accordance with manufacturer's instructions, but at least 6-monthly. Additionally, following any failed bump test.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Light barriers
APM Object	CT.SAFE.LIGHTBARRIERS
APM Description	Light barriers
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site that uses physical or non-physical barriers as means to prevent, control or mitigate undesired events or accidents.
This Standard is for planned preventative maintenance only. It is expected that pre-use checks are undertaken by operator prior to using the equipment and that equipment would not be used where guarding has been removed or damaged.
Note other guarding is covered in CT.SAFE.CONVGUARDING

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance of all light barriers, including cleaning, parts replacing, etc.	Competent person	Maintenance logbook			CT					
All	2	Based on risk assessment (environment and manufacturers instructions), but at least monthly Technical assessment annually (it is assumed supervisors will check for unauthorised modifications more frequently)	Regular inspection of condition and integrity of all light barriers to ensure safe use.	Competent person	Inspection records, report or certificate. Risk assessment CE declaration of conformity			CT			CT		
CZ	3	Between 6 - 36 months	Inspection and maintenance of equipment (depending on type and environment)	Competent person.	Inspection records					(CT)			6-36 Month CT

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll. Decree No 50/1978 Coll. ČSN 33 1600 ed.2.	Competent person, best practice to outsource to specialist	Inspection every 12 months. Inspection and maintenance of equipment (depending on type and environment) between 6 - 36 months

DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen TRBS 1203 - Befähigte Personen Prüfungen an BWS - Berührungslos Wirkende Schutzeinrichtungen	competent person (befähigte Person) according to TRBS 1203	Regular inspections based on risk assessment.
ES	Directive 2006/42 / EC of the European Parliament and of the Council of 17 May 2006 on machines. RD 1644/2008, of October 10, which establishes the rules for marketing and commissioning of the machines. RD 1215/1997, of July 18, establishing minimum security provisions and Health for the use by workers of work equipment. RD 1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person.	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	Labor Code : Article R4323-22 to R4323-28 relating to work equipment checks Code du travail article R4223-22 à 128 relatifs au contrôle des équipements de travail https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489757/#LEGISCTA000018531487	Qualified person	Daily with visual inspections Required after dismantling the equipment. Regular inspections in accordance with manufacturer's instructions, but at least every 6 months
IT	Legislative Decree 9/04/2008 n.81 IEC 61496-1:2020 (Electro-sensitive protective equipment) IEC 62046:2018 (Application of protective equipment to detect the presence of persons) IEC TS 62998-1:2019 (Safety-related sensors used for the protection of persons)	Qualified personnel	Daily checks. Regular inspections in accordance with manufacturer's instructions, but at least every 6 months
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, number 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirementsfor machines (Dz.U. 2008 nr 199 poz. 1228)	Qualified or competent person	Regular inspections based on risk assessment. In accordance with manufacturer's instruction or internal procedure / good practices implemented in the company.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person - but often delivered by the owner or manager	Routine maintenance Regular inspections in line with risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work. Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection when working with technical pressure, lifting, electric and gas equipment and laying down technical equipment which is considered to be the reserved technical equipment	Competent and qualified person	In accordance with the type of equipment on which the system is mounted in accordance with the manufacturer's instructions or at least every two years.
UK	The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk)	Competent person - but often delivered by the owner / manager of the site	Routine maintenance Regular inspections in line with risk assessment, but at least monthly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Emergency showers and eyewash stations
APM Object	CT.SAFE.WASH
APM Description	Emergency showers and eyewash stations
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.WATER.COLDSERVICE CT.WATER.LEGIONELLA		

Scope

Any site with eye wash stations and emergency showers fed by mains water.
Disposable eyewash solutions are not covered within this Compliance Standard.
Water quality inspection requirements are covered under "Cold water services" and "Legionella Risk Assessment (LRA)".

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance of all safety critical equipment.	Competent person, usually internal	Maintenance logbook			CT					
All	2	In accordance with manufacturer's instructions and recommendations, and based on risk assessment, but at least monthly	Regular inspections of all plumbed-in safety showers to ensure a minimum discharge of water at a rate of 60 l/s for at least 15 minutes and that a minimum of 95% of the water flow is contained within a 40cm diameter.	Competent person, can be sourced internally or externally	Inspection records, report or certificate. Risk assessment Equipment should be labelled.			CT					
All	3	In accordance with manufacturer's instructions and recommendations, and based on risk assessment, but at least monthly	Regular inspections and testing of all plumbed-in eyewash stations to ensure a minimum discharge of water at a rate of 6 l/s for at least 15 minutes and at a jet height of between 100mm and 300mm, and a response time when activated via a valve of less than 1 second.	Competent person, can be sourced internally or externally	Inspection records, report or certificate. Risk assessment Equipment should be labelled.			CT					
All	4	In accordance with manufacturer's instructions and recommendations, and based on risk assessment, but at least monthly	Regular temperature checks of the water discharged via eyewash stations and emergency showers to ensure it is no less than 15°C.	Competent person, can be sourced internally or externally	Inspection records, report or certificate. Risk assessment Equipment should be labelled.			CT					
CZ	6	In accordance with the manufacturer's instructions and recommendations	Regular inspection of equipment	Competent person	Record of the check performed			(CT)					

IT	5	Every 6 months.	Inspection as for [1]	No additional requirements.	CE Declaration of Conformity.					(CT)			

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Act No. 262/2006 Coll. Traumatological plan Manufacturer's instructions Nam. Government Regulation No. 378/2001 Coll.	Competent person	At least once a year, unless stated otherwise by the manufacturer
DE	Arbeitsschutzgesetz (ArbSchG) Arbeitsstättenverordnung (ArbStättV) DGUV Information 204-022 Erste-Hilfe im Betrieb Betriebssicherheitsverordnung (BetrSichV) Gefahrstoffverordnung (GefStoffV) DIN EN 15154-5:2019-12	Competent person (befähigte Person)	Regular inspection of emergency showers and eyewash stations based on risk assessment, but a functional inspection and inspectional of effectiveness of technical protective measures at least every third year. A general inspection of the functionality at least monthly and annual maintenance.
ES	RD 656/2017, of June 23, which approves Chemical Substances Storage regulation and its Complementary Technical Instructions MIE APQ 0 to 10. UNE-EN 15154: 2007. Emergency safety showers	Official inspections by accredited company (OCA) authorised by ENAC. On-site inspection by competent person.	Regular and official inspections according to Royal Decree 656/2017 its Complementary Technical Instructions: every 5 years.
FR	Labor Code Art R4224-17 to 19 relating to site and installation maintenance Code du travail article R4224-17 à 19 relatifs à la maintenance du site et de ses installations https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532199/ NF X15-221 - voluntary standard for insurance	On-site inspection by competent person	Regular inspection of emergency showers and eyewash stations based on risk assessment, but at least monthly (Best practice).
IT	Legislative Decree 9/04/2008 n.81 Decree 15/07/2003 n.388 UNI EN 15154-2:2007 (Eye washers) UNI EN 15154-1:2007 (Emergency showers)	Competent person.	Functional test (as for [2], [3], [4]) every month or in accordance with manufacturer's instructions. Maintenance every 6 months.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, number 169, item 1650) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Dz.U. 2008 nr 199 poz. 1228)	Competent person.	Functional test (every month or in accordance with manufacturer's instructions. Maintenance every 6 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) BS EN 15154 – Safety Shower Stations	Competent person	Regular maintenance of all safety critical equipment. Regular inspections of all plumbed-in safety showers to ensure appropriate operation, based on risk assessment and manufacturer's instructions. Regular inspections of all plumbed-in eyewash stations to ensure appropriate operation, based on risk assessment and manufacturer's instructions.
SK	STN EN 15154-2 Emergency safety showers - Part 2: Plumbed-in eye wash units STN EN 15154-4 Emergency safety showers - Part 4: Non plumbed-in eyewash units	Competent and qualified person	Monthly functionality test (performed by user) and annual inspection (performed by qualified person)
UK	The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Health and Safety (First-Aid) Regulations 1981 (legislation.gov.uk) The Health and Safety (First-Aid) Regulations (Northern Ireland) 1982 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) BS EN 15154 – Safety Shower Stations	Competent person	Regular maintenance of all safety critical equipment. Regular inspections of all plumbed-in safety showers to ensure appropriate operation, based on risk assessment and manufacturer's instructions. Regular inspections of all plumbed-in eyewash stations to ensure appropriate operation, based on risk assessment and manufacturer's instructions.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Sewage pumping Stations						
APM Object	CT.SEWAGE.SEWAGEPUMP						
APM Description	Pumping stations / pumps, in take filters, operation panels, telemetry/sensors and alarms.						
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template						
Last Update: (Version) abr-24	**Last Update Change Detail:** PM evidence changed from 3M to 12M.		**Activities may be covered by No-Go restrictions:** Not Specified	**Special Certification Required:**		**Delivered By:**	
Evidenced part or full by PM: Yes	**Related BBM PM:** Waste water pumps Waste macerator pumps Drainage Systems (Gravity system)		**Related CT Areas:** CT.FAC.DRAIN				

Scope

Any site where pumping stations are operated to pump sewage from site into the foul networks.
This standard does not cover sewage treatment plants.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In line with manufacturers requirements but at least monthly.	Regular inspection and maintenance of pumps and clearance of any filters and telemetry/sensors to ensure correct operation. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	2	In line with manufacturers requirements but at least every 3 months.	Regular maintenance (cleaning and testing) of other associated assets e.g. operational panel, alarms etc.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	3	In line with drainage survey findings.	Regular flushing of the system to remove deposits.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	4	As per 1- 3 unless stated in the Permit.	If pump system is used to discharge treated sewage into the environment, septic tank or treatment system, a permit might be required or in place. The discharge to a sewer network may also need a permit from the utility company. The permit could determine the frequency of inspections and maintenance. Ensure current permit or discharge consent stored on Document Management System.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)						Doc Check		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

ALL	No region specific legislation specified	N/A	N/A
CZ	Water Act No. 258/2000 Coll. Act No. 274/2001 Coll., on Water supply and sewerage systems for public use	N/A	The discharge to a sewer network needs an agreement with a network operator. The agreement could determine maintenance/inspection requirements.
DE	Wasserhaushaltsgesetz (WHG) §60 DIN 1986 - Entwässerungsanlagen für Gebäude und Grundstücke DIN EN 12050-1 Abwasserhebeanlagen für die Gebäude- und Grundstücksentwässerung - Bau- und Prüfgrundsätze - Teil 1: Fäkalienhebeanlagen entsprechen.	Competent person (befähigte Person).	Prior first use, the tightness of the facility has to be checked. Regular visual inspections of structural condition of the system. Monthly checks of the operational capability should be conducted by the operator, by observing at least two system cycles. Regular maintenance at least every 3 months. Regular flushing of the system at least every 2 years.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person.	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	No additional requirements Observe local site permit.	N/A	N/A
IT	UNI EN 12050-1:2015 (Sewage lifting plants) UNI EN 15885:2018 (Restoration, repair, replacement and maintenance of wastewater disposal installations) UNI EN 13508-1:2012 (wastewater disposal installations evaluation) UNI EN 752:2017 (Drain connections and sewer collectors outside buildings)	Competent person.	Maintenance in accordance with manufacturer's instructions. The periodicity of the maintenance activities is not set by Italian legislation
PL	Act of 20 July 2017 on water law (Journal of Laws 2021, item 624) Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333) Act of 7 June 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028) Act of 27 April 2001 on environmental law (Journal of Law 2020, item 1219) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	N/A	N/A
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Based on risk assessment (use and environment) and manufacturer's recommendations.
SK	Act No. 124/2006 Coll. on safety and health at work	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment.
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person.	Based on risk assessment (use and environment) and manufacturer's recommendations.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Backflow prevention devices					
APM Object	CT.WATER.BACKFLOW					
APM Description	Water systems (drinking, sanitary and process water)					
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template					
Last Update: (Version) abr-24	**Last Update Change Detail:** PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:** Not Specified	**Special Certification Required:**	**Delivered By:**		
Evidenced part or full by PM: Yes	**Related BBM PM:** WTR.SUPPLY.VALVES BLDG.INT	**Related CT Areas:** Not Specified				

Scope

All sites are required to have backflow prevention devices to avoid contaminated water flowing back and contaminating the system or mains supply pipework.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Based on risk assessment, but at least annually. Where repair works or new work is undertaken, inspect work following completion.	Regular inspection and testing of water systems to ensure that backflow preventers (e.g. double check valves, pipe interrupters) are present and operating correctly.	Competent person, best practice to outsource	Inspection records, report or certificate. Maintenance and operating logbook	PM					EVID		
IT	2	Every 6 months	Inspection of the backflow protection devices	No additional requirements	No additional requirements	PM					EVID		
IT	3	Every 12 months	Maintenance (functional test) of the devices	No additional requirements	No additional requirements	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll.	Competent person, best practices for outsourcing to a specialist.	Carryout checks every 12 months.

DE	VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung DIN EN 806-5 - Technische Regeln für Trinkwasser-Installationen - Teil 5: Betrieb und Wartung	Competent person (befähigte Person) of a registered installation company	Regular inspection and maintenance of backflow preventers based on risk assessment, but at least annually.
ES	Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4). Section 3.3.	Competent person of a registered installation company	Regular inspection of all backflow preventers based on manufacturer's instructions and risk assessment.
FR	Departmental Health Regulations - article 16.3 https://www.paca.ars.sante.fr/sites/default/files/2017-01/RSD_13_ars_paca_01.pdf	Competent person, best practices for outsourcing to a specialist.	Carryout checks every 12 months
IT	Legislative Decree 02/02/2001 n. 31 Legislative Decree 04/09/2008 n.81 UNI EN 806-5:2012 (Maintenance) UNI EN 1717:2002 (Backflow protection devices)	Competent person.	Maintenance in accordance with manufacturer's instructions. Inspection of backflow protection devices every 6 months and maintenance (functional test) every 12 months.
PL	Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 7 July 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028) Act of 27 April 2001 on Environmental Law (Journal of Law 2020, item 1219) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333)	N/A	N/A
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Regular inspection of all backflow preventers based on manufacturer's instructions and risk assessment.
SK	Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply STN EN 1717 Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow	Competent person, best practice to outsource to specialist	Functional test intervals depend on the type of construction site.
UK	The Water Supply (Water Fittings) (England and Wales) Regulations 1999 The Water Supply (Water Fittings) Regulations (Northern Ireland) 2009 Water Supply (Water Fittings) (Scotland) Byelaws 2014	Competent person, best practice to outsource to specialist.	Regular inspection of all backflow preventers based on manufacturer's instructions and risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Cold water services
APM Object	CT.WATER.COLDSERVICE
APM Description	Cold water storage and supply systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.WATER.LEGIONELLA, CT.WATER.COOLINGTOWERS, CT.WATER.HOTSERVICE and CT.SAFE.WASH		

Scope

Any site with cold water services, such as water supply storage tanks and distribution network, that might lead to a risk of employees contracting legionella disease (or other water borne pathogen).
Legionella risk assessment requirements are covered under CT.WATER.LEGIONELLA. Hot water systems are covered in CT.WATER.HOTSERVICE and cooling towers in CT.WATER.COOLINGTOWERS.
Additional requirements of emergency showers and eyewashes are covered under CT.SAFE.WASH

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Based on risk assessment, but at least weekly.	Flush through water distribution dead legs to drain for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. (Programme removal of dead legs ASAP) These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella Risk Assessment Inspection and checks records, report or certificate. Schematic diagram of cold water services. Legionella log book (results of temperature checks, management actions etc)		CT						
All		Based on risk assessment, but at least weekly.	Flush through satellite/sentinel outlets and taps (rarely used) for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services		CT						
All		Based on risk assessment, but at least weekly.	Staff showers, emergency eyewash and emergency showers need to be flushed through for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services		CT						
All		Based on risk assessment, but at least monthly.	Check that temperature is <20°C after running the water for up to two minutes in the sentinel taps. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services			CT					
All		Based on risk assessment, but at least every 6 months	Check tank water temperature remote from ball valve and mains temperature at ball valve is <20°C. Note maximum temperatures recorded by fixed max/min thermometers where fitted. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services					CT			

All		Based on risk assessment and manufacturers instructions but at least annually	Visually inspect cold water storage tanks and carry out remedial work where necessary. Check representative taps for temperature as above on a rotational basis	Competent person	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.						CT		
All		Based on risk assessment and manufacturers instructions but at least annually	Check thermal insulation of cold water storage tanks and associated pipework to ensure it is intact	Competent person	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.						CT		
All		Based on risk assessment and manufacturers instructions but at least annually	Service and disinfect base exchange softeners	Competent person	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.						CT		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist	Carryout checks every 12 months.
DE	Trinkwasserverordnung (TrinkwV) VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung VDI/BTGA/ZVSHK 6023 Blatt 2 - Hygiene in Trinkwasser-Installationen - Gefährdungsanalyse	Accredited specialist company (Zugelassener Fachbetrieb)	Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in line with risk assessment, but at least weekly. Mechanical filters: backwashing is triggered every six months for backwashable filters or replacement of the filter insert for non-backwashable filters. Shut-off valves: regular actuation of the valves by turning so that they remain mobile. Water taps / extraction fittings: use daily if possible, at least every seven days. Maintenance of softening unit every 6 months. Maintenance of Pressure reducer every 12 months.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption. RD 865/2003, laying down the hygienic-sanitary criteria for the prevention and control of legionellosis. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Periodic servicing: Competent person.	Annual inspection, cleaning, disinfection and sampling of equipment.
FR	Labor Code article R4225-4 https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532171/	Competent person, best practice to outsource to specialist	Best Practice: Annual inspection, cleaning, disinfection and sampling of equipment.
IT	Legislative Decree 04/09/2008 n.81, Annex IV Legislative Decree 02/02/2001 n. 31, Annex I Guidelines for prevention and control of legionnaires' disease Min salute 2015 UNI EN 918:2014(hot and cold water supply and distribution systems). UNI EN 806-5:2012 (operation and maintenance of installations inside buildings for the conveyance of water intended for human consumption) UNI EN ISO 11731: 2017 (cultural methods for the determination of the charge in water parameters)	Qualified person	Control measurements are required. Frequency of periodical check and inspection are not specified by Italian legislation; however the best practices, in accordance with the guidelines of the Ministry of health regarding the water system maintenance are: - Descaling of less worn elements by immersion in acid solution (sulfamic acid, acetic acid, etc.) and subsequent disinfection (not less than 30 minutes, in cold water containing at least 50 mg/L free chlorine). - Periodically replacement of faucet valve, faucet water filters, shower heads and pipes, as well as any other discontinuity element. The frequency of replacement is usually a function of water characteristics. - Microfiltering that allows the removal of Legionella from the water exiting at the point of use, through a mechanical barrier. - Thermal treatment at temperatures between 50 and 55 degrees. In case of presence of Legionella,
PL	Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294) Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 7 June 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028)	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Regular check of tank water temperature remote from ball valve and mains temperature at ball valve in accordance with manufacturer's instructions. Regular checks to ensure temperature is below 20°C after running the water for up to two minutes in the sentinel taps in accordance with manufacturer's instructions. Regular visual inspection of cold water storage tanks and undertaking of remedial work where necessary. Check representative taps for temperature as above on a rotational basis at least annually. Regular check of thermal insulation of cold water storage tanks and undertaking remedial work where necessary. Frequency in accordance with manufacturer's instructions. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in accordance with manufacturer's instructions.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Regular check of tank water temperature remote from ball valve and mains temperature at ball valve in line with risk assessment, but at least 6-monthly. Regular checks to ensure temperature is below 20°C after running the water for up to two minutes in the sentinel taps in line with risk assessment, but at least monthly. Regular visual inspection of cold water storage tanks and undertaking of remedial work where necessary. Check representative taps for temperature as above on a rotational basis. Frequency in line with risk assessment, but at least annually. Regular check of thermal insulation of cold water storage tanks and undertaking remedial work where necessary. Frequency in line with risk assessment, but at least annually. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant
SK	Act No. 442/2002 Coll. on public water supply and public sewerage Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Annual water quality control or control based at request from the regional public health office. Periodic inspection of technical equipment.

UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Control of Substances Hazardous to Health Regulations 2002 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) Legionnaires' disease: The control of legionella bacteria in water systems. Approved Code of Practice and guidance on regulations L8 (hse.gov.uk) HSG 274 Part 2 - The control of legionella bacteria in hot and cold water systems (legionellacontrol.com)	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Regular check of tank water temperature remote from ball valve and mains temperature at ball valve in line with risk assessment, but at least 6-monthly. Regular checks to ensure temperature is below 20°C after running the water for up to two minutes in the sentinel taps in line with risk assessment, but at least monthly. Regular visual inspection of cold water storage tanks and undertaking of remedial work where necessary. Check representative taps for temperature as above on a rotational basis. Frequency in line with risk assessment, but at least annually. Regular check of thermal insulation of cold water storage tanks and undertaking remedial work where necessary. Frequency in line with risk assessment, but at least annually. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Drinking water stations
APM Object	CT.WATER.DRINKING
APM Description	Plumbed and free-standing drinking water points
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.DWDISP	**Related CT Areas:**	CT.WATER.COLDSERVICE CT.ELEC.PAT		

Scope

Any site with either plumbed in drinking water fountains/dispensers and, or free standing water coolers. (e.g. Hydrachill, Water Logic, Niagara units).
It is assumed that routine cleaning of handles and spouts and emptying of any overflow device will be completed by the cleaning contractor.
Where units are on a hire arrangement, some services maybe fulfilled by an external contractor. A PPM task should still be raised.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Based on risk assessment, but at least weekly	If a drinking station is plumbed into the cold water system, flush through water distribution dead legs to drain for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk Assessment Schematic diagram of cold water services.	PM					EVID		
All		At least every 6 months	All drinking stations (free standing and plumbed) must be serviced and filters changed (lines and fittings should be sterilised and spouts descaled)	Competent person, can be externally (i.e. external provider/contractor) or internally sourced.	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.	PM					EVID		
All		At least every 12 months	Service and disinfect base exchange softeners	Competent person, usually sourced internally.	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A

CZ	Act No. 544/2020 Coll. – Water Act Act No. 205/2020 Coll. - Public Health Protection Act Government Regulation No. 101/2005 Coll. - Regulation on more detailed requirements for workplaces and working environments. Nam. Government Regulation No. 378/2001 Coll. - Regulation laying down more detailed requirements for the safe operation and use of machinery, technical equipment, instruments and tools Decree no. 70/2018 Coll. - establishes the sanitary requirements for drinking water and hot water and the frequency and extent of inspection of drinking water	Competent person	Carry out checks every 12 months.
DE	Trinkwasserverordnung (TrinkwV) VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung VDI/BTGA/ZVSHK 6023 Blatt 2 - Hygiene in Trinkwasser-Installationen - Gefährdungsanalyse	Competent person	Water taps / extraction fittings: use daily if possible, at least every seven days. Maintenance of softening unit every 6 months. Maintenance of system separator and backflow preventer: maintenance and function check every 12 months.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption, and further modifications such as RD902/2018, of July 20. RD 865/2003, laying down the hygienic-sanitary criteria for the prevention and control of legionellosis. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Competent person. Cleaning and disinfection works must be carried out by authorised company according to RD830/2010	Cleaning, disinfection and sampling of equipment in line with risk assessment. At least once per year according to Appendix 3 of RD865/2003. Review of the state of conservation and cleanliness must be carried out every 3 months in tanks and monthly in a representative number, rotating throughout the year, of the terminal points (taps) of the inner drinking water net. At the end of the year all terminal points must have been reviewed.
FR	Labour Code article R4225-4 relating to the drink water provision https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532171/2008-05-01	Competent person	Best Practice: Annual inspection, cleaning, disinfection and sampling of equipment.
IT	Legislative Decree 04/09/2008 n.81, Annex IV Legislative Decree 02/02/2001 n. 31, Annex I UNI EN 918:2014(hot and cold water supply and distribution systems). UNI EN 806-5:2012 (operation and maintenance of installations inside buildings for the conveyance of water intended for human consumption)	Qualified person	Frequency of periodical check and inspection are not specified by Italian legislation. Regarding the plumbed drinking water points, inspections and maintenance in accordance with the risk assessment. Concerning the free-standing systems, inspection and maintenance in accordance with manufacturer's instructions, best practice is every 6 months.
PL	Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294) Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 7 June 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028)	Competent person	Carryout checks every 12 months. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in accordance with manufacturer's instructions or risk assessment. Service and disinfect base exchange softeners, in accordance with manufacturer's instructions risk assessment, Water supplied must be wholesome (i.e. free from contamination/pathogens
ROI	Safety, Health and Welfare at Work (General Application) Regulations 2007	Competent person	Regular flushing of sentinel outlets, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in line with risk assessment, but at least weekly. Service and disinfect base exchange softeners, in line with risk assessment, but at least annually. Regular cleaning and disinfection of component parts including filters. Frequency in line with risk assessment. Water supplied must be wholesome (i.e., free from contamination/pathogens)
SK	Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply	Regular control conducted by competent and qualified person Regular inspections conducted by competent person, best practice to outsource to specialist	Annual water quality control or control based at request from the regional public health office. Periodic inspection of technical equipment: Cleaning and maintenance of water facilities, areas, premises and facilities that are part of the drinking water distribution system or which may adversely affect the quality of drinking water.
UK	Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 The Control of Substances Hazardous to Health Regulations 2002 (legislation.gov.uk) The Workplace (Health, Safety and Welfare) Regulations 1992	Competent person	Regular flushing of sentinel outlets, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in line with risk assessment, but at least weekly. Service and disinfect base exchange softeners, in line with risk assessment, but at least annually. Regular cleaning and disinfection of component parts including filters. Frequency in line with risk assessment. Water supplied must be wholesome (i.e. free from contamination/pathogens)

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Hot water services
APM Object	CT.WATER.HOTSERVICE
APM Description	Hot water storage and supply systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	HVAC.HTR	**Related CT Areas:**	CT.WATER.LEGIONELLA - CT.WATER.COLDSERVICE - CT.SAFE.WASH		

Scope

Any site with hot water services, such as hot water supply storage tanks, calorifiers, mixer taps, showers and distribution network, that might lead to a risk of employees contracting legionnaires disease.
Legionella risk assessment requirements are covered under CT.WATER.LEGIONELLA. Cold water systems are covered in CT.WATER.COLDSERVICE.
Additional requirements of emergency showers and A are covered under CT.SAFE.WASH

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Based on risk assessment but at least monthly	Check temperatures at in flow and return at calorifiers and storage cylinders to ensure 50-60°C These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all hot water services			CT					
All	2	Based on risk assessment but at least monthly	Check water temperature up to one minute to see if it has reached 50°C in the sentinel taps. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all hot water services			CT					
All	3	Based on risk assessment but at least monthly	Check outlets associated with each combination water heater to ensure the unit stores water at 50-60°C. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all hot water services			CT					
All	4	Based on risk assessment, but at least every 3 months.	Check temperatures in subordinate recirculating loops ensuring at least 50°C is achieved. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all hot water services				CT				
All	5	Based on risk assessment, but at least every 3 months.	Dismantle, clean and descale shower heads and hoses (including emergency showers)	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all hot water services				CT				

All	6	Based on risk assessment, but at least every 6 months.	Check the temperature of the water provided by point of use heaters (<15l) ensuring at least 50°C is achieved	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all hot water services					CT			
All	7	Based on risk assessment, but at least every 6 months.	Flush through and purge to drain all expansion vessels.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all hot water services					CT			
All	8	Based on risk assessment, but at least annually	Arrange for samples to be taken from hot water calorifiers and storage cylinders, in order to note condition of drain water and identify internal scale or sludge	Competent person, best practice to outsource . Any analysis should be completed at UKAS accredited laboratory.	Inspection records, report or certificate. Legionella Risk assessment Laboratory testing results Schematic diagram of all hot water services						CT		
All	9	Based on risk assessment, but at least annually	Visual check on internal surfaces of calorifiers and storage cylinders for scale and sludge. Check representative taps for temperature as per [2] on a rotational basis.	Competent person	Inspection records, report or certificate. Legionella Risk assessment Schematic diagram of all hot water services						CT		
All	10	Based on risk assessment, but at least annually	Inspect the header units of each combination water heater.	Competent person	Inspection records, report or certificate. Legionella Risk assessment Schematic diagram of all hot water services	PM					EVID		
All	11	Based on risk assessment, but at least annually	Undertake service of all Thermostatic Mixing Valves (TMV's) to the manufacturer's instructions.	Competent person	Inspection records, report or certificate. Legionella Risk assessment Schematic diagram of all hot water services	PM					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
ALL	No region specific legislation specified	N/A	N/A
CZ	Act No. 258/2000 Coll. Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978 Coll.	Accredited company Competent technician	Carryout, as a producer of hot water, regular analyses according to the extent covered by the legislation. Frequency determined by the Protocol on the list of external influences, between 6 and 60months.
DE	Trinkwasserverordnung (TrinkwV) Bekanntmachungen und Empfehlungen des Umweltbundesamtes zur TrinkwV DVGW W 551 - Trinkwassererwärmungs- und Trinkwasserleitungsanlagen - Technische Maßnahmen zur Verminderung des Legionellenwachstums - Planung, Errichtung, Betrieb und Sanierung von Trinkwasser-Installationen VDI/DVGW 6023 - Hygiene in Trinkwasser-Installationen - Anforderungen an Planung, Ausführung, Betrieb und Instandhaltung	Accredited specialist company (Zugelassener Fachbetrieb)	Visual inspection of hot water storage facility at least annually to identify any physical defects. Visual inspection of the drinking water heater every two months (check the temperature setting of the device, it should be at least 60 ° C.) Maintenance and cleaning of hot water heater every 12 months. Maintenance of softening unit every 6 months. Maintenance of Pressure reducer every 12 months. Maintenance of system separator and backflow preventer: maintenance and function check every 12 months.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption. RD 865/2003, laying down the hygienic-sanitary criteria for the prevention and control of legionellosis. RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE) Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	RITE: Competent person and authorised Maintainer. Legionella inspections: authorised companies (by ENAC).	Annual inspection, cleaning, disinfection and sampling of equipment. Legionella periodic inspections and sampling: Cooling towers and evaporative condensers: annual inspections. Domestic hot water systems with storage tank and return circuit: every 4 years. Industrial humidifying plants: every 2 years.
FR	Public Health Code – Art. R1321-43 to 61 https://www.legifrance.gouv.fr/codes/id/LEGIARTI000006909561/2007-01-12	Qualified person	Regular inspection of header units of each water heater in line with risk assessment but at least annually.

IT	Legislative Decree 04/09/2008 n.81, Annex IV Legislative Decree 02/02/2001 n.31, Annex I Guidelines for prevention and control of legionnaires' disease Min salute 2015 UNI EN 918:2014(hot and cold-water supply and distribution systems). UNI EN 806-5:2012 (operation and maintenance of installations inside buildings for the conveyance of water intended for human consumption) UNI EN ISO 11731: 2017 (cultural methods for the determination of the charge in water parameters)	Qualified person	Control measurements are required. Frequency periodical of check is not specified by Italian legislation; however the best practices, in accordance with the guidelines of the Ministry of health regarding the water system maintenance are: - Descaling of less worn elements by immersion in acid solution (sulfamic acid, acetic acid, etc.) and subsequent disinfection (not less than 30 minutes, in cold water containing at least 50 mg/L free chlorine). - Periodically replacement of faucet valve, faucet water filters, shower heads and pipes, as well as any other discontinuity element. The frequency of replacement is usually a function of water characteristics. - Microfiltering that allows the removal of Legionella from the water exiting at the point of use, through a mechanical barrier.
PL	Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294) Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624)	The State Sanitary Inspection	Regular samples to be taken from calorifiers and storage cylinders not stipulated by regulations Check calorifier and storage cylinder's flow and return water temperature not stipulated by regulations. Check water temperature at sentinel taps (up to 1 minute) in line with risk assessment, but at least annually. Visual checks of internal surfaces of calorifiers and storage cylinders for scale and sludge and check temperature on representative taps in line with risk assessment, but at least annually. Regular inspection of header units of each water heater in line with risk assessment but at least annually. Check temperature of water heater outlets not stipulated by regulations Check temperature of subordinate recirculating loops not stipulated by regulations Check temperature of the water provided by point of use heaters (if <15L) not stipulated by regulations
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist	Regular samples to be taken from calorifiers and storage cylinders in line with risk assessment, but at least annually. Check calorifier and storage cylinder's flow and return water temperature in line with risk assessment but at least monthly. Check water temperature at sentinel taps (up to 1 minute) in line with risk assessment, but at least monthly. Visual checks of internal surfaces of calorifiers and storage cylinders for scale and sludge and check temperature on representative taps in line with risk assessment, but at least annually. Regular inspection of header units of each water heater in line with risk assessment but at least annually. Check temperature of water heater outlets in line with risk assessment but at least monthly.
SK	Act No. 355/2007 Coll. on the protection, promotion and development of public health and on the amendment of certain laws Act No. 124/2006 Coll. on safety and health at work Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection when working with technical pressure, lifting, electric and gas equipment and laying down technical equipment which is considered to be the reserved technical equipment	Competent and certified person	Annual water quality control or control based at request from the regional public health office. Frequency of inspection depends on type of equipment and its parameters (performance and pressure). Inspection of equipment is realized at least twice a year. .
UK	The Control of Substances Hazardous to Health Regulations 2002 Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) Legionnaires' disease: The control of legionella bacteria in water systems. Approved Code of Practice and guidance on regulations L8 (hse.gov.uk) HSG 274 Part 2 - The control of legionella bacteria in hot and cold water systems (legionellacontrol.com)	Competent person, best practice to outsource to specialist	Regular samples to be taken from calorifiers and storage cylinders in line with risk assessment, but at least annually. Check calorifier and storage cylinder's flow and return water temperature in line with risk assessment but at least monthly. Check water temperature at sentinel taps (up to 1 minute) in line with risk assessment, but at least monthly. Visual checks of internal surfaces of calorifiers and storage cylinders for scale and sludge and check temperature on representative taps in line with risk assessment, but at least annually. Regular inspection of header units of each water heater in line with risk assessment but at least annually. Check temperature of water heater outlets in line with risk assessment but at least monthly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Lead
APM Object	CT.WATER.LEAD
APM Description	Water supply - lead monitoring.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

All sites are required under Health and Safety regulations to ensure their employees' health is maintained. As such, employers have the responsibility of ensuring their water supply is wholesome.
Water provided by the city/municipality/water company should not contain lead in excess of statutory levels. Responsibility for supply and distribution outside the facility boundary is not part of the scope of the standard.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Initial inspection at start of tenancy/purchase	Pipework survey to identify lead pipes in your water distribution network. This includes only those pipes within the boundary of the installation or those whose responsibility is the owner of the installation/building.	Competent person	Survey report								One Off EVID
All	2	Regular water sampling and laboratory testing in line with risk assessment, but at least annually.	If lead pipes are identified following, a water sampling and monitoring program must be in place to ensure employees are not exposed to lead levels above statutory levels	Competent person, laboratory analysis via accredited laboratory	Analysis results Risk assessment Sampling and monitoring programme						CT		
All	3	As programmed	Where lead pipes are identified a replacement programme should be scheduled and undertaken	Competent person	Project file showing replacement						DOC		
SK	4	Full analysis: 12 times per year Minimum analysis: 4 times per year	Inspection requirements are set up for water service provider.	No additional requirements	No additional requirements			CT*	CT*				

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Act No. 258/2000 Coll.	Accredited company	Carry out regular analyses according to the scope of the legislation.
DE	Trinkwasserverordnung (TrinkwV)	Health department (Gesundheitsamt) or Accredited institutions (zugelassene Institute/Prüfstellen) Health Department or Specialist plumbing and heating companies (Gesundheitsamt / Fachbetriebe der Sanitär- und Heizungstechnik) for removal of pipes.	Monitoring water quality for lead presence, at least every three years, if piping is made of lead. Removal of lead pipes. If lead in drinking water exceeds the threshold value of 0.010 mg/l.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption. RD 902/2018, which modifies RD 140/2003. RD 314/2016. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Outside piping systems: Local authorities. Private properties: owner, site manager. Lead sampling: authorised laboratories (ENAC).	Removal of lead pipes. Monitoring water quality for lead presence.
FR	Ministerail Order of 2010, January 21st relating to sanitary control analyses for water supplied by a distribution network https://cdnmedia.eurofins.com/european-west/media/1216/arr%C3%AAt%C3%A9-du-21-janvier-2010-relatif-au-contr%C3%B4le-sanitaire.pdf	Mainly managed by water supply companies.	Monitoring of water quality parameters, including lead
IT	Legislative Decree 04/09/2008 n.81, Annex IV Legislative Decree 02/02/2001 n. 31 UNI EN 806-5:2012(maintenance)	Qualified personnel	Monitoring to be undertaken periodically. The periodicity is not set by Italian Legislation.
PL	Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 27 April 2001 on Environmental Law (Journal of Laws 2020, item 1219) Act of 7 June 2001 on collective water supply and collective sewage disposal. (Journal of Laws 2020, item 2028) Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294)	Qualified or competent person (authorised under Construction Law)	Initial survey when handing over of building and installation.
ROI	Safety, Health and Welfare at Work Act 2005 (No. 10 of 2005) Safety S.I. No. 122/2014 - European Union (Drinking Water) Regulations 2014. (irishstatutebook.ie)	Mainly managed by water supply companies.	Monitoring of water quality parameters, including lead.
SK	Act No. 355/2007 Coll. on the protection, promotion and development of public health and on the amendment of certain laws Act No. 442/2002 Coll. on public water supply and public sewerage Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply	Competent and authorized person Water samples must be tested by accredited laboratory.	Non drinkable water: Annual sample analysis Drinkable water: before the first use of the system and based at specific requirements.
UK	The Water Supply (Water Quality) Regulations 2018 (legislation.gov.uk) The Water Supply (Water Quality) (Scotland) Regulations 2001 (legislation.gov.uk) The Water Supply (Water Quality) Regulations (Northern Ireland) 2017 (legislation.gov.uk)	Mainly managed by water supply companies.	Monitoring of water quality parameters, including lead

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Legionella Risk Assessment (LRA)
APM Object	CT.WATER.LEGIONELLA
APM Description	Hot and cold-water systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.WATER.COLDSERVICE CT.WATER.HOTSERVICE CT.WATER.COOLINGTOWERS CT.SAFE.WASH		

Scope

All sites are required to conduct a legionella risk assessment to ensure that hot and cold-water systems are managed effectively to manage the risk of legionella. This includes fire sprinkler systems.
Specific inspection requirements for the physical water systems are covered under CT.WATER.COLDSERVICE, CT.WATER.HOTSERVICE and CT.WATER.COOLINGTOWERS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Before the installation is occupied. Regularly, at intervals identified in the risk assessment, but at least every 2 years for low-risk systems. Following any significant water system changes or following	Conduct and maintain up to date a legionella risk assessment of all water systems within your installation, ensure reviewed and approved by Duty Holder	Competent person, best practice to outsource	Legionella risk assessment. Inspection records, report or certificate. Logbook Record of incidents. Records of remedial actions taken. Schematic diagram of all water							CT	

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A
CZ	Act No. 258/2000 Coll.	Accredited company	Carry out regular analyses according to the scope of the legislation.

DE	Trinkwasserverordnung (TrinkwV)	Health department (Gesundheitsamt) or Accredited institutions (zugelassene Institute/Prüfstellen)	First tests must be conducted within 3 – 12 months after the installation of a water supply system. Based on risk assessment but at least every 3 years. Water samples are taken both from hot and cold-water points. Legionella analysis of drinking water samples for hot water installations with more than 400L storage volume or hot water pipes with more than 3L content between the water heater and the tapping point. Frequency of sampling is 3 years. Additional drinking water analysis for legionella and pseudomonas based on risk assessment for cold and hot water systems, but at least every 3 years.
ES	RD 487/2022, of June 21, which establishes the health requirements for the prevention and control of legionellosis.	Legionella inspections: authorised companies (by ENAC).	- Sanitary water systems: Legionella spp .(UFC/L) : Quarterly Aerobes (UFC/ml) : Quarterly Ph (1) (2) : Daily. Temperature (ºC)(2) : Daily, rotating. Turbidity (UNF)(2) :Weekly Biocide (3) : Diary, if applicable, with automatic continuous reading. Total iron (µg/L) : Quarterly Conductivity: N/A. - Cooling towers and evaporative condensers.: Legionella spp .(UFC/L) : Monthly. Aerobes (UFC/ml) : Quarterly Ph (1) (2) : Daily. Temperature (ºC)(2) : Daily. Turbidity (UNF)(2) :Weekly Biocide (3) : Diary, if applicable, where appropriate, with automatic continuous reading. Total iron (µg/L) : Monthly. Conductivity: Monthly. - Installations with heated water systems or with temperatures similar to heated ones and aerosolization with agitation and recirculation through high-speed jets and/or air injection, etc. Legionella spp .(UFC/L) : Monthly. Aerobes (UFC/ml) : Monthly. Ph (1) (2) : Daily. Temperature (ºC)(2) : Daily. Turbidity (UNF)(2) :Daily. Biocide (3) : Diary, if applicable, where appropriate, with automatic continuous reading. Total iron (µg/L) : N/A. Conductivity: N/A. -Evaporative spray cooling devices using aerosol cooling elements. Legionella spp .(UFC/L) : Biannual. Aerobes (UFC/ml) : Biannual. Ph (1) (2) : Monthly. Temperature (ºC)(2) : Monthly. Turbidity (UNF)(2) :Monthly. Biocide (3) : Monthly. Total iron (µg/L) : N/A.Conductivity: N/A. (1) Depending on the biocide. (2) In the case of pH, temperature and turbidity, it can be controlled in situ, preferably with automatic continuous reading. (3) In the case of using physical disinfection treatments, the control of the biocide must be replaced by controls that ensure the correct functioning of the disinfection system. (4) If necessary, other parameters that are considered useful in determining the quality of the water or the effectiveness of the water treatment program will be included. However, the health authority may exempt the person who owns the facility from analyzing any of these parameters if, based on the type of facility in question, their presence in the water at levels such that they pose a risk is not likely to health.
FR	Site Authorization Permit can require periodic exams. See CT. WATER.COOLINGTOWERS	N/A	N/A
IT	Legislative Decree 04/09/2008 n.81	The Employer	All sites need to have a legionella risk assessment that must be updated every three years or in case of significant changes in work activity.
PL	Regulation of Health Minister of 22 April 2005 on harmful biological agents for health in the work environment and protection of the health of workers professionally exposed to these factors (Journal of Laws 2005, number 81, item 716) Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294) Act of 7 July 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028)	The State Sanitary Inspection	All sites need to have a legionella risk assessment. Review frequency not stipulated by regulations.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person	All sites need to have an initial legionella risk assessment. Review frequency is based on findings of risk assessment, but at least every 1-2 years, and following any changes to the water systems.
SK	Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply STN P ISO/TS 12869 Water quality. Detection and quantification of Legionella	Competent person, best practice to outsource to specialist	Annual quality control or control based at request from the regional public health office.
UK	The Control of Substances Hazardous to Health Regulations 2002 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003 (legislation.gov.uk) Legionnaires' disease: The control of legionella bacteria in water systems. Approved Code of Practice and guidance on regulations L8 (hse.gov.uk)	Competent person, best practice to outsource to specialist	All sites need to have an initial legionella risk assessment. Review frequency is based on findings of risk assessment, but at least every 2 years, and following any changes to the water systems.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Reverse osmosis water systems
APM Object	CT.WATER.OSMOSISSYS
APM Description	RO water systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where Reverse Osmosis (RO) systems are used to purify and filter water.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendation	Routine maintenance to ensure optimal operation of the RO system, including pre- and post-filter and membrane replacements.	Competent person	Maintenance logbook	PM					EVID		
All		In accordance with manufacturer's instructions and recommendation, but at least every 12 months.	Disinfection and cleaning of RO system tank and associated pipes to manage fouling	Competent person	Inspection records, report or certificate. Risk assessment						CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll.	Competent person, best practices for outsourcing to a specialist.	Carryout checks every 12 months.

DE	Trinkwasserverordnung (TrinkwV) VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung DIN EN 806-5 - Technische Regeln für Trinkwasser-Installationen - Teil 5: Betrieb und Wartung	Competent person (befähigte Person)of a registered installation company (Zugelassenes Fachbetrieb)	Change of filter at least every 6 months, and the membrane at least every 24 months. Best practice to disinfect before any filter change. The system must be flushed regularly, at least after every change of the membrane or filter. In accordance with manufacturer's instructions and recommendations.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Competent person	Change of membranes and/or other filtering devices according to the periodicity and instructions of the manufacturer or supplier
FR	Labor Code article R4225-4 https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532171/	Competent person, best practice to outsource to specialist	Best Practice: Change of membranes and/or other filtering devices according to the periodicity and instructions of the manufacturer or supplier
IT	Legislative Decree 04/09/2008 n.81 Legislative Decree 02/02/2001 n. 31	Qualified person.	Maintenance in accordance with manufacturer's instructions. The periodicity of the maintenance activities is not set by Italian legislation.
PL	Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624)	N/A	N/A
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person	Regular maintenance of RO systems in accordance with manufacturer's instructions or recommendations. Regular disinfection of tanks and pipes to avoid fouling, at least yearly.
SK	Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 550/2007 Coll. on details of requirements for products intended to come into contact with drinking water	Certified and accredited person	Regular inspection on annual basis or based at current user need.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk)	Competent person	Regular maintenance of RO systems in accordance with manufacturer's instructions or recommendations. Regular disinfection of tanks and pipes to avoid fouling, at least yearly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Noise Inspections
APM Object	CT.WHS.NOISE
APM Description	Noise inspections - whole site
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

All sites are required under Health and Safety regulations to safeguard the health and safety of their employees, visitors and that of others whom their work might affect. This includes the statutory requirement of risk assessing and minimising sources of noise as well as providing control measures in high noise areas.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Initially and at regular intervals as identified on the risk assessment, but at least yearly. Additionally, following any change in the activities, technology used or number of occupants.	Initial and periodic assessment of working conditions to identify sources of noise and put measures in place to minimise or remove/reduce sources that could pose a risk for the health and safety of the employees and visitors.	Competent person. Often outsourced although Amazon Safety Team maybe able to support)	Risk assessment Training records. Inspection records, reports or certificate. Surveillance/ medical examination records. CE Declaration of Conformity for machinery and Personal						CT		
All	2	Regular checks based on risk assessment.	Monitor levels of noise at work to ensure the noise thresholds and exposure limits (peak and daily) are not exceeded.	Competent person. Often outsourced although Amazon Safety Team maybe able to support)	Risk assessment Training records. Inspection records, reports or certificate. Surveillance/ medical examination records. CE Declaration of Conformity for machinery and Personal						CT		
All	3	Based on risk assessment (use conditions and frequency).	If Personal Protection Equipment (PPE) is required, regular maintenance should be conducted to ensure correct operation and condition.	Competent person.	Risk assessment Training records. Inspection records, reports or certificate. Surveillance/ medical examination records. CE Declaration of Conformity for machinery and Personal						CT		
All	4	Initially (baseline) and at regular intervals, usually annually.	Health surveillance (e.g. audiometric testing) to monitor employees' hearing ability when they are likely to be frequently exposed above the upper exposure action values or are at risk for any other reason.	Competent person. Often outsourced	Risk assessment Training records. Inspection records, reports or certificate. Surveillance/ medical examination records. CE Declaration of Conformity for machinery and Personal						CT		
All	5	Based on risk assessment and/or manufacturer's instructions and recommendations.	Regular maintenance of all equipment that has been identified as a source of noise to ensure it continues to work effectively and minimises noise to lowest possible level.	Competent person.	Risk assessment Training records. Inspection records, reports or certificate. Surveillance/ medical examination records. CE Declaration of Conformity for machinery and Personal						CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Abrasive wheels
APM Object	CT.WORK.ABRASIVE
APM Description	Abrasive wheels
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where employees use abrasive wheels, whether fixed or portable.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of equipment.	Competent person.	Inspection records, report or certificate Risk assessment Maintenance logbook.			CT*			CT*		
All	2	Based on risk assessment, but at least every 12 months.	Regular inspection of its integrity to ensure safe use. If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement - do Not use. Report issue.	Competent person.	Inspection records, report or certificate Risk assessment Maintenance logbook.						CT		
IT	7	6 months	Inspection as per [2].	No additional requirements	CE Declaration of conformity. Records to be kept for at least 3 years.					CT			
ROI	6	No additional requirements	Inspection as per [2].	No additional requirements	Records need to be kept for at least 5 years.						CT		
SK	8	Every 6 months	Inspection of portable, hand-held abrasive wheels	No additional requirements	Records need to be kept for at least 5 years.					CT			

UK	3	Weekly for 110v grinders. Daily for 240v grinders.	Safety checks to be carried out on portable electric grinders.	No additional requirements	Record of pre use checks / inspections						EVID		These are pre-use checks
UK	4	Monthly for 110v grinders. Weekly for 240v grinders.	Formal visual inspection to be carried out on portable electric grinders.	No additional requirements	Record of inspections		CT*	CT*					
UK	5	3-monthly for 110v grinders. Monthly for 240v grinders.	Formal inspection and testing to be carried out on portable electric grinders.	No additional requirements	Record of inspections			CT*	CT*				

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist company.	Inspections carried out every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Regel 100-500 Section 2.19 and Section 2.25 DGUV Vorschrift 3 - Elektrische Anlagen und Betriebsmittel DGUV Information 209-002 - Grinders	Competent person (befähigte Person).	Visual inspection before clamping the abrasive wheel and dry run. Inspection frequency based on risk assessment. Electrical safety tests every year according to DGUV Vorschrift 3, as well as before commissioning and after repairs
ES	RD 1644/2008, of October 10, which establishes the rules for the marketing and commissioning of machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment	Competent person.	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	28 July 1961 Decree "Arrêté du 28 juillet 1961 relatif aux mesures particulieres de securite relatives a l'utilisation des meules et machines a meuler" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000656198/	Qualified person.	Daily visual check. Regular maintenance and inspections.
IT	Law n. 320/1990 UNI EN 12413:2020 (Safety requirements for rigid abrasives) UNI EN 13743:2017 (Safety requirements for flexible abrasives) ISO 525:2020 (Bonded abrasive products -- Shape types, designation and marking) UNI EN 13236:2019 (Safety requirements for super-abrasive products) UNI EN ISO 6103:2014 (Permissible unbalance of grinding wheels) UNI EN ISO 16089:2016 (Safety requirements for grinding machines) ISO 13942:2019 (Bonded abrasive products -- Limit deviations and run-out tolerances) Directive 2006/42/CE on machinery D. Lgs 81/08	Qualified person.	Maintenance follow manufacturer's instructions.
PL	Regulation of Minister of Labour and Social Policy of 26 September 1997on general provisions for occupational health and safety (Journal of Laws 2003 No 169 item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228)	Competent person or person with Electrical qualification	Inspection frequency follow manufacturer's instructions, or internal policies and procedures.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Initial inspection before it is first used or assembled, and periodic inspections based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment Ordinance No. 59/1982 Coll. laying down the basic requirements to ensure the safety of work and technical equipment STN EN 33 1610/Z1: Verification and checking of electrical appliances during use	Competent person.	Abrasive wheels – portable – to be held in the hand: Control before first use, inspections at least every 6 months as defined by STN EN 33 1610/Z1. Abrasive wheels – portable: Control before first use, inspections at least every 12 months as defined by STN EN 33 1610/Z1. Abrasive wheels – not portable (GENERAL): Inspection after installation and before first use. Further inspection intervals to be defined by employer.

UK	The Provision and Use of Work Equipment Regulations 1998 Safety in the use of abrasive wheels; Revised in line with the Provision and Use of Work Equipment Regulations 1998 (PUWER 98); HSG17 (hse.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person.	Maintenance. Regular inspections based on risk assessment. Additional frequency for portable grinders based on voltage.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Automatic gate - pedestrians
APM Object	CT.WORK.AUTOGATE-PEDESTRIAN
APM Description	Powered gates and doors for pedestrians
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.DOOR.AUTODOOR BLDG.DOOR.RLRDOORS BLDG.EXT BLDG.TURNST BLDG.SPEEDGATE	**Related CT Areas:**	Not Specified		

Scope

Any site with automatic gates and doors designed for pedestrian use, including turnstiles.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Before it is first used	Initial inspection.	Competent person.	Inspection records, report or certificate Risk assessment Maintenance logbook								Check
All	2	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of the equipment	Competent person.	Inspection records, report or certificate Risk assessment Maintenance logbook	PM					EVID		
All	3	Based on risk assessments, but at least once every 12 months. Additionally, following any modifications.	Regular inspections and checks to ensure safe use and correct operation, including effectiveness of protective devices. If defects are identified, prevent subsequent use through quarantine prior repair or disposal and replacement - do Not use. Report issue	Competent person.	Inspection records, report or certificate Risk assessment Maintenance logbook	PM					EVID		
CZ	8	When gate is commissioned and further as needed.	Automatic pedestrian gates need to be appropriately marked with black and yellow tape.	No additional requirements	No additional requirements								Check
FR	4	Every 6 months	Automatic and semi-automatic doors inspections.	No additional requirements	No additional requirements	PM					EVID		

IT	5	No additional requirements	Check technical specification.	No additional requirements	CE Declaration of Conformity	PM					EVID		
ROI	6	At least every 12 months, based on manufacturer's instructions.	If falls within the scope of BS EN 13241:2003+A2:2016, it might also be subject to the requirements of the Construction Products Regulations.	No additional requirements	Declaration of Performance	PM					EVID		
SK	7	At least every 12 months, based on manufacturer's instructions.	Vertical sliding gates with motor drive with a lift height of more than 2.7m requires a professional inspection and professional test.	No additional requirements	No additional requirements	PM					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll. Regulation No. 375/2017 Coll.	Competent person, best practice to outsource to specialist.	Inspections every 12 months.
DE	Arbeitsstättenverordnung (ArbStättV), §3ff, Annex1 Section 1.7 Technische Regel für Arbeitsstätten ASR A1.7 - Türen und Tore DGUV Information 208-022 - Sicherer Umgang mit Toren DGUV Information 208-026 Sicherheit von kraftbetätigten Karusselltüren DIN 18650-1:2010-06 Respective law of the federal state with reference to the building permit (case-by-case examination)	Competent person (befähigte Person) according to ASR A1.7,	Regular visual and functional checks to detect defects. Inspection before initial start-up, after modifications and at least every 12 months.
ES	RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. UNE-EN 16005: 2013. Power operated pedestrian doorsets - Safety in use - Requirements and test methods. UNE 85121:2018. Powered pedestrian doors. Installation, use and maintenance. UNE-EN 16361: 2014+A1: 2017. Power operated pedestrian doors - Product standard, performance characteristics - Pedestrian doorsets, other than swing type, initially designed for installation with power operation Building Technical Code (CTE). Fire Safety Basic Document (DB SI3 - Evacuation). Section 6.5 "powered pedestrian doors must have a system which, in case of electric supply failure or in case of emergency	Competent person. Manufacturer, maintenance or installation staff (UNE 85121 4.1, 4.2)	Maintenance follow manufacturer's instructions. Regular inspections and checks. Maintenance Registers must be kept at least for 5 years. (According to UNE 85121).
FR	Labour code : Art. R4224-12 Article R4224-12 - Code du travail - Légifrance (legifrance.gouv.fr). Arrêté du 21 décembre 1993 relatif aux portes et portails automatiques et semi-automatiques sur les lieux de travail - Légifrance (legifrance.gouv.fr)	Qualified person. (internal or not)	Inspections every 6 months and adapted to the frequency of use and the nature of the door or gate.
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81 Circular letter n.4962-04.04.2012 UNI EN 16005:2012 (Safety) UNI EN 12978:2009 (Safety devices) UNI EN 16361:2016 (Requirements)	Authorised person.	Maintenance follow manufacturer's instructions. Inspection at suitable intervals. Periodic maintenance every 12 months for individuals, every 6 months for companies.
PL	Regulation of Minister of Labour and Social Policy of 26 September 1997on general provisions for occupational health and safety (Journal of Laws 2003 No 169 item 1650) Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of Minister of Infrastructure of 12 April 2002 on on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	Qualified & competent person.	Inspections follow manufacturer's instructions or internal procedures.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Regular maintenance. Inspections at least every 12 months.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment No. 59/1982 Coll. laying down the basic requirements to ensure the safety of work and technical equipment STN EN 12453: Industrial, commercial and garage doors and gates. Safety in use of power operated doors. Requirements and test methods	Competent person.	Inspections at least every 12 months as defined by STN 12453.

UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) The Supply of Machinery (Safety) Regulations 2008 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993	Competent person, best practice to outsource to specialist.	Regular maintenance. Initial inspection, and at least every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Cardboard and Plastic balers
APM Object	CT.WORK.BALER
APM Description	Cardboard and plastic and other waste balers.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where cardboard and plastic balers are used to flatten, stack and bind together cardboard boxes and pieces of carboard and plastic so they can be easier to store or dispose of via a recycling or waste facility.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of equipment (cleaning, topping-up liquids, etc).	Competent person.	Inspection records, report or certificate. Risk assessment Maintenance logbook			CT*	CT*				
All	2	Based on risk assessment and manufacturer's recommendations, but at least once every 12 months.	Regular inspections to ensure safe use and correct operation (technical characteristics, damage to components, maximum load, etc). If defects are identified, prevent subsequent use through quarantine prior repair or disposal and replacement - do Not use. Report issue	Competent person.	Inspection records, report or certificate. Risk assessment Maintenance logbook						CT		
CZ	8	No additional requirements	Inspection as per [1] and [2].	No additional requirements	CE Declaration of Conformity			(CT)	(CT)		(CT)		
DE	3	Daily, monthly or operating-hours dependant.	Additional inspections possible dependant on plant/equipment type - operating instructions.	Competent person (befähigte Person)	No additional requirements			CT					
DE	4	Inspection every 12 months.	Electrical equipment needs to be inspected according to DGUV Vorschrift 3.	Competent person (befähigte Person)	No additional requirements						CT		

FR	5	Regular inspections to take place at least every 3 months.	Inspections as per [2].	Accredited company.	No additional requirements			CT					
IT	6	No additional requirements	Check technical characteristics	No additional requirements	CE Declaration of Conformity. Maximum working load must be clearly marked. Records to be kept for 3 years.								N A R
ROI	7	No additional requirements	No additional requirements	No additional requirements	Inspection records must be kept for 5 years								N A R

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll. Decree No 50/1978 ČSN 33 1600 ed.2	Competent person, best practice to outsource to specialist.	Inspections every 12 months
DE	BetrSichV, §3 DGUV Vorschrift 3 - Elektrische Anlagen und Betriebsmittel DIN EN 16252 - Maschinen zum Verdichten von Abfällen oder recyclebaren Materialien - Horizontal arbeitende Ballenpressen - Sicherheitsanforderungen	Electrician (Elektrofachkraft), according to DGUV 3 Competent person (befähigte Person)	Before initial commissioning and after modification or repair. Daily and monthly visual inspections. Functional inspections based on risk assessment, but at least every 12 months. Electrical equipment needs to be inspected every 12 months according to DGUV 3.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person.	Maintenance follow manufacturer's instructions. Regular inspections and checks
FR	https://www.legifrance.gouv.fr/loda/id/LEGITEXT000006060118/ Note technique n° 9 du 2 août 1995 (yonne-controle.com) - periodic general inspections of work equipment	Accredited company, qualified person.	Inspections at least every 3 months
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81 UNI EN 16252:2013 (Horizontal machinery safety requirements) UNI EN 16486:2020 (Safety requirements) UNI EN 16500:2014 (Vertical machinery safety requirements)	Authorised person.	Maintenance follow manufacturer's instructions. Inspection at suitable intervals.
PL	Regulation of Minister of Labour and Social Policy of 26 September 1997on general provisions for occupational health and safety (Journal of Laws 2003 No 169 item 1650) Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228)	Qualified & competent person.	Inspections follow manufacturer's instructions or internal procedures.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Regular maintenance. Initial inspection before first use and after assembled. Regular inspections based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment Ordinance No. 59/1982 laying down the basic requirements to ensure the safety of work and technical equipment	Competent person.	GENERAL: Inspection after installation and before first use. Further inspection intervals to be defined by employer. Inspection record required.

UK	The Provision and Use of Work Equipment Regulations 1998 The Supply of Machinery (Safety) Regulations 2008 Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 The Lifting Operations and Lifting Equipment Regulations 1998 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource to specialist	Regular maintenance. Inspection at least every 12 months unless contain a lifting element – then thorough examination 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	General waste compactor
APM Object	CT.WORK.COMPACTOR
APM Description	General waste, plastic or cardboard compactors.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where compactors are used to flatten, stack and bind together general waste, plastic or cardboard so that it can be easier to store or dispose of via a recycling or waste facility.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of equipment.	Competent person.	Inspection records, report or certificate. Risk assessment Maintenance logbook					CT			
All	2	Based on risk assessment and manufacturer's recommendations, but at least once every 12 months.	Regular inspections to ensure safe use and correct operation (technical characteristics, damage to components, maximum load, controls, lights, etc). If defects are identified, prevent subsequent use through quarantine prior repair or disposal and replacement - do Not use. Report issue.	Competent person.	Inspection records, report or certificate. Risk assessment Maintenance logbook						CT		
DE	3	Daily, monthly or operating-hours dependant.	Additional inspections possible dependant on plant/equipment type - operating instructions.	Competent person (befähigte Person)	No additional requirements		CT*						
DE	4	Every 12 months.	Electrical equipment needs to be inspected according to DGUV Vorschrift 3.								CT		
FR	5	Regular inspections to take place at least every 3 months.	Inspections as per [2].	No additional requirements	No additional requirements				CT				

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll. Decree No 50/1978 ČSN 33 1600 ed.2.	Competent person, best practice to outsource to specialist.	Inspections every 12 months
DE	BetrSichV, §3 DGUV Vorschrift 3 - Elektrische Anlagen und Betriebsmittel (electrical portable and stationary appliances) DGUV Information 214-016 – Sicherer Einsatz von Absetzkippern BGHW Kompakt 56 DIN EN 16252 - Maschinen zum Verdichten von Abfällen oder recyclebaren Materialien - Horizontal arbeitende Ballenpressen - Sicherheitsanforderungen	Competent person (befähigte Person) Electrician (Elektro-fachkraft) for electrical parts	Daily and monthly visual inspections. Functional inspections based on risk assessment, but at least every 12 months. Electrical equipment needs to be inspected every 12 months according to DGUV 3.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD 1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person.	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	5th March 1993 Ministerial Order "Arrêté du 5 mars 1993 soumettant certains équipements de travail à l'obligation de faire l'objet des vérifications générales périodiques prévues à l'article R. 233-11 du code du travail" https://www.legifrance.gouv.fr/loda/id/LEGITEXT000006060118/ Technical Note No. 9 of 2 August 1995 on periodic general inspections of work equipment http://www.yonne-controle.com/pdf/note-technique-n-9-du-2-aout-1995.pdf	Accredited company, qualified person	Inspections at least every 3 months.
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81 UNI EN 16252:2013 (Horizontal machinery safety requirements) UNI EN 16486:2020 (Safety requirements) UNI EN 16500:2014 (Vertical machinery safety requirements)	Authorised person.	Maintenance follow manufacturer's instructions. Inspection at suitable intervals.
PL	Regulation of Minister of Labour and Social Policy of 26 September 1997 on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228)	Qualified & competent person	Inspections follow manufacturer's instructions or internal procedures
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Regular maintenance. Initial inspection before first use and after assembled. Regular inspections based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment No. 59/1982 laying down the basic requirements to ensure the safety of work and technical equipment	Competent person.	GENERAL: Inspection after installation and before first use. Further inspection intervals to be defined by employer. Inspection record required.
UK	The Provision and Use of Work Equipment Regulations 1998 The Supply of Machinery (Safety) Regulations 2008 Health and Safety at Work etc. Act 1974 The Workplace (Health, Safety and Welfare) Regulations 1992 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 (legislation.gov.uk) The Lifting Operations and Lifting Equipment Regulations 1998 (legislation.gov.uk) Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource to specialist.	Regular maintenance. Initial inspection before first use and after assembled. Regular inspections based on risk assessment unless contain a lifting element – then thorough examination 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Dock Assets
APM Object	CT.WORK.DOCK
APM Description	Dock doors and associated equipment (dock levellers, dock locks, etc.), security gates and barriers.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 6M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Docks Doors Dock levellers Dock Shelters Dock Airbags	**Related CT Areas:**	Not Specified		

Scope

Any site with automatic dock doors for loading/unloading operations, including associated equipment such as dock levellers and locks. This Compliance Standard also includes the minimum maintenance and inspection requirements for security gates and barriers.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Maintenance program follow manufacturer's instructions.	Regular maintenance of equipment (lubrication, cleaning, replacement of parts, topping-up liquids, etc.).	Competent person.	Maintenance logbook	PM					EVID		
All	2	Before it is first used and once assembled.	Acceptance inspection	Competent person.	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	3	Inspections based on risk assessments, but at least once every 12 months.	Regular inspections and checks to ensure safe use and correct operation, including effectiveness of protective devices.	Competent person.	Inspection records, report or certificate. Risk assessment	PM					EVID		
CZ	9	No additional requirements	Inspection as per [2] and [3].	No additional requirements	CE Declaration of Conformity	(PM)					EVID		
FR	6	Every 6 months	Automatic and semi-automatic doors inspections.	No additional requirements	No additional requirements	PM					EVID		

FR	7	Regular inspections of dock levellers to take place every 6 months.	Dock levellers inspections.	No additional requirements	No additional requirements	PM					EVID		
IT	8	No additional requirements	Inspection as per [2] and [3].	No additional requirements	CE Declaration of Conformity	(PM)					EVID		
SK	4	At least every 12 months, based on manufacturer's instructions.	Vertical sliding gates with motor drive with a lift height of more than 2.7m requires a professional inspection and professional test.	No additional requirements	No additional requirements	PM					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll. Decree No 50/1978 ČSN 33 1600 ed.2.	Competent person, best practice to outsource to specialist.	Inspections every 12 months
DE	Arbeitsstättenverordnung (ArbStättV), §3ff, Annex1 Section 1.7 Technische Regel für Arbeitsstätten ASR A1.7 - Türen und Tore DGUV Information 208-022 - Sicherer Umgang mit Toren DGUV Information 208-026 Sicherheit von kraftbetätigten Karusselltüren DIN 18650-1:2010-06 Respective law of the federal state with reference to the building permit (case-by-case examination)	Competent person (befähigte Person) according to ASR A1.7	Regular visual and functional checks to detect defects. Inspection before initial start-up, after modifications and at least every 12 months, based on risk assessment.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines. Prevention Technical Note NTP 1016. Loading and unloading bays: security. Prevention Technical Note NTP 985. Loading and unloading bays: security. UNE-EN 13241-1: 2004+A1:2011. Industrial, commercial and garage doors and gates - Product standard - Part 1: Products without fire resistance or smoke control characteristics	Competent person.	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	Labour code : Art. R4224-12 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018532211/#:~:text=Les%20portes%20et%20portails%20sont,pr%C3%A9vu%20%C3%A0%20l'article%20R. 21 December 1993 Decree "Arrêté du 21 décembre 1993 relatif aux portes et portails automatiques et semi-automatiques sur les lieux de travail" https://www.legifrance.gouv.fr/loda/id/LEGITEXT000006082855/	Qualified person. (internal or not).	Inspections every 6 months and adapted to the frequency of use and the nature of the door or gate.
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81 UNI EN 12978:2009 (Safety devices) UNI EN 1398:2009 (Dock levellers) UNI EN 13241:2016 (Performance requirements) UNI EN 1570:2015 (Lifting platforms for dock levellers) UNI EN 12453:2017 (Safety requirements)	Authorised person.	Maintenance follow manufacturer's instructions. Inspection at every 6 months.
PL	Regulation of Minister of Labour and Social Policy of 26 September 1997 on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228)	Qualified & competent person.	Inspections follow manufacturer's instructions or internal procedures
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Regular inspections based on risk assessment, but at least every 12 months.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN EN 12453: Industrial, commercial and garage doors and gates. Safety in use of power operated doors. Requirements and test methods	Competent person, best practice to outsource to specialist.	Inspections at least every 12 months defined by STN EN 12453. GENERAL: Inspection after installation and before first use. Further inspection intervals to be defined by employer according to manufacturer´s instruction. Inspection record required.

UK	The Provision and Use of Work Equipment Regulations 1998 The Supply of Machinery (Safety) Regulations 2008 Health and Safety at Work etc. Act 1974) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 (legislation.gov.uk)	Competent person, best practice to outsource to specialist.	Regular maintenance. Initial inspection, and at least every 12 months.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Equipment used to move goods
APM Object	CT.WORK.GOODSMOVE
APM Description	Equipment used to move goods/objects, including pick carts, rebin trollies and stow carts.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where goods/objects are moved within the warehouse/short distances with the aid of trolleys (e.g. COWs), pick carts, stow carts or rebin trollies.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of equipment (visual damage, topping-up liquids, cleaning, replacement of parts, etc.).	Competent person.	Maintenance logbook					CT			
All	2	Frequency determined by risk assessment (use and environment), but at least every 12 months.	Thorough inspection of safety-critical to ensure safe use. If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement - do Not use. Report issue	Competent person.	Inspection records, report or certificate Risk assessment						CT		
FR	3	Inspection frequency is 6 months.	Inspection as per [2] - for pick carts only.	No additional requirements	For rebin walls: - security logbook. - appliance verification.					CT			
IT	6	No additional requirements	Inspection as per [2].	No additional requirements	CE Declaration of Conformity. Records to be kept for at least 3 years						(CT)		
ROI	4	Before first use and after assembled.	Initial inspection	No additional requirements	Records must be kept for 5 years								As Needed CT

UK	5	At least monthly.	Stow carts - regular safety inspection	No additional requirements	No additional requirements			CT					

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll. ČSN EN ISO 3691-5	Competent person, best practice to outsource to H&S specialist.	Inspections carried out every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen	Competent person (befähigte Person), according to BetrSichV	Pre-use checks. Periodic inspections based on risk assessment.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD 1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines. RD 485/1997, of April 14, about minimum requirements for occupational health and safety signs.	Competent person.	Maintenance follow manufacturer's instructions. Inspections frequency based on risk assessment.
FR	Arrêté du 1 mars 2004 relatif aux vérifications des appareils et accessoires de levage - Légifrance (legifrance.gouv.fr)	Qualified person.	Stock carts and rebin walls - Inspections every 12 months. Pick carts - inspections every 6 months.
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81 UNI ISO 5053-1:2020 (Industrial trucks) UNI EN ISO 3691-5:2020 (Truck with on foot operator) UNI ISO 22915-16:2020 (Stability test) UNI EN ISO 3691-4:2020 (Safety requirements) UNI ISO 938:1994 (Hand pallet trucks) UNI EN 16307-5:2013 (Safety requirements)	Competent person.	Maintenance in accordance with manufacturer's instructions and use.
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Development and Finance of 15 December 2017 on health and safety at work with the use of motorized industrial trucks Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228)	Competent person or qualified person (if required by manufacturer)	Inspection frequency based on manufacturer's recommendations.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Regular maintenance in accordance with manufacturer's recommendations. Initial inspection, after assembly and at intervals based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment No. 59/1982 Coll. laying down the basic requirements to ensure the safety of work and technical equipment	Competent person.	GENERAL: Inspection after installation and before first use. Further inspection intervals to be defined by employer. Inspection record required.
UK	The Provision and Use of Work Equipment Regulations 1998 Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent person. Can be delivered by owner or manager if competent.	Regular maintenance in accordance with manufacturer's recommendations. Pick carts and rebin walls - Inspection frequency based on risk assessment, but at least yearly. Regular safety inspection of stow carts recommended at least monthly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Lifting equipment and machinery
APM Object	CT.WORK.LIFTING
APM Description	Lifting equipment and machinery, including those designed to lift goods only and those which involve lifting of people.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where mobile or stationary lifting equipment and machinery is used to lift and transport goods and materials over short distances. This Compliance Standard includes the minimum and additional maintenance and inspection requirements for forklift trucks, pallet trucks, reach trucks, PUPS and pallet lifts. Refer also to Amazon safety standards

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of equipment (visual damage, topping-up liquids, cleaning, replacement of parts, etc.).	Competent person.	APM Record			CT					
All	2	If used to lift ONLY goods/materials - at least every 12 months. More frequent inspections might be required based on risk assessment (use and environmental conditions). If involves lifting people as well as goods and materials - at least	Thorough inspection of safety-critical to ensure safe use. This includes lifting and non-lifting parts. If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement - do Not use. Report issue.	Competent person.	Inspection records, report or certificate Risk assessment					CT*	CT*		
DE	4	Before commissioning (Inbetriebenahme) /re-commissioning (Außerbetriebenahme).	Initial inspection according to Section 2.10 DGUV Regel 100-500 for lifting platforms.	No additional requirements	No additional requirements								As Needed CT
FR	3	Inspection frequency is 6 months for goods lifting equipment.	Inspection as per [2].	No additional requirements	No additional requirements					(CT)			
IT	9	Preliminary inspection if the equipment has not been used for more than 3 months (PUPS).	No additional requirements	No additional requirements	CE Declaration of conformity. Records to be kept for 3 years.				*CT				

PL	5	No additional requirements	Inspection as per [2] for PUPS.	Government Authority for the Technical Inspection.	If the equipment passes the test, mark with sticker.					(CT)			
ROI	6	No additional requirements	No additional requirements	No additional requirements	Register of lifting equipment. All records need to be kept for at least 5 years.								NAR
SK	7	Electrical and lifting inspections every 3 months, and professional examination every 3 years.	Inspection as per [2].	No additional requirements	No additional requirements				CT*				3Yr CT
UK	8	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme								

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 Government Regulation No. 378/2001 Coll., EN 81-1, EN 81-2, EN 81 - 80 ČSN 274007 – ČSN 274002 EN 81 - 80	Competent person, best practice to outsource to specialist company.	Checks carried out every 6 months. Testing is carried out every 6 years.
DE	BetrSichV, §3, Annex 1 TRBS 1201 DGUV Regel 100-500, Section 2.10 DGUV Vorschrift 68 - Flurförderzeuge	Competent person (befähigte Person)	Daily visual inspection. Routine inspections at least every 12 months. For lifting platforms inspection prior first use, after significant changes and recurrent every 12 months.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines. UNE EN 280:2014 Standard. Mobile elevating work platforms - Design calculations - Stability criteria - Construction - Safety - Examinations and tests UNE 58921: 2017 Standard. Instructions for installation, handling, maintenance, revisions and examinations of mobile elevating work platforms. UNE EN 13155 Standard. Removable Load Lifting Equipment Standard	Competent person.	Maintenance follow manufacturer's instructions. Pallet trucks, PUPS and forklift trucks - regular inspections and checks when required. Pallet lifts - inspections at least every 3 years.
FR	1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified) https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000439029/ Labour Code Art. R. 4323-22 à R. 4323-28 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489757/#LEGISCTA000018531487	Qualified person.	Inspections every 6 months.
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81 UNI EN ISO 3691:2020 (Safety requirements and test) UNI ISO 5053:2020 (Classifications) UNI EN 16037:2020 (Supplementary safety requirements) UNI EN 1459:2020 (Safety requirements) UNI EN 16203:2014 (Lateral stability tests) UNI ISO 5057:2000 (Fork arms repair) UNI ISO 13562:2012 (Stability test) UNI ISO 15000:2009 (Safety specifications for loading operations)	Competent person.	Maintenance in accordance with manufacturer's instructions. Pallet lifts and trucks and forklift trucks – Periodic inspection at least every 12 months. Lifting components inspection every 3 months. PUPS - inspections every 12 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical supervision in the field of operation, repair and modernization of handling equipment. (Journal of Laws 2018, item 2176) Regulation of Minister of Labour and Social Policy of 26 September 1997 on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Development and Finance of 15 December 2017 on health and safety at work with the use of motorized industrial trucks (Journal of Laws 2020, item 852)	Competent person or qualified person. Government Authority to conduct PUPS inspections.	Forklifts and PUPS - full periodic verification every 12 months. Pallet trucks and lifts - inspections in accordance with manufacturer's recommendations.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Regular maintenance in accordance with manufacturer's recommendations. Forklift trucks and pallet lifts - inspections at least every 12 months, or every 6 months if it involves lifting people. Pallet trucks - Inspection based on risk assessment.

SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment	Competent person, best practice to outsource to specialist company.	Pallet lifts and trucks - inspections at least every 12 months. PUPS - Professional inspections every 3 months and testing every 3 years. Forklift trucks - technical inspection at least every 2 years.
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) The Lifting Operations and Lifting Equipment Regulations 1998 (legislation.gov.uk) Rider-operated lift trucks: Operator training and safe use. Approved Code of Practice and guidance L117 (hse.gov.uk) l113.pdf (hse.gov.uk) Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 (legislation.gov.uk) Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent person, best practice to outsource to specialist company.	Maintenance in accordance with manufacturer's recommendations. Thorough inspections at least every 12 months for all equipment and every 6 months if it involves lifting people. Pallet trucks - Inspection based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Pest control – check database
APM Object	CT.WORK.PEST
APM Description	Sitewide
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where goods or food products are stored.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Frequency determined by risk assessment, but at least monthly.	Vendor inspection.	Competent person, usually sub contracted to pest control	Inspection records, report or certificate Risk assessment						EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A
CZ	Act No. 258/2000 Coll.	Competent person	Frequency determined by risk assessment

DE	Lebensmittel- und Futtermittelgesetzbuch - LFGB; §36 LMHV - Lebensmittelhygiene-Verordnung TRGS 523 - Schädlingsbekämpfung mit sehr giftigen, giftigen und gesundheitsschädlichen Stoffen und Zubereitungen IFS Pest Control Guideline	N/A	N/A
ES	RD485/1997, of April 14, about minimum requirements for occupational health and safety signs. RD3349/1983. Sanitary and technical regulation on manufacturing and use of pesticides. RD 830/2010, Establishing the regulatory regulations for training to perform biocide treatments. RD363/1995, of March 10, approving the regulation about notification of new substances and classification, packaging and labelling of hazardous substances. RD374/2001, of April 6, about health and safety protection for workers against chemical agents on workplaces. RD1054/2002, of October 11, which regulate the evaluation process for the register, authorisation and commercialisation of biocides. RD255/2003, of February 28, approving the regulation about classification, packaging and labelling of	Authorized and accredited technician (possession of official license is compulsory).	Maintenance in accordance with Pest Control Plan. Equipment: once during the first 5 years after purchase and, from that point, every 3 years (RD1702/2011).
FR	N/A	N/A	Regular inspections
IT	CE n. 852/2004 Reg. UE 625/2017 D.P.R 327/80 UNI/ PdR 86:2020 (Guidelines for application of UNI EN 16636) UNI EN 16636:2015 (Pest management requirements) CE n.178/2002 CE n.853/2004 CE n.2023/2006 CE N.183/2005	Competent person.	Check database monthly. Daily inspection (walkaround).
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) The Act of 25 August 2006 on food and nutrition safety (Journal of Laws 2020, item 2021) The Act of 5 December 2008 on preventing and combating infections and infectious diseases in humans (Journal of Laws 2020, item 1845) The Act of 13 September 1996 on maintaining cleanliness and order in communes (Journal of Laws 2020, item 1439)	Competent or qualified person.	Inspection frequency based on manufacturer's recommendations
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) Waste Management Act, 1996 (irishstatutebook.ie)	Competent person.	Based on risk assessment.
SK	Act No. 152/1995 Coll. on food Ordinance No. 585/2008 Coll., which lays down details on the prevention and control of transmittable diseases	Competent person.	Inspection frequency depending on stored material.
UK	Health and Safety at Work etc. Act 1974 Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk)	Competent person.	Based on risk assessment.

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Storage Structures
APM Object	CT.WORK.STORAGE
APM Description	Storage structures
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	STOR.HRACK - STOR.SHELV	**Related CT Areas:**	Not Specified		

Scope

Any site where materials and goods are stored in tiered structures, such as pallet racking, pick towers, rebin walls and shelves.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Regular maintenance.	In accordance with manufacturer's instructions and recommendations.	Competent person	Maintenance logbook CE Declaration of Conformity (at purchase)	PM					EVID		
All	2	Thorough inspection of safety-critical to ensure safe use (e.g. stability, structural damage, distribution of load's weight, etc.). If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement -	At least every 12 months. More frequent inspections might be required based on risk assessment (use and environment).	Competent person	Inspection records, report or certificate Risk assessment	(PM)					(EVID)		
All	3	Condition inspection – check for signs of damage from collision, collapse, buckling, over stocking etc.	In line with risk assessment but at least monthly.	Competent person	Inspection records	(PM)					(EVID)		
DE	5	Based on risk assessment, but at least weekly.	Visual inspections	Competent person	No additional requirements	(PM)					(EVID)		
FR	4	Inspections to be conducted every 6 months for lifting equipment only.	Inspections as per [2].	No additional requirements	No additional requirements					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll. ČSN EN ISO 3691-5	Qualified technician or H&S specialist. Accredited.	Inspections carried out every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) DGUV Regel 108-007 - Lagereinrichtungen und -geräte DGUV 208-043 – Sicherheit von Regalen DIN EN 15635 - Ortsfeste Regalsysteme aus Stahl - Anwendung und Wartung von Lagereinrichtungen	Competent person (befähigte Person) according to BetrSichV	Before first use, weekly visual inspections, expert inspections at least once a year. Regular shelf-inspection based on risk assessment.
ES	RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines. RD 486/1997. Minimum prevention measures in working places. RD2267/2004, of December 3, which approve fire safety regulation in industrial premises. Section 8.1 – appendix II: fire resistance in steel static storage systems. UNE-EN 15635: 2010. Steel static storage systems - Application and maintenance of storage equipment UNE 58011: 2004. Steel static storage systems. Classification. Definitions. Terminology	Competent person.	Maintenance in accordance with manufacturer's recommendations. Inspections at regular intervals based on risk assessment.
FR	Arrêté du 1 mars 2004 relatif aux vérifications des appareils et accessoires de levage - Légifrance (legifrance.gouv.fr) Best practice : standard NF EN 15635	Qualified person.	Inspections every 6 months (lifting equipment only) Pick towers – inspections annually.
IT	Directive 2006/42/CE on machinery (Annex II A) (Automated storage structures) Legislative Decree 9.04.2008 n° 81 UNI EN 15878:2010 (Terms and definitions) UNI EN 15512:2021 (Design principles) UNI EN 15620:2009 (Tolerances, deformations and interspaces) UNI EN 15635:2009 (Use and maintenance) UNI EN 15629:2009 (Specifications) UNI 11636:2016 (Validation) UNI 11262:2017 (Metal storage structures) UNI EN 15095:2009 (Safety requirements for automated storage structures)	Competent person.	Maintenance in accordance with manufacturer's instructions. Inspection at least every 12 months.
PL	Regulation of Minister of Labour and Social Policy of 26 September 1997 on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596)	Competent or qualified person (if required by manufacturer)	Inspection frequency based on manufacturer's recommendations or internal procedures.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Regular maintenance in accordance with manufacturer's recommendations. Initial inspection after installation and at regular intervals based on risk assessment.
SK	No. 59/1982 Coll. laying down the basic requirements to ensure the safety of work and technical equipment STN 26 9030: Storage. Principles of security in the materials handling	Competent person.	Inspections to be carried out at least every 12 months as defined by STN EN 26 9030.
UK	The Provision and Use of Work Equipment Regulations 1998 SEMA | Codes of Practice | Publications | Codes of Practice | Publications Warehousing and storage: Keep it safe INDG412 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Approved Rack Inspector or other technically competent person.	Thorough examination by Approved Rack Inspector at least every 12 months. Safety inspections conducted monthly.

AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Trailer Jacks
APM Object	CT.WORK.TRAILER
APM Description	Trailer jacks.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

Any site where trailer jacks are used to aid in the connection/disconnection of trailers from tow vehicles and in maintaining the trailer levelled to avoid unwanted movement of the load. [these are not "jacks" to lift vehicles]

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of equipment (visual damage, topping-up liquids, cleaning, replacement of parts, etc.).	Competent person.	Maintenance logbook						CT		
All	2	At least every 12 months. More frequent inspections might be required based on risk assessment (use and environment).	Thorough inspection of safety-critical to ensure safe use. If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement - do Not use. Report issue	Competent person.	Inspection records, report or certificate Risk assessment						CT		
CZ	7	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme								NAR
FR	3	Inspection frequency is 6 months.	Inspection as per [2].	No additional requirements	No additional requirements					CT			
IT	4	No additional requirements.	Check maximum tracking effort on the towing hitch (in Newton) as defined by the manufacturer	No additional requirements	CE Declaration of Conformity.						(CT)		

ROI	5	No additional requirements	No additional requirements	No additional requirements	Register of lifting equipment. Records must be kept for 5 years								NAR
UK	6	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme								NAR

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to H&S specialist.	Thorough and regular maintenance in accordance with the manufacturer's recommendations. Inspections carried out every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Vorschrift 54 - Winden, Hub- und Zuggeräte	Competent person (befähigte Person)	Initial inspection before first use. Routine inspections at least every 12 months.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person.	Maintenance follow manufacturer’s instructions. Inspections and checks as appropriate.
FR	Arrêté du 1 mars 2004 relatif aux vérifications des appareils et accessoires de levage - Légifrance (legifrance.gouv.fr)	Qualified person.	Inspections every 6 months.
IT	Directive 2006/42/CE on machinery (Annex II A) Legislative Decree 9.04.2008 n° 81	Competent person.	Maintenance in accordance with manufacturer’s instructions and use.
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, no 169, item 1650) as amended. Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Council of Ministers of 7 December 2012 on the types of technical devices subject to technical inspection (Journal of Laws 2012, item 1468) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228)	Competent or qualified person.	Inspection frequency based on manufacturer’s recommendations
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Regular maintenance in accordance with manufacturer’s recommendations. Initial inspection, after assembly and at intervals of at least 12 months.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment No. 59/1982 Coll. laying down the basic requirements to ensure the safety of work and technical equipment Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment	Competent person.	GENERAL: Inspection after installation and before first use. Further inspection intervals to be defined by employer. Inspection record required.

UK	The Provision and Use of Work Equipment Regulations 1998 Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent person.	Thorough and regular maintenance in accordance with manufacturer's recommendations. Inspection frequency at least every 12 months

AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	F-Gas Refrigeration
APM Object	CT.REFR.FGAS
APM Description	All stationary refrigeration plant that contain F-Gas refrigerants.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	New system created.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Refrigeration System.	**Related CT Areas:**	CT.HVAC.FGAS		

Scope

Any site with refrigeration systems containing fluorinated refrigerants listed in https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A32014R0517&qid=1608306002561, where the combination of type and mass gives a CO2 equivalent in the range of 50-500 te. CO2 equivalent values for various refrigerants are given here:

https://www.gov.uk/guidance/calculate-the-carbon-dioxide-equivalent-quantity-of-an-f-gas

For pressure systems refer to CT.PRESSURE.SYS. For HVAC FGAS refer to CT.HVAC.FGAS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance of equipment containing F-gas.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Maintenance logbook	PM					EVID		
All	2	12 months without leak detection system. 24 months with leak detection system	Statutory requirement for leak inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 50 tonnes of CO2. Best practice to include units <5 tonnes CO2 equivalent.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.							CT*	
All	3	6 months without leak detection system. 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 50 to 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*			
All	4	3 months without leak detection system. 6 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*	CT*		
All	5	Every 12 months.	Leak detection system inspections.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT		

All	6	Within 1 month	In the event that a leak is identified and fixed. Reinspection is required.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.								On Demand EVID
PL	7	Every 12 months without leak detection system or every 24 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 10 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT	CT	
PL	8	Every 6 months without leak detection system or every 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 10 to 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT*			
PL	9	Every 6 months. Leak detection system mandatory.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT			
SK	10	Every 3 months without leak detection system or 6 months with leak detection system.	Leak inspection of units with more than 300 kg of fluid charge.	No additional requirements	No additional requirements.					CT*	CT*		