

Prineville coupled-chain evidence (public test bed)

Meta annual facility electricity	reported / measured	High-confidence annual scale; not hourly IT
Meta annual water withdrawal	reported / measured	From 2014; not WUE or source mix
Meta location Scope 2	reported / measured	Site accounting; not marginal/campus-attributed generators
Weather (KS39/KRDM)	reported / measured	External cooling driver; wet bulb derived; not campus microclimate
Regional grid (EIA-930 / FERC PACW)	derived / proxy	Regional context; not campus demand or serving plants
Permits / facility chronology	reported / measured	Technology not static; not causal water-model evidence
Campus / utility electricity meters	missing / pending	Not identified in the public test bed
Campus water-meter / billing	missing / pending	Not identified in the public test bed
Sewer / wastewater discharge	missing / pending	Consumption/return remain unidentified
POD / direct pumping	reported / measured	POD boundary only; not campus θ^{gw}
Reuse / reclaimed water	not identified / not a target	Not identified
Source bridge Ψ (with/cons/return)	not identified / not a target	Conditioning water is not withdrawal
GWIS / OWRD groundwater observations	reported / measured	Observed layer; network dynamics not identified
USGS HUC12 / IWA context	derived / proxy	Regional hydrology/use; not an aquifer node
Hourly IT telemetry	not identified / not a target	Not an active public-data target

Statuses follow master.tex / pipeline provenance. Fitted reconstructions are omitted so they are not read as telemetry.