

GENERAL DEMOLITION NOTES:

1. ELECTRICAL DEMOLITION GENERALLY INCLUDES REMOVAL OF EXISTING ELECTRICAL DEVICES FROM WALLS AND CEILINGS BEING DEMOLISHED INCLUDING BACKBOXES, CONDUITS, AND CONDUCTORS BACK TO THE POINT WHERE THEY ENTER THE WALL OR CEILING. CONTRACTOR SHALL BE RESPONSIBLE FOR THE EXTENSION AND RECONNECTION TO CONTINUE REMAINING CIRCUIT IN SERVICE BEYOND THE DEMOLITION AREA.
2. INDICATE ALL NEW WORK AND WORK REQUIRED TO MODIFY EXISTING CONDITIONS WHERE TO CONTINUE IN OPERATION.
3. PROVIDE RELEVANT CIRCUIT INFORMATION ON EXISTING DRAWINGS TO INDICATE ALL LOADS, NEW MOTORS, CAPS, AND RELOCATED DEVICES.
4. INDICATE ALL NEW DEVICES TO BE INSTALLED. NEW WIRING MUST BE DONE TO PROVIDE ALL ELECTRICAL DEVICES WITH THE CORRECT VOLTAGE AND PHASE.
5. INDICATE ALL ELECTRICAL DEVICES SPECIFICALLY POSITIONED ON ELECTRICAL PLANS OR NOT. CONTRACTOR IS CAPABLE OF PROVIDING THE LOCATION OF ALL DEVICES IN NEW LOCATION OF ALL EXISTING DEVICES.
6. REMOVE ALL ELECTRICAL DEVICES FROM BEING RELOCATED.
7. INDICATE ALL EXISTING DEVICES IN AREAS WHERE NEW LIGHTING IS PROVIDED INCLUDING CONDUIT, BOXES AND CONDUCTORS.
8. INDICATE ON RECORD DRAWINGS CIRCUITS FOR ALL ELECTRICAL DEVICES (INCLUDING LIGHTS) IN DEMOLITION AREA.
9. CONTRACTOR SHALL COORDINATE WITH RENOVATION DRAWINGS FOR IDENTIFICATION OF EXISTING DEVICES AND FAILURES TO BE RELOCATED. ALL RELOCATED DEVICES AND FIXTURES WILL BE IDENTIFIED WITH RENOVATION DRAWINGS.

DEMOLITION LEGEND:

EXISTING ELECTRICAL SYSTEM ELEMENT BEING DEMOLISHED DENOTED BY HATCHING. REMOVE DEVICE, BOX, CONDUCTOR AND CONDUIT TO SOURCE U.N.O. FOR SWITCH LOCATIONS RE-USE EXISTING LOCATION FOR NEW SWITCHING INDICATED ON RENOVATION PLANS, WHERE NO NEW SWITCH IS INDICATED PROVIDE BLANK PLATE.

EX EXISTING TO REMAIN

ER EXISTING TO BE RELOCATED. SEE RENOVATION PLANS FOR NEW LOCATION (EN)

DEMOLITION KEYNOTES

- 1** REMOVE ALL LIGHTING IN THIS AREA AND SAVE EXISTING CIRCUIT FOR RECONNECTION TO NEW LIGHTING PER RENOVATION PLAN.

verify?

**20A CIRCUIT REQ'D
HERE — UPDATE
PANEL SCHEDULE**

**FIXTURE TYPE 2B
CONFLICTS W/ SPEC
SEC. 265000 — VERIFY**

EXIT SIGN MISSING
AT EGRESS PATH —
ADD W/ BATTERY BCK

**PANEL SCHED.
NOT UPDATED FOR
NEW CIRCUITS**

**CONDUIT ROUTE
CONFLICTS W/
PLUMBING ↑ COORD.**

1ST FLOOR

2ND FLOOR

??

1 ELECTRICAL DEMOLITION PLAN
E100 APPROXIMATE SCALE: 1/4" = 1'-0"

APPROXIMATE SCALE: 1/4" = 1'-0"

1. THIS DRAWING IS THE PROPERTY AND ©BOOMERANG DESIGN P.A. AND IS NOT TO BE REPRODUCED OR COPIED IN WHOLE OR IN PART. IT IS NOT TO BE USED ON ANY OTHER PROJECT AND IS TO BE RETURNED ON REQUEST.

2. MATERIALS, DIMENSIONS AND ALL OTHER CONDITIONS WHICH ARE NOT OTHERWISE DEFINED ON THIS DRAWING SHALL BE CONSTRUED AS HAVING THE SAME MEANING AS SIMILARLY INDICATED CONDITIONS WHICH ARE MORE FULLY DEFINED ELSEWHERE ON THIS PROJECT OR OTHER DRAWINGS OF THIS PROJECT.

3. DO NOT SCALE OFF DIMENSIONS.

REVISIONS

NO.	DATE	DESCRIPTION
-----	------	-------------

CD

PROJECT PHASE

2217

BOOMERANG DESIGN PROJECT NUMBER

9.23.2022

DRAWING RELEASE DATE

ELECTRICAL DEMOLITION PLAN

SHEET TITLE

E100

SHEET