

Chapter 19 Special Appliances, Equipment and Systems: 2023 FBC - Residential, 8th edition | UpCodes

Chapter 19 Special Appliances, Equipment and Systems

Section M1901 Ranges and Ovens

M1901.1 Clearances

Freestanding or built-in ranges shall have a vertical clearance above the cooking top of not less than 30 inches (762 mm) to unprotected combustible material. Reduced clearances are permitted in accordance with the *listing* and *labeling* of the range hoods or *appliances*. The installation of a listed and labeled cooking appliance or microwave oven over a listed and labeled cooking appliance shall be in accordance with Section M1504.1. The clearances for a domestic open-top broiler unit shall be in accordance with Section M1505.1.

M1901.2 Cooking Appliances

Cooking *appliances* shall be *listed* and *labeled* for household use and shall be installed in accordance with the manufacturer's instructions. The installation shall not interfere with *combustion air* or access for operation and servicing. Electric cooking appliances shall comply with UL 1026 or UL 858. Solid-fuel-fired fireplace stoves shall comply with UL 737.

Section M1902 Sauna Heaters

M1902.1 Locations and Protection

Sauna heaters shall be protected from accidental contact by persons with a guard of material having a low thermal conductivity, such as wood. The guard shall not have a substantial effect on the transfer of heat from the heater to the room.

M1902.2 Installation

Sauna heaters shall be installed in accordance with the manufacturer's instructions. Sauna heaters shall comply with UL 875.

M1902.3 Combustion Air

Combustion air and venting for a nondirect vent-type heater shall be provided in accordance with Chapters 17 and 18, respectively.

M1902.4 Controls

Sauna heaters shall be equipped with a thermostat that will limit room temperature to not greater than 194°F (90°C). Where the thermostat is not an integral part of the heater, the heat-sensing element shall be located within 6 inches (152 mm) of the ceiling.

Section M1903

RESERVED

Section M1904 Gaseous Hydrogen Systems

M1904.1 Installation

Gaseous hydrogen systems shall be installed in accordance with the applicable requirements of Section M1307.4 and the *Florida Building Code, Fuel Gas*, the *Florida Fire Prevention Code* and the *Florida Building Code, Building*.

Section M1905 Residential Permanently Installed Stand-by Generators

M1905.1 Listed and Labeled

Permanently installed stand-by generators regulated by this code shall be listed and labeled for the application in which they are installed and used.

M1905.2 Installation

Installation of permanently installed stand-by generators shall comply with manufacturer's installation instructions and listing conditions.

M1905.2.1 Electrical Installation

Electrical installation of permanently installed stand-by generators shall comply with the applicable provisions of NFPA 70, *National Electrical Code*, manufacturer's installation instructions, and conditions of the listing.

M1905.2.2 Flood Hazard

In flood hazard areas as established by Table R301.2(1), permanently installed stand-by generators shall be located or installed in accordance with Section R322.1.6.

M1905.2.3 Fuel Installation

M1905.2.3.1 Fuel Gas

Fuel gas installation for permanently installed stand-by generators shall comply with the applicable provisions of Chapter 24 of this code.

M1905.2.3.2 Liquid Fuel

Liquid fuel installation for permanently installed stand-by generators shall comply with the applicable provisions of NFPA-30.

M1905.2.4 Wind Resistance

Permanently installed standby generators that are exposed to wind shall be designed and installed to resist the wind pressures determined in accordance with this code.

M1905.2.5 Exhaust Location

Permanently installed residential standby generator's exhaust shall be located to not create a nuisance. Exhaust termination shall be a minimum of 10 feet (3048 mm) from any openings that could allow fumes into the building (doors, operable windows, eave vents, etc.) or air intakes.

Exception: The generator exhaust can be located a minimum of 5 feet (1524 mm) from any such openings (doors, operable windows, eave vents, etc.) or in compliance with generator manufacturer installation requirements and listing, whichever is more restrictive, if all of the following are complied with:

1. A carbon monoxide (CO) alarm(s) is installed in the residency within 10 feet (3048 mm) of each room used for sleeping purposes, or in accordance with the alarm's manufacturer installation requirements and listing, whichever is more restrictive.
2. An additional carbon monoxide (CO) alarm is installed in the residency as close as possible to the building's exterior opening nearest to the generator exhaust.
3. The carbon monoxide (CO) alarms mentioned above shall be of the types required by Sections R315.1.1 or R315.1.2 of this code.