

Chapter 34 General Requirements: 2023 FBC - Residential, 8th edition | UpCodes

Chapter 34 General Requirements

Section E3401 General

E3401.1 Applicability

Electrical systems, equipment and components for buildings under the scope of this code shall comply with the applicable provisions of NFPA 70, *National Electrical Code*.

E3401.2 Scope

Reserved.

E3401.3 Not Covered

Reserved.

E3401.4 Additions and Alterations

Any addition or alteration to an existing electrical system shall be made in conformity to the provisions of the *Florida Building Code, Existing Building* and NFPA 70, *National Electrical Code*.

Section E3402 Building Structure Protection

RESERVED

Section E3403 Inspection and Approval

RESERVED

Section E3404 General Equipment Requirements

RESERVED

Section E3405 Equipment Location and Clearances

RESERVED

Section E3406 Electrical Conductors and Connections

RESERVED

Section E3407 Conductor and Terminal Identification

RESERVED

Section E3408 GFCI Protection

E3408.1

NFPA 70-20: *National Electric Code*, Article 210 (Branch Circuits), Section 210.8, Ground-Fault Circuit-Interrupter Protection for Personnel, is amended to read as follows:

210.8 Ground-Fault Circuit-Interrupter Protection for Personnel. Ground-fault circuit-interrupter protection for personnel shall be provided as required in 210.8(A) through (F). The ground-fault circuit-interrupter shall be installed in a readily accessible location.

Items (A) through (E) unchanged.

(F) Outdoor Outlets. All outdoor outlets for dwellings, other than those covered in 210.8(A)(3), Exception to (3) that are supplied by single-phase branch circuits rated 150 volts to ground or less, 50 amperes or less, shall have ground-fault circuit-interrupter protection for personnel.

Exception No. 1: Ground-fault circuit-interrupter protection shall not be required on lighting outlets other than those covered in 210.8(C).

Exception No. 2: GFCI protection shall not be required for listed and labeled HVAC equipment.

Informational Note: See UL 60335-2-40, Household And Similar Electrical Appliances — Safety — Part 2-40: Particular Requirements for Electrical Heat Pumps, Air-Conditioners and Dehumidifiers or UL 1995, Heating and Cooling Equipment for product safety standards.(1)