

261. If a septic tank has a compartment that exceeds 3.7 m in length, what should be the additional requirement?

- (a) An additional manhole
- (b) Increase the size of the leaching chamber
- (c) Increase the number of compartments
- (d) Baffle wall is added



262. The Building Code stated that all dry standpipe outlets shall be equipped with valves having substantial chains. What kind of valve is this?

(a) Check valve

(c) Gate valve

(b) Globe valve

(d) Ball valve

