

204. What vents are pipes that serve as the drain of one fixture while venting another fixture?

(a) Stack vents

(c) Relief vents

(b) Wet vents

(d) Relief vents



205. According to the Fire Code of the Philippines, what is the required slope of all horizontal runs of dry standpipes system for the purpose of drawing?

(a) 10%

(c) 5%

(b) 20%

(d) 2%

