

231. For assembly places for public use, how many water closets are required if the capacity is 115 males?

(a) 4

(c) 2

(b) 3

(d) 5



232. Which of the following is not a function of all faucets?

(a) Temperature control

(c) Level control

(b) Volume control

(d) On/off control

