

118. What is the suitable gasket material for a flange union used in gasoline conduction?

- (a) Metallic or rubber composition
- (b) **Metallic**
- (c) Rubber or asbestos sheet
- (d) Rubber or asbestos composition



119. Approved manholes may be installed in lieu of cleanouts when first approved by the administrative authority. The maximum distance between manholes shall not exceed how many meters.

(a) 30 m

(c) 61 m

(b) 91 m

(d) 100 m

