

589. The type of Joints for soft copper water tubing shall be made with fittings meeting approved standards. The tubing shall be expanded with a proper flaring tool.

(a) Flared joints

(c) Cement Mortar Joints

(b) Solder & Sweat joints

(d) Burned Lead Joints



589. The type of Joints for soft copper water tubing shall be made with fittings meeting approved standards. The tubing shall be expanded with a proper flaring tool.

(a) Flared joints

(c) Cement Mortar Joints

(b) Solder & Sweat joints

(d) Burned Lead Joints

