

588. A fixture vent pipe increased one pie size its entire length
- (a) May exceed the maximum horizontal length limited by code
 - (b) Will be a better workmanship job
 - (c) Will increase venting efficiency
 - (d) Will reduce the cost of installation



589. The type of Joints for soft copper water tubing shall be made with fittings meeting approved standards. The tubing shall be expanded with a proper flaring tool.

(a) Flared joints

(c) Cement Mortar Joints

(b) Solder & Sweat joints

(d) Burned Lead Joints

