

245. The commercial size of cast iron pipe is \_\_\_\_\_ .

(a) 1.80 L

(c) 1.50 L

(b) 2.00 L

(d) 1.60 L



246. A septic tank is a watertight receptacle for which sewage is digested through a biological action mainly by microorganisms such as

(a) Facultative bacteria

(c) Anaerobic bacteria

(b) Aerobic bacteria

(d) Enzymes

