

604. According to the Building Code of the Philippines what is the range in height above grade should the Siamese fire department connection be installed?

(a) 30 cm to 1.2 m

(b) 60 cm to 1.5 m

(c) 80 cm to 1.8 m

(d) 50 cm to 1.0 m



605. What is the pipe fitting with outside thread and projecting square head used for closing the edge of another fitting?

(a) Plug

(c) Knot

(b) Cap

(d) Bushing

