

205. According to the Fire Code of the Philippines, what is the required slope of all horizontal runs of dry standpipes system for the purpose of drawing?

(a) 10%

(c) 5%

(b) 20%

(d) 2%



206. Located at the lower end of the pump used to prevent loss of priming the pump?

(a) Foot valve

(c) Angle valve

(b) Gate valve

(d) Globe valve

