

223. Who was awarded as the most outstanding Registered Master Plumber for the Year 2011?

(a) Dave Vela

(c) Alberto Cabael

(b) Alberto Azarcon

(d) Thelma Cardente



224. Drainage piping serving fixtures located below the crown level of the main sewer shall discharge into an approved water-tight

(a) Septic tank

(c) Cesspool

(b) Sump

(d) Leaching tank

