

127. Leaching field is categorized as one of the on-site effluent disposal for septic tanks. How far should the distance from a shallow well be to prevent contamination of water?

(a) 25 m

(c) 15 m

(b) 50 m

(d) 40 m



128. Whenever the piping is pressurized by a pump or ejector, what kind of pipe should not be used in the excreta drainage system?

(a) Vitrified clay pipe

(c) Galvanized wrought iron

(b) Hubless cast iron

(d) None of these

