

89. Shall be installed in the water supply piping within 0.30 m away from regulating equipment, water heater, conditioning tank and similar equipment which require removal for servicing or replacement.

(a) Elbow

(c) Union

(b) Nipple

(d) Coupling



89. Shall be installed in the water supply piping within 0.30 m away from regulating equipment, water heater, conditioning tank and similar equipment which require removal for servicing or replacement.

(a) Elbow

(b) Nipple

(c) Union

(d) Coupling

