

671. The inspection of a gas piping system prior to covering or concealing such pipe is called

(a) Routine inspection

(c) Site inspection

(b) Hydro piping inspection

(d) Rough piping inspection



672. A positive displacement pump is

(a) Rotary pump

(c) Turbine pump

(b) Centrifugal pump

(d) Piston pump

