

239. Gravity storage tanks shall be vented with a return-bend vent pipe & shall be screened with fine corrosion resistant screen with openings of:

(a) 8–14 mess per 25 mm

(c) 8–14 mess per 38 mm

(b) 14–18 mess per 25 mm

(d) 14–18 mess per 38 mm



240. What should be the minimum clearance that should be made with respect to the floor line to allow convenient opening or closing of a cleanout?

(a) 100 mm

(c) 50 mm

(b) 200 mm

(d) 300 mm

