

478. Always located near the stairs for use by firemen in case of fire?

(a) Standpipe

(c) Fire hose

(b) Hydro-pneumatic pump

(d) Fire tank



479. What is the maximum water pressure must standpipe fittings and connections must withstand when ready for service?

(a) 21 kg/cm<sup>2</sup>

(c) 15 kg/cm<sup>2</sup>

(b) 34 kg/cm<sup>2</sup>

(d) 8 kg/cm<sup>2</sup>

