

687. Every building in which plumbing fixtures are installed shall have a connection to a:

(a) Drywell

(c) Storm sewer

(b) Cesspool

(d) Public or Private sewer



688. Which method is not commonly used for bringing water from its source to the customer?

- (a) Gravity system
- (b) Distributing reservoir system
- (c) Domestic water softener system
- (d) Direct pressure system

