

88. PD 1095 prescribes that a dry standpipe is required for every building of how many floors?

(a) 3 stories or more

(c) 2 stories or more

(b) 4 stories or more

(d) 5 stories or more



89. Shall be installed in the water supply piping within 0.30 m away from regulating equipment, water heater, conditioning tank and similar equipment which require removal for servicing or replacement.

(a) Elbow

(c) Union

(b) Nipple

(d) Coupling

