

490. 1 psi is equivalent to a water head of

(a) 2.31 ft

(c) 2.50 ft

(b) 3.52 ft

(d) 3.9 ft



491. The minimum allowable size of any building drain, horizontal branch, vertical soil, or waste stack serving one or more water closets shall be:

(a) 4"

(c) 3

(b) 4 1/2"

(d) 5

