20. Bacteria which has no function in sewage treatment

(a) Non-aerobic bacteria

(c) Facultative bacteria

(b) Pathogenic bacteria

(d) Aerobic bacteria

21. The invert of the inlet pipe of the septic tank shall be at a level not less than \_\_\_\_ above the invert of the outlet pipe.

(a) 101.6 mm

(c) 304.8 mm

(b) 50.8 mm

(d) 228 mm