

634. The quantity of water required to be supplied to every plumbing fixture shall be represented by:

(a) Pound per square inch

(c) Fixture units

(b) Gallons per minutes

(d) Feet per second



635. On a sanitary waste line, what is located in an accessible area and attaches to the end of the waste pipe in the direction opposite of flow?

(a) Clean out

(b) Sewer pipe

(c) Vent pipe

(d) Floor drain

