

345. National Plumbing Code prepared by NAMPOP was Promulgated and approved by Malacañang.

(a) June 18, 1955

(c) January 28, 1959

(b) June 8, 1959

(d) January 18, 1955



346. A pressure gauge registers 50 psig in a region where the barometer is 14.25 psi. Find the absolute pressure

(a) 64.25 kPa

(c) 86.25 kPa

(b) 10.125 psi

(d) 64.25 psi

