

77. The minimum slope of 3" horizontal pipe shall not be less than;

(a)  $3/4$  inch per foot

(c) 1 inch per foot

(b)  $1/2$  inch per foot

(d)  $1/4$  inch per foot



78. Potable water supply piping is colored

(a) Blue

(c) Grey

(b) White

(d) Cream

