

189. Minimum height of an atmospheric vacuum breaker above the flood level rim of such trap fixture.

(a) 51 mm

(c) 102 mm

(b) 76 mm

(d) 152 mm



190. What kind of concealed connections on fixtures it is required to provide an access panel or utility at least 0.30 meters in its least dimension for easy inspection and repair?

(a) Slip joint

(c) Hubless

(b) Ball and socket

(d) Flanged

