

374. Within how many meters away shall unions be installed from regulating equipment, water heater, conditioning tank and similar equipment which require removal for servicing or replacement?

- (a) 2 ft
- (b) 1 m

- (c) 5 ft
- (d) 0.3 m



375. When can vertical piping be considered to be wet-vented?

- (a) Between openings of vent pipes
- (b) Between any two consecutive inlet levels
- (c) On stack vent
- (d) When serving two water closets at different levels

