

157. As per NPCP 1959, fixtures used in factories, dormitories, office buildings and similar installation are classified as.

(a) Class 1

(c) Class 2

(b) Class 3

(d) All of the above



158. The static water pressure at the water meter is 80 psi. at the outlet 40 ft above the meter, the static water pressure would be approximately

(a) 80 psi

(c) 120 psi

(b) 60 psi

(d) 40 psi

