

305. Rock deck strainers for use on sundecks, parking decks shall be of an approved flat surface type equipped with a strainer having a total net inlet area opening of not less than?

- (a) 1 times of the area of outlet pipe
- (b) $1\frac{1}{2}$ times the area of outlet pipe
- (c) 2 times the area of the outlet pipe
- (d) $2\frac{1}{2}$ times the area of the outlet pipe



306. An electrically or mechanically operated device used to elevate sewage and liquid waste from a lower level to a point of discharge into a sewer or other disposal system.

(a) Ejector

(c) Compressor

(b) Ram

(d) Hand pump

