

514. What is the minimum pipe size of the standpipe if the highest outlet is located more than 23 meters above the Fire Service connection?

(a) 3 inches

(b) 6 inches

(c) 5 inches

(d) 4 inches



515. Consists of a loaded air inlet valve, an internally loaded check valve, two properly located test cocks, and two isolation gate valves.

- (a) PVB or Pressure Vacuum Breaker Backflow Prevention Assembly
- (b) RP or Reduced Pressure Principle Backflow Prevention Assembly
- (c) DC or Double Check Valve Backflow Prevention Assembly
- (d) AVB or Atmospheric Vacuum Breaker

