Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking)

No: CEE/BMAZ-N/SEE(O)/AE-1/24-25/NOC/ 3762-65
Encl:
Ph.No.
Email: ceenz@bescom.co.in
cebmaznorth@gmail.com

Office of the
The Chief Engineer (Ele), (C,O & M)
BMAZ-NORTH, BESCOM,
#8,Nandi Durga Road, Benson Town
Bangalore.

Date: 10 FEB 2025

To,

M/s Bricks & Milestones Projects LLP, Rep by Praveen
Sy No. 55/1,2,3,4,56/2,3, 62/1,2,3,4,5,6,7 & 63/2,3,4,5,6
Gunjur Village, Varthur Hobli,
Bangalore East Taluk, Bengaluru

"NO OBJECTION CERTIFICATE'

Sir,

Sub: **Issuing No objection Certificate for arranging power supply to residential building to an extent of 1995KVA in favour of M/s Bricks & Milestones Projects LLP, Rep by Praveen, at Sy No. 55/1,2,3,4, 56/2,3, 62/1,2,3,4,5,6,7 & 63/2,3,4,5,6 Gunjur Village, Varthur Hobli, Bangalore East Taluk, Bengaluru in Varthur O&M Unit of E4 Sub Division, Whitefield Division-Reg.**

Ref: Letter No: SEE/BEC/EE(O)/AEE/24-25/7295-96 Dated: 03.02.2025 of the SEE, BEC

****

With reference to the above subject proposal, NOC is hereby issued for arranging power supply to **3 No of residential buildings (Block 1,2,3 Wing A to F) to an extent of 1995KVA in favour of M/s Bricks & Milestones Projects LLP, Rep by Praveen, at Sy No. 55/1,2,3,4, 56/2,3, 62/1,2,3,4,5,6,7 & 63/2,3,4,5,6 Gunjur Village, Varthur Hobli, Bangalore East Taluk, Bengaluru in E-4 Sub-Division, Whitefield Division** subject to the following conditions.

1. **Regular Source**: You shall tap 11KV power supply from existing F-16 feeder of Kachamarahalli MUSS by installing new 3Way DAS RMU to trunk line passing at near KRK villa Gunjur for F16 BDA Apt feeder and extend the 11KV Power supply through 3x400Sqmm XLPE HTUG Cable to a distance of 1.8KM up to consumer premises and extend by using 3x95 sqmm XLPE cable and terminated at 5 Way DAS RMU and extend to DTC 1,2,3 along with LT extension at proposed premises under self-execution.
2. **Alternate source**: You shall to tap 11KV power supply from existing F-05 feeder of Kachamaranahalli MUSS, by installingnew 3Way DAS RMU trunk line passing at near BM properties Gunjur for F-05 KM Halli feeder and then extend 11KV power supply through 3x400sqmm XLPE HTUG Cable to a distance of 1.0KM up to proposed premises and terminated at 5Way DAS RMU and extend to DTC 1,2,3 along with LT extension at proposed premises under self-execution.
3. Inside the premises you shall provide suitable sufficient place for 1 No of 5 way DAS Compatible RMU & 3x500KVA oil type transformer with accessories on cement bedding and erect them under self-execution as per BESCOM norms.

4. **You are liable to shift the EHT/HT line passing through the proposed premises as per KPTCL/BESCOM norms at your own cost.**
5. **You shall furnish necessary approvals and safety clearance from KPTCL authorities before availing power supply.**
6. **For the future loads to the proposed premises, if the load requirement in future exceeds 7500KVA, you have to establish 66/11KV sub-station at your premises under self-execution and avail power supply on 66KV basis as per KERC norms**
7. In future, at the time of applying for power supply in the said premises, the consumer shall mandatorily follow the prevailing KERC/BESCOM Rules and Regulations without fail.
8. Power supply will be arranged based only on KBESCOM norms to the buildings that may come up in future inside the consumer's premises.
9. The purpose of issuing this NOC is only to obtain sanctioned plan from BDA or BBMP or any other Competent Authorities and this is not a binding on BESCOM for arranging power supply. Power supply will be arranged in future based only after re-examining the latest Technical feasibility as per BESCOM norms.
10. The validity of NOC is for two years from the date of approval letter as per the decision of the 46th TCC meeting held on 7-9-2009 and the power supply position will be reviewed at the time of sanctioning regular connectivity.
11. BESCOM in any way is not responsible for any kind of problems that may arise due to this NOC.
12. As per KERC order no: KERC/CoS/DDD/1/2018-19/908, Bengaluru Dt: 22.10.2019 in the premises of proposed MS building applicant shall provide minimum 2 No's of charging points capable of charging Electric Vehicles i.e., four/ three/ two wheeler with adequate space in such building.

Yours faithfully

Chief Engineer (Ele), (C, O & M) 10/2/20
BMAZ-NORTH, BESCOM,
Bangalore