Portfolio Project

Petersgasse
93415 Straubing
Phone

EPLAN Education

Company / customer	
Project description	VFD conveyor control cabinet
Job number	IEC_bas001
Commission	Eplan
Manufacturer (company)	Portfolio Project
Path	Eplan sample project
Project name	CAB1_VFD_CONVEYOR
Make	
Type	
Place of installation	
Responsible for project	
Part feature	

Created on 11/2/2026
Edit date 11/4/2026 by (short name) Niks Workstation
Number of pages 17

Table of contents

F06_003

Page	Page type	Page description	Date	Edited by
=CONV+CAB1/1	Title page / cover sheet	Title page / cover sheet	11/4/2026	Niks Workstation
=CONV+CAB1/2	Table of contents	Table of contents : =CONV+CAB1/1 - =CONV+CAB1/10	11/4/2026	Niks Workstation
=CONV+CAB1/3	Schematic multi-line	Power infeed and main switch	11/4/2026	Niks Workstation
=CONV+CAB1/4	Schematic multi-line	Drive circuit -U1 / motor -M1	11/4/2026	Niks Workstation
=CONV+CAB1/5	Schematic multi-line	230 V auxiliaries: PSU, fan	11/4/2026	Niks Workstation
=CONV+CAB1/6	Schematic multi-line	24 V DC distribution	11/4/2026	Niks Workstation
=CONV+CAB1/7	Schematic multi-line	Safety circuit: E-stop	11/4/2026	Niks Workstation
=CONV+CAB1/8	Schematic multi-line	PLC supply and PROFINET	11/4/2026	Niks Workstation
=CONV+CAB1/9	Schematic multi-line	PLC digital inputs	11/4/2026	Niks Workstation
=CONV+CAB1/10	Schematic multi-line	PLC digital outputs	11/4/2026	Niks Workstation

ITEAN Education


-W0
5G4



EPLAN Education

2 4


			Date	11/4/2026	Eplan	Portfolio Project	Power infeed and main switch		= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001	Page 3
Modification	Date	Name	Original		Replacement of	Replaced by			Page 3 / 17



EPLAN Education

3 5


			Date	11/4/2026	Eplan	Portfolio Project	Drive circuit -U1 / motor -M1		= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001	Page 4
Modification	Date	Name	Original		Replacement of	Replaced by			Page 4 / 17



EPLAN Education

4 6


			Date	11/4/2026	Eplan		Portfolio Project	230 V auxiliaries: PSU, fan	= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet				IEC_bas001
Modification	Date	Name	Original		Replacement of	Replaced by			



EPLAN Education

5 7


			Date	11/4/2026	Eplan	Portfolio Project	24 V DC distribution	= CONV	
			Ed.	Niks Workstation				+ CAB1	
			Appr.		VFD conveyor control cabinet			IEC_bas001	Page 6
Modification	Date	Name	Original		Replacement of	Replaced by			Page 6 / 17



EPLAN Education

6 8


			Date	11/4/2026	Eplan		Portfolio Project	Safety circuit: E-stop	= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet				IEC_bas001
Modification	Date	Name	Original		Replacement of	Replaced by			Page 7
									Page 7 / 17



EPLAN Education


7 9

			Date	11/4/2026	Eplan	Portfolio Project	PLC supply and PROFINET		= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001	Page 8
Modification	Date	Name	Original		Replacement of	Replaced by			Page 8 / 17



EPLAN Education

			Date	11/4/2026	Eplan	Portfolio Project	PLC digital inputs		= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001	Page 9
Modification	Date	Name	Original		Replacement of	Replaced by			Page 9 / 17



EPLAN Education

			Date	11/4/2026	Eplan	Portfolio Project	PLC digital outputs		= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001	Page 10
Modification	Date	Name	Original		Replacement of	Replaced by			Page 10 / 17

Terminal diagram

F13_001

Strip

=CONV+CAB1-X0

Supply terminals

Function text	Cable name	Cable type	Target designation	Connection point	Terminal	Jumper	Target designation	Connection point	Cable name	Cable type	Page / column
			-Q0	1	1	,					/3.0
			-Q0	3	2	,					/3.0
			-Q0	5	3	,					/3.0
			-F2	3	4	,					/3.1
			-U1	PE1	PE	,					/3.1

EPLAN Education

			Date	11/4/2026	Eplan	Portfolio Project	Terminal diagram =CONV+CAB1-X0	= CONV
			Ed.	Niks Workstation				+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001
Modification	Date	Name	Original		Replacement of	Replaced by		Page 11
								Page 11 / 17

Terminal diagram

F13_001

Strip

=CONV+CAB1-X1

Motor terminals

Function text	Cable name	Cable type	Target designation	Connection point	Terminal	Jumper	Target designation	Connection point	Cable name	Cable type	-W1	4G1.5	Page / column
			-M1	U1	1	,	-U1	U			BK		/4.1
			-M1	V1	2	,	-U1	V			BN		/4.1
			-M1	W1	3	,	-U1	W			GY		/4.2
			-M1	PE	PE	,	-U1	PE2			GNYE		/4.2

EPLAN Education

			Date	11/4/2026	Eplan	Portfolio Project	Terminal diagram =CONV+CAB1-X1	= CONV
			Ed.	Niks Workstation				+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001
Modification	Date	Name	Original		Replacement of	Replaced by		Page 12
								Page 12 / 17

Terminal diagram

F13_001

Strip

=CONV+CAB1-X2

Control terminals

Function text	Cable name	Cable type	Target designation	Connection point	Terminal	Jumper	Target designation	Connection point	Cable name	Cable type	Page / column
			-A1	DI a.0	1	,	+DOOR-S1	14			/9.1
			-A1	DI a.1	2	,	+DOOR-S2	12			/9.2
			-A1	DI a.2	3	,	+DOOR-S3	14			/9.3
			-A1	DI a.3	4	,	+DOOR-S4	24			/9.4
			-A1	DI a.7	5	,	+FIELD-B2	BK			/9.8
			+DOOR-H1	x1	10	,	-A1	DQ a.0			/10.1
			+DOOR-H2	x1	11	,	-A1	DQ a.1			/10.2
			+DOOR-H3	x1	12	,	-A1	DQ a.2			/10.3

EPLAN Education

			Date	11/4/2026	Eplan	Portfolio Project	Terminal diagram =CONV+CAB1-X2	= CONV
			Ed.	Niks Workstation				+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001
Modification	Date	Name	Original		Replacement of	Replaced by		Page 13
								Page 13 / 17

Cable overview


F10_001



Cable name	Source (from)	Target (to)	Cable type	all conductors	Conductors used	Cross-section [mm]	Length [m]	Function text	Graphical page of cable diagram
-W0			5G4		0				
-W1	-X1	-U1	4G1.5		4				
-W10	-A1	-U1	PROFINET cable		1				
-W11	-A1	+DOOR-A2	PROFINET cable		1				

EPLAN Education

Device tag list

F03_001

Device tag Part number Type number	Function text Article designation	X-Ref	Symbol
-A1	CPU 1215C DC/DC/DC	/8.1	
-B1	closes above 35 °C	/5.5	
-E1	Cabinet fan	/5.5	
-F1		/4.1	
-F2		/5.1	
-F11		/6.1	
-F12		/6.3	
-F13		/6.5	
-K1	Line contactor	/7.5	

Device tag Part number Type number	Function text Article designation	X-Ref	Symbol
-K10	Safety relay	/7.4	
-M1		/4.1	
-Q0		/3.0	
-T1	Power supply 24 V DC 5 A	/5.1	
-U1	VFD PROFINET port	/4.1	
-W0		/3.0	
-W1		/4.1	
-W10		/8.6	
-W11		/8.3	

EPLAN Education

Device tag list

F03_001

Device tag Part number Type number	Function text Article designation	X-Ref	Symbol
-X0	Supply terminals		
-X0		/3.0	1
-X0		/3.0	2
-X0		/3.0	3
-X0		/3.1	4
-X0		/3.1	PE
-X1	Motor terminals		
-X1		/4.1	1
-X1		/4.1	2

Device tag Part number Type number	Function text Article designation	X-Ref	Symbol
-X1		/4.2	3
-X1		/4.2	PE
-X2	Control terminals		
-X2		/9.1	1
-X2		/9.2	2
-X2		/9.3	3
-X2		/9.4	4
-X2		/9.8	5
-X2		/10.1	10

EPLAN Education

Device tag list

F03_001

Device tag Part number Type number	Function text Article designation	X-Ref	Symbol
-X2		/10.2	
-X2		/10.3	
+FIELD-B2	Part present PNP 3-wire	/9.8	
+DOOR-A2	HMI panel	/8.4	
+DOOR-H1	Running	/10.1	
+DOOR-H2	Fault	/10.2	
+DOOR-H3	Reset required	/10.3	
+DOOR-S0	Emergency stop	/7.1	
+DOOR-S1	Start	/9.1	

Device tag Part number Type number	Function text Article designation	X-Ref	Symbol
+DOOR-S2	Stop	/9.2	
+DOOR-S3	Manual/Auto	/9.3	
+DOOR-S4	Reset	/7.3	

EPLAN Education

15.1

			Date	11/4/2026	Eplan	Portfolio Project	Device tag list : =CONV+CAB1-X2 - =CONV+DOOR-S4		= CONV
			Ed.	Niks Workstation					+ CAB1
			Appr.		VFD conveyor control cabinet			IEC_bas001	Page 15.2
Modification	Date	Name	Original		Replacement of	Replaced by			Page 17 / 17