

57

NIMRA IDRIS
SIDDIQUI

17 EEB 409

GI-2134

GROUP-07

Air clearance Calculations

Air clearance are required to provide adequate clearance of a conductor from the ground & other conductors under all loading conditions so as to ensure reliability of the system & safe operation

Shielding angle \rightarrow is defined as the angle between the vertical line passing through the ground wire & the line passing through the outermost power conductor.

a = Minimum air clearance b/w phase conductor & tower structure

$2a$ = Length of cross arms

b = width of upper portion of tower

c = Distance of phase conductor from centre of the tower.


l = Length of insulator string

H_1 = Height of lowest conductor from the ground.

H_2 = Height of middle conductor from the ground.

H_3 = Height of upper conductor from the ground

H_4 = Height of tower



θ = shielding angle

x = vertical height of the cross arm

y = vertical distance b/n the conductors

d' = height of the ground wire from the top most conductor.

Calculations

→ Minimum clearance b/n phase conductor & tower structure, a

$$a = (\text{phase voltage} \times 1.65 + 10) \text{ cm}$$

$$a = \frac{V_L (\text{KV})}{\sqrt{3}} \times 1.65 + 10 \text{ cm}$$
$$= 135.746 \text{ cm}$$

$$a = 135.75 \text{ cm}$$

→ width of upper portion of tower, b

$$b = 1.5 \times a \text{ cm}$$
$$= 1.5 \times 135.75 \text{ cm}$$

$$b = 203.625 \text{ cm}$$

→ Distance of phase conductor from the centre of tower, c

$$c = 2a + \frac{b}{2} \text{ cm}$$

$$c = 2 \times 135.75 + \frac{203.62}{2} \text{ cm}$$


$$c = 271.50 + 101.8125 \text{ cm}$$

$$c = 373.312 \text{ cm}$$

→ Length of string, l

$$l = \sqrt{2} \times a \text{ cm}$$

$$l = 191.98 \text{ cm}$$



→ Length of cross arm, $2a$

$$m = 2 \times a \text{ cm}$$

$$m = 271.50 \text{ cm}$$

where, m : length of cross arm

→ Vertical distance b/w the phase conductors, y

$$y = \frac{(l+a)}{\sqrt{1 - \left[\left(\frac{l+a}{2 \times a} \right) \left(\frac{x}{y} \right) \right]^2}} \quad \left(\because \frac{x}{y} = \frac{1}{3} \right)$$

$$= \frac{191.979 + 135.75}{\sqrt{1 - \left[\left(\frac{191.979 + 135.75}{2 \times 135.75} \right) \left(\frac{1}{3} \right) \right]^2}}$$

$$= \frac{327.729}{0.9154}$$

$$y = 357.997 \text{ cm}$$

In triangle ABC,

$$\cos \phi = \frac{a+l}{y} \quad \text{--- (1)}$$


In triangle CDE,

$$\tan \phi = \frac{x}{2a} \quad \text{--- (2)}$$

from eqⁿ (1)

$$y = \frac{a+l}{\cos \phi} = \frac{a+l}{\sqrt{1-\sin^2 \phi}}$$

$$= \frac{a+l}{\sqrt{1-(\cos \phi \tan \phi)^2}} \Rightarrow \frac{a+l}{\sqrt{1-\left(\frac{x}{y} \cdot \frac{a+l}{2a}\right)^2}}$$



→ Vertical height of the cross arm, x

$$x = \frac{y}{3} = \frac{357.997}{3}$$

$$x = 119.329 \text{ cm}$$

→ Height of the ground wire from the uppermost conductor, d'

$$d' = \frac{c}{\tan \theta} \text{ cm}$$

$$d' = \frac{373.3125}{\tan 30} \text{ cm}$$

$$d' = 646.6 \text{ cm}$$