N

PROFILE OF FOOTBRIDGE SUPPORTS AND CONNECTIONS FOR FUTURE FOOTBRIDGE ABOVE (UNDER SEPERATE SUBMISSION)

PAVEMENT (2.1m WIDTH APPROX.)

PIPE DUCT (FRR 240/240/240)

SYSTEM 3: 2000x500 SED/EAD F/B TO H/L T/A
SYSTEM 3: 1700x500 SED/ EAD (6050L/s) F/B & T/A
SYSTEM 3: 1700x500 SED/ EAD (6050L/s) F/B & T/A

3,000mH VERTICAL OPENWING

VENT DUCT M.L. AT H/L

BOUNDARY OF ADJACENT LOT

PUBLIC LANE

9900mmH FEATURE WALL W/ PERFORATED GRILL FREE AREA >2/3 from level 11.32 to 15.10

RC FENCE WALL 5000mm H.

(FOR PODIUM & BASEMENT)

R.C. PLINTH

AIR RELEASE FAN RM. (FOR ST-B1)

ST-09

ST-B3

FIRE RATED ENCLOSURE (FRR 240/240/240 BY MAIN CON)

SYSTEM 2: 1000x600 SED (7800L/s) H/L T/A

SYSTEM 2: 1000x600 SED (7800L/s) F/B TO H/L

PIPE DUCT (FRR 240/240/240)

MA TAU WAI ROAD (30.65m WIDTH APPROX.)

PLANTER

SHOP G20

SHOP G21

SHOP G19

SHOP G18

SHOP G17

SHOP G16

SHOP G15

SHOP G11

SHOP G10

SHOP G09

SHOP G08

SHOP G12

ENTRANCE LOBBY (TOWER 3)

CARETAKER'S COUNTER

RAMP DN 1:12

RAMP UP 1:12

RAMP 1:21

FALL 1:21

FALL T.20 T

FALL 1:20.5

SYSTEM 3: 1350x700 MAD (9720L/s) (S.E.S.)

SYSTEM 3: 1350x700 MAD (9720L/s) H/L T/B

PIPE DUCT (FRR 240/240/240)

SYSTEM 3: 1600x500 MAD (9720L/s) T/B

PIPE DUCT (FRR 240/240/240)

VOID 0.25 -0.05

REFER TO DWG NO.2503373A/SES/301

REFER TO ELEVATION E5

REFER TO ELEVATION E12 (DWG NO.2503373A/SES/302

SYSTEM 3: WP MAL 4800x800 1 9720 5.06 AFFL +3650

50% FREE AREA RATIO BOTTOM LEVEL +4.45 TOP LEVEL +10.25

BUILDING LINE ABOVE (1/F)

BUILDING LINE ABOVE AT 2/F

1/F BUILDING LINE ABOVE

NOTIONAL SHOPFRONT

PROJECTING PLANTER ABOVE

VOID ABOVE W/ -/30/- F.R.R. 450H. VERTICAL BARRIER AT H/L

VOID ABOVE W/ -/30/- F.R.R. 450H. VERTICAL BARRIER AT H/L

FOOTBRIDGE ABOVE

GLASS CANOPY ABOVE

CANOPY ABOVE

TRANSFER PLATE ABOVE

BUILDING LINE ABOVE (1/F)

ST-B6 INDEPENDENT STAIRCASE FOR B3

ST-B11 INDEPENDENT STAIRCASE FOR B1

ST-04

ST-10

ST-11

ST-12 (FOR ST-B1)

F.S.A.P

F.S.INLET FOR ST-05, ST-06, ST-B4 & ST-B8

SPRINKLER CONTROL VALVE CABINET & SPRINKLER INLET (FOR TOWER 3)

TOP VENT FOR ST-B4

TOP VENT FOR ST-B8

TOP VENT FOR ST-B11

TOP VENT FOR ST-B6

FIREMAN'S EMERGENCY SWITCH FOR EV CHARGER

SPRINKLER INLET (FOR TOWER 2)

SPRINKLER INLET (FOR PODIUM AND BASEMENT) F.S. INLET (FOR ST-B1)

F.S. INLET FOR ST-10, ST-11, ST-B1 & ST-B7

3m x 3m ACCESS AREA FOR DELIVERY

TRANSFER PLATE ABOVE

RUN IN

RUN OUT

DRIVEWAY RAMP DN 1:10

RAMP DN 1:30

BALCONY ABOVE AT 3/F

CANOPY ABOVE

STAIRCASE PRESSURIZATION ROOM

L.V. SWITCH ROOM

SPRINKLER CONTROL VALVE RM.

METAL GATE

H.V. CABLE RISER ROOM

ENTRANCE LOBBY (TOWER 2)

PRESSURIZATION

FLV. RM.

A.D. (S.P.S)

A.D./(SMOKE EXTRACTION SYSTEM)

WAN ON STREET (12.17m WIDTH APPROX.)

PAVEMENT (7m WIDTH APPROX.)

KEY PLAN 1:500

WING KWONG STREET

BAILEY STREET

GROUND FLOOR PLAN

FIRE SERVICE INSTALLATION PLANS AS CERTIFIED BY THE AUTHORIZED PERSON AND FIRE SERVICE INSTALLATION CONTRACTOR / CONSULTANT

Date 18 SEP 2026

Signed _(FUNG Kam-wah)_ for Director of Fire Services

LOO Kwan Wai
(RPE No.: RP0260258)

NO.	DATE	REVISIONS	DRAFTED	CHECKED	DESIGNED	ENDORSED
B	06/2026	FSD THIRD SUBMISSION	HYH	WWC	HYH	TKL
A	09/2025	FSD SECOND SUBMISSION	HYH	WWC	HYH	TKL
0	05/2025	FSD FIRST SUBMISSION	HYH	WWC	HYH	TKL

CLIENT:

NATION STAR DEVELOPMENT LIMITED
75/F, 8 Finance Street,
Central, Hong Kong

PROJECT ARCHITECT & AUTHORIZED PERSON:

RONALD LU & PARTNERS
呂元祥建築師事務所
33rd Floor, Wu Chung house, 213 Queen's Road East, Wanchai, Hong Kong

STRUCTURAL/GEOTECHNICAL:

wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

BUILDING SERVICES ENGINEER:

wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

QUANTITY SURVEYOR:

ARCADIS
17/F, Two Harbour Square, 180 Wai Yip Street, Kwun Tong, Kowloon
Hong Kong

FIRE SERVICES CONTRACTOR:

開創工程有限公司
GRAND CREATIVE ENGINEERS LIMITED

PROJECT:

PROPOSED DEVELOPMENT AT BAILEY STREET & WING KWONG STREET, TO KWA WAN, KOWLOON
INLAND LOT NO. 11279
(URA PROJECT KC-009)

TITLE:

SMOKE EXTRACTION SYSTEM - G/F LAYOUT (1 OF 2)

13

DATE: 06/2026		SCALE: 1:100@A0	
DRAFTED: HYH	CHECKED: WWC	DESIGNED: HYH	REVIEWED: TKL
JOB NO. 2503373A	DRAWING NO. 2503373A/SES/204		REV. NO. B