FROM TOP TO BOTTOM
ø150 FS INCOMING WATER PIPE F/A TO H/L
ø150 FS PIPE AT H/L T/A – TOWER 3
ø100 FS PIPE FROM H/L T/A
AND TO M/L FOR FH

ø100 FS PIPE FROM H/L T/A
FROM LEFT TO RIGHT
ø150 SPR PIPE T/A TO H/L (3/F – 17/F) – TOWER 3
ø150 SPR PIPE T/A TO H/L (18/F – 30/F) – TOWER 3
ø150 FS INCOMING WATER PIPE F/A TO H/L
ø150 FS INLET SUPPLY PIPE F/A TO H/L

FROM TOP TO BOTTOM
ø150 FS INLET SUPPLY PIPE T/A TO H/L
ø150 SPR PIPE F/A – PODIUM
FROM TOP TO BOTTOM
ø150 SPR PIPE F/A TO H/L (18/F – 30/F) – TOWER 2
ø150 SPR PIPE F/A TO H/L (3/F – 17/F) – TOWER 2
FROM TOP TO BOTTOM
ø150 SPR INLET SUPPLY PIPE T/A TO H/L
ø150 FS PIPE F/A TO H/L – TOWER 2
ø100 FS INCOMING WATER PIPE AT H/L T/A

ø100 FS PIPE FROM H/L T/A

ø100 FS PIPE FROM H/L T/A
AND T/B AND TO M/L FOR FH

FROM LEFT TO RIGHT
ø150 SPR PIPE F/A TO H/L – ARCADE
ø150 SPR PIPE F/A TO H/L – COMMERCIAL CARPARK

ø100 FS PIPE FROM H/L T/A
& T/B AND TO M/L FOR FH

FROM TOP TO BOTTOM
ø150 SPR INLET T/A
ø150 FS INLET T/A

ø100 FS PIPE FROM H/L T/A
AND TO M/L FOR FH
FROM TOP TO BOTTOM
ø150 SPR INLET SUPPLY PIPE T/A
ø150 FS PIPE T/A – TOWER 2
ø150 SPR PIPE T/A (18/F – 30/F) – TOWER 2
ø150 SPR PIPE T/A (3/F – 17/F) – TOWER 2
ø150 FS PIPE T/A – BASEMENT AND PODIUM
ø150 SPR PIPE FROM H/L T/B
– RESIDENTIAL CARPARK
ø150 SPR PIPE FROM H/L F/A – CLUBHOUSE
ø150 SPR PIPE T/A PODIUM
ø150 FS INLET SUPPLY PIPE F/A

FROM LEFT TO RIGHT
ø100 FS PIPE FROM H/L T/B
ø150 SPR PIPE FROM H/L T/B – RESIDENTIAL CARPARK

ø100 FS PIPE FROM H/L T/A
& T/B AND TO M/L FOR FH

FROM TOP TO BOTTOM
ø65 FS CHECK METER POSITION – TOWER 1
ø80 SPR CHECK METER POSITION – TOWER 1

FROM TOP TO BOTTOM
ø150 FS PIPE T/A – TOWER 1
ø150 SPR INLET SUPPLY PIPE F/A TO H/L
ø150 SPR PIPE T/A (18/F – 30/F) – TOWER 1
ø150 SPR PIPE T/A (3/F – 17/F) – TOWER 1
ø150 FS INLET SUPPLY PIPE F/A

FROM TOP TO BOTTOM
ø150 FS PIPE F/A FROM WATER TANK TO PUMP
ø150 FS PIPE H/L T/A – TOWER 5
FROM TOP TO BOTTOM
ø150 SPR PIPE FROM H/L T/A – ARCADE
ø150 SPR PIPE H/L T/A – CLUBHOUSE

ø100 FS PIPE FROM H/L T/A
AND TO M/L FOR FH

FROM LEFT TO RIGHT
ø65 FS PIPE AT M/L TO H/L – TOWER 3
ø80 SPR PIPE AT M/L TO H/L – TOWER 3
FROM TOP TO BOTTOM
ø65 FS CHECK METER POSITION – TOWER 3
ø80 SPR CHECK METER POSITION – TOWER 3

FIRE SERVICE INSTALLATION PLANS AS CERTIFIED BY THE AUTHORIZED PERSON AND FIRE SERVICE INSTALLATION CONTRACTOR / CONSULTANT
Date 18 SEP 2026
Signed (FUNG Kam-wah)
for Director of Fire Services

PROTECTED AREA

DETAIL A: STANDARD PROVISIONS FOR ROOM PROTECTED BY CLEAN AGENT FIRE SUPPRESSION SYSTEM

FOR INFORMATION ONLY

LOO Kwan Wai
(RPE No.: RP0260258)

NO.	DATE	REVISIONS	DRAFTED	CHECKED	DESIGNED	REVIEWED
B	06/2026	FSD THIRD SUBMISSION	HYH	WWC	HYH	TKL
A	09/2025	FSD SECOND SUBMISSION	HYH	WWC	HYH	TKL
0	05/2025	FSD FIRST SUBMISSION	HYH	WWC	HYH	TKL

CLIENT:

NATION STAR DEVELOPMENT LIMITED
75/F, 8 Finance Street,
Central, Hong Kong

PROJECT ARCHITECT & AUTHORIZED PERSON:
RONALD LU & PARTNERS
呂元祥建築師事務所
33rd Floor, Wu Chung house, 213 Queen's Road East, Wanchai, Hong Kong

STRUCTURAL/GEOTECHNICAL:
wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

BUILDING SERVICES ENGINEER:
wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

QUANTITY SURVEYOR:
ARCADIS
17/F, Two Harbour Square, 180 Wai Yip Street, Kwun Tong, Kowloon
Hong Kong

FIRE SERVICES CONTRACTOR:
開創工程有限公司
GRAND CREATIVE ENGINEERS LIMITED

PROJECT:
PROPOSED DEVELOPMENT AT BAILEY STREET & WING KWONG STREET, TO KWA WAN, KOWLOON
INLAND LOT NO. 11279
(URA PROJECT KC-009)

TITLE:
Fire Serivce Layout of B2/F

DATE: 06/2026	SCALE: 1:150@A0		
DRAFTED: HYH	CHECKED: WWC	DESIGNED: HYH	REVIEWED: TKL
JOB NO. 2503373A	DRAWING NO. FS-201		REV. NO. B