FACING STREET

TOP OF TRANSFER PLATE (COMMON) (ACCESS BY GONDOLA)

FACING STREET

TOWER 3 22.00

ADJOINING LOT BUILDING HEIGHT: ≈60M

UNDER BUILDING (PLANNING) REG. 31
LEVEL OF MAIN ROOF PARAPET : 101.35
LEVEL OF WINDOW SILL AT 3/F : 23.00
REQUIRED LENGTH OF HORIZONTAL PLANE
= (101.35 − 23.00) / 6 = 13.058
HORIZONTAL PLANE AREA PROVIDED
= 13.100 x 2.300 = 30.130 > 21 m² (REQUIRED)

UNDER BUILDING (PLANNING) REG. 31
LEVEL OF MAIN ROOF PARAPET : 101.35
LEVEL OF WINDOW SILL AT 3/F : 23.00
REQUIRED LENGTH OF HORIZONTAL PLANE
= (101.35 − 23.00) / 3 = 26.117
HORIZONTAL PLANE AREA PROVIDED
= 26.200 x 2.300 = 60.260 > 21 m² (REQUIRED)

UNDER BUILDING (PLANNING) REG. 31
LEVEL OF MAIN ROOF PARAPET : 101.35
LEVEL OF WINDOW SILL AT 3/F : 22.00
REQUIRED LENGTH OF HORIZONTAL PLANE
= (101.35 − 22.00) / 4 = 19.838
HORIZONTAL PLANE AREA PROVIDED
= 20.00 x 2.300 = 46.000 > 21 m² (REQUIRED)

UNDER BUILDING (PLANNING) REG. 31
LEVEL OF MAIN ROOF PARAPET : 101.350
LEVEL OF WINDOW SILL AT 3/F : 23.00
REQUIRED LENGTH OF HORIZONTAL PLANE
= (101.350 − 23.00) / 6 = 13.058
HORIZONTAL PLANE AREA PROVIDED
= 13.500 x 2.300 = 31.050 > 21 m² (REQUIRED)

YELLOW & BLACK STRIPE CAUTION ADHESIVE FLOOR TAPE
AV SIGNAL FOR SPS (REFER TO DETAIL 2)
FLOOR MOUNTED WARNING SIGN (REFER TO DETAIL 1)
LOCKED & FOR MAINTENANCE ONLY
1250x600 ARD (8900L/s) F/B
1050x700 ARD (8900L/s)
PIPE DUCT FRR 240/240/240
PLANTER IS ABOVE PIPE DUCT
PIPE DUCT FRR 240/240/240
1050x700 ARD (8900L/s) TO H/L

	WP ARL
1	3215X1050
	8900
	5.27
	AFFL 14800

50% FREE AREA RATIO
B.L 14800mm, T.L 15850mm
(AWAY FROM 1/F FINISHING LEVEL)
(REFER TO ELEVATION E2
(DWG NO.2503373A/SPS/STB3/301)

FOR MAINTENANCE ONLY

RC PARAPET WALL 900mm H.
PORTAL FOR METAL GATE
S.S. HATCH COVER
ALUM. FEATURE
PLANTER
22.55 (T.O.S.)
22.25
22.15
21.40 (T.O.S.)
21.10
21.00
22.13
22.03
24.85(T.O.S.)
24.55
25.50(T.O.S.)
25.20
23.40 (T.O.S.)
23.10
FLAT ROOF (FOR MAINTENANCE)
A.D. BELOW
METAL RAILING
min. 5000mm
ROOF W/. ALUM. CLADDING (ACCESS BY GONDOLA)
METAL CANOPY (ACCESS BY GONDOLA)
TOP OF TRANSFER PLATE (COMMON) (ACCESS BY GONDOLA)
COMMON FLAT ROOF (ACCESS BY GONDOLA)
FLAT ROOF
21.875
21.65
18.45
18.55TOK
19.70
20.05
19.95 (TOS)
19.25

MA TAU WAI ROAD
WAN ON STREET
ADJOINING LOT
BAILEY STREET
WING KWONG STREET
ADJOINING BUILDING

3RD FLOOR PLAN 2026003
NOTE : 1. ALL FLR OR 3RD FLOOR OF TOWERS SHALL REFER TO TYPICAL FLOOR PLANS.

KEY PLAN 1:500

FIRE SERVICE INSTALLATION PLANS AS CERTIFIED BY THE AUTHORIZED PERSON AND FIRE SERVICE INSTALLATION CONTRACTOR / CONSULTANT
Date 27 AUG 2026
Signed (FUNG Kam-wah)
for Director of Fire Services

DETAIL 1: WARNING SIGN (SCALE : N.T.S.)

900 × 500

CAUTION
小心
SMOKE OUTLET LOCATED AT THIS AREA
此處設有排煙口
WHEN ALARM SOUNDS OR SMOKE DISCHARGES EVACUATE IMMEDIATELY
當警鐘響動或排煙時
應即時撤離現場

DETAIL 2: AV SIGNAL FOR SPS (LAMP AND BUZZER) (SCALE : N.T.S.)

600 × 500

樓梯增壓排煙系統
STAIRCASE PRESSURIZATION AIR RELEASE SYSTEM
運行中
IN OPERATION

LOO Kwan Wai
(RPE No.: RP0260258)

NO.	DATE	REVISIONS	DRAFTED	CHECKED	DESIGNED	REVIEWED
A	06/2026	FSD SECOND SUBMISSION	HYH	WWC	HYH	TKL
0	03/2025	FSD FIRST SUBMISSION	HYH	WWC	HYH	TKL

CLIENT:

NATION STAR DEVELOPMENT LIMITED
75/F, 8 Finance Street,
Central, Hong Kong

PROJECT ARCHITECT & AUTHORIZED PERSON:
RONALD LU & PARTNERS 呂元祥建築師事務所
33rd Floor, Wu Chung house, 213 Queen's Road East, Wanchai, Hong Kong

STRUCTURAL/GEOTECHNICAL
wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

BUILDING SERVICES ENGINEER:
wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

QUANTITY SURVEYOR:
ARCADIS
17/F, Two Harbour Square, 180 Wai Yip Street, Kwun Tong, Kowloon
Hong Kong

FIRE SERVICES CONTRACTOR:
開創工程有限公司
GRAND CREATIVE ENGINEERS LIMITED
CLASS 1, 2 & 3 REGISTERED FIRE SERVICES CONTRACTOR
WSD LICENSED PLUMBER (GRADE 1)
EMSD REGISTERED ELECTRICAL CONTRACTOR
陳廣開
Chan Kwong Hoi
Director
Unit D, 2/F, Cheong Wah Comm. Bldg., 900-904 Canton Road, Kowloon.
Mobile : 9015 8686 Tel : 3612 5782 Fax : 3612 5785
Email : info@grandcreative.com.hk

PROJECT:
PROPOSED DEVELOPMENT AT BAILEY STREET & WING KWONG STREET, TO KWA WAN, KOWLOON
INLAND LOT NO. 11279
(URA PROJECT KC–009)

TITLE:
STAIRCASE PRESSURIZATION SYSTEM – 3F LAYOUT (ST–B3)

DATE: 06/2026	SCALE: 1:100@A0		
DRAFTED: HYH	CHECKED: WWC	DESIGNED: HYH	REVIEWED: TKL
JOB NO. 2503373A	DRAWING NO. 2503373A/SPS/STB3/207		REV. NO. A