350X200 PAD
ACC. TOILET
450X300 EAD
650X700 EAL/WPL
150X150 PAD
650X700 EAL/WPL
1000X300 SAD
EAF 2F|02 (600L/s)
450X300 EAD
VIU-03(D)(293L/s)
1000x600 SED F/B TO H/L T/A
A.D. (S.E.S.)
1200x500 SED/EAD TO H/L
1100x550 SED/EAD TO H/L
1200x500 SED/EAD H/L T/A
1100x550 SED/EAD H/L T/A
1000X300 SAD
VIU-03(D)(293L/s)
1200X300 RAD
VIU-05(D)(150L/s)
BUILDING LINE ABOVE
TRELLIS ABOVE
1200x500 SED/EAD F/B H/L
1100x550 SED/EAD F/B H/L
MAINTENANCE STAIRCASE
1100x550 SED/EAD F/B H/L
LIFT CONTROL PANEL
E.M.R. (FOR R.R.F.)
600X500 EAL
EAF 2F|09 (100L/s)
LIFT VENT AT H/L
VIU-03(D)(293L/s)
TOTAL 22NOS VIU FOR GYM1&2
300x300 EAL/WPL
200x200 EAD
STONE ARCH. FEATURE
ALUM. CLAD.
TRANSFER PLATE ABOVE
200X200 PAD(TYP.)
450X350 PAD
1000x450 FAL/WPL
FAP-03(583L/s)
1000x450 FAL/WPL
MIN. RC EDGE OF ARCH. FEATURE
ARCH. FEATURE
BAL. & U.P. ABOVE
METAL CLADDING
PLANTER
15.35 TOS
15.05 BOS
14.95 SFL
METAL CLADDING
RC EDGE OF ARCH. FEATURE
ARCH. FEATURE
METAL CLADDING
VIU-03(D)(293L/s)
950X300 SAD (TYP.)
FOR VIU
PLANTER
300x300 PAD
550x350 PAD
FOR CONTINUATION PLS. REFER TO DWG. NO. P42424/FSD/VAC/220
17.00
15.60
15.40
METAL ROOF ABOVE
FALL 1:25
15.95
15.75
ROOF ABOVE
17.00
16.85 W.L.
15.95
15.85
POOL DECK
16.95
16.65
TRANSFER PLATE ABOVE
16.875(W.L.)
16.70
16.50
13.65
16.90
16.875 W.F.
16.15
15.95
15.90
16.05
15.00
LIFT VENT AT H/L
RC EDGE OF ARCH. FEATURE
PLANTER
16.35 TOS
15.90 BOS
15.80 SFL
950X300 SAD
ARCH. FEATURE
EAF 2F|07 (140L/s)
500X300 EAL
500X300 EAL
VOID
ARCH. FEATURE
RC EDGE OF ARCH. FEATURE
OUTDOOR SWIMMING POOL
ARCH. FEATURE
VIU-03(D)(293L/s)
TOTAL 8NOS VIU
950X300 SAD (TYP.)
150X150 PAD(TYP.)
PLANTER
18.45 (TOP OF GLASS)
17.31 (TOP OF KERB)
600X350 PAD
FAP-01(300L/s)
18.45 (TOP OF GLASS)
800x500 FAL
16.85 W.L.
16.70
16.50
18.45 (TOW)
18.30 TOS
17.10 BOS
16.95 SFL
POOL DECK
16.95
16.65
16.35 TOS
15.90 BOS
15.80 SFL
15.975
16.50
R.C. PARAPET WALL
PLANTER
V.G. ABOVE
15.25 TOS
14.90 BOS
15.35 TOS
14.90 BOS
15.50 TOS
14.90 BOS
18.35 TOW
18.30 TOS
17.10 BOS
16.85 SFL
16.875 (W.L.)
16.30 (W.L.)
16.15
15.95
WATER FEATURE
16.875
WATER FEATURE
GYMNASIUM
16.10
15.40 (TOWER SLAB)
250X250 PAD
200X200 PAD
350X350 PAD
550X350 PAD
RAMP UP 1:12
GYMNASIUM 1
15.05
15.00
GYMNASIUM 2
15.35
15.00
3000X300 SAD
VIU-03(D)(293L/s)
950X300 SAD (TYP.)
FOR VIU
PLANTER
300x300 PAD
550x350 PAD
METAL GATE
16.25
16.20 TOS
15.60 BOS
15.45 SFL
15.30 TOS
14.70 BOS
14.60 SFL
15.20
14.75
15.45
15.25
15.25
16.80
16.75 TOS
15.55 BOS
15.45 SFL
18.20
16.20 TOS
15.60 BOS
15.45 SFL
15.40 TOS
14.45 BOS
14.35 SFL
PUMP PIT
WATER FEATURE
15.25 W.L.
15.20
15.00
15.50 TOS
14.30 BOS
14.25 SFL
15.25
15.20
16.80 TOS
15.40 BOS
15.30 SFL
18.20
LIFT CONTROL PANEL
E.D.
CHILDREN PLAY ROOM
15.05
16.85 W.L.
16.70
16.50
18.45 (TOP OF GLASS)
17.10
18.20 (TOP OF GLASS)
BUILDING LINE ABOVE
SINK 15.30
LAWN
15.40
15.25
15.60
15.25
15.30
15.05
14.80
15.55 TOS
14.35 BOS
15.55
15.40
SEATING AREA 1
15.05
15.00
CARPARK SHUTTLE LIFT LOBBY
LIFT L17
LIFT L18 A D
200X200 PAD
VIU-04(D)(158L/s)
200X200 EAD
15.25
15.20
15.75
F-LOB
STORE
LIFT L4
LIFT L5
LIFT L6 A D
STUDY RM. 1
STUDY RM. 3
ELV RM. (FOR R.R.F.)
V. SWITCH ROOM NO.2 (FOR RESIDENTIAL)
COMMON
600X350 FAD
LIFT VENT AT H/L
VIU-03(D)(293L/s)
950X300 SAD
600X350 FAD
800x500 FAL/WPL
FAP-01(300L/s)
950X300 SAD
VIU-05(D)(150L/s)
RC EDGE OF ARCH. FEATURE
VIU-03(D)(293L/s)
950X300 SAD
E.D.
600X350 PAD
EAF 2F|19 (480L/s)
200X200 EAD
VIU-05(D)(150L/s)
400X300 EAD
400X300 PAD
650X300 SAD
15.15 F.F.L.
15.00 S.F.L.
200X200 PAD
950X300 SAD (TYP.)
METAL CLADDING
VIU-03(D)(293L/s)
VIU-05(D)(150L/s)
PLANTER
650X300 SAD
VIU-03(D)(293L/s)
15.35 TOS
15.05 BOS
14.95 SFL
TOTAL 4NOS VIU
200x200 PAD
150x150 PAD(TYP.)
METAL CLADDING
600X350 PAD
-/60/60 FRR GLASS WALL & DOOR
800x500 FAL/WPL
FAP-01(300L/s)
RC EDGE OF ARCH. FEATURE
950X300 SAD (TYP.)
VIU-05(D)(150L/s)
VIU-04(D)(158L/s)
FIRE SERVICE INSTALLATION (FSI) AS CERTIFIED BY THE AUTHORISED PERSON AND FIRE SERVICE INSTALLATION CONTRACTOR / CONSULTANT
Date 10 SEP 2026
Signed (WU Wai-kei)2
for Director of Fire Services
200X200 TAD
EAF 2F|20 (100L/s)
950X300 SAD
150X150 TAD
EAF 2F|01 (100L/s)
SPA 1
SPA 2
ARCH. FEATURE
METAL CLADDING
750x500 EAL/WPL
150X150 TAD
650X300 SAD
150X150 EAD
VIU-05(D)(150L/s)
150X150 EAD
150X150 TAD
150X150 PAD
VIU-05(D)(150L/s)
GAME R RM.1
GAME RM.2
15.35 TOS
15.05 BOS
14.95 SFL
EAF 2F|12 (60L/s)
600X300 SAD (TYP.)
VIU-05(D)(150L/s)
11820
7765
8955
10900
10900
A
B
C
D
E
F
G

KEY PLAN
LEGEND REFER TO P42424-FSD-VAC-001

REV.	DESCRIPTION	DATE
A	SECOND SUBMISSION	17/06/2026
0	FIRST SUBMISSION	18/11/2025

CLIENT:

NATION STAR DEVELOPMENT LIMITED
75/F, 8 Finance Street,
Central, Hong Kong

ARCHITECT:

RONALD LU & PARTNERS
呂元祥建築師事務所
33rd Floor, Wu Chung house, 213 Queen's Road East, Wanchai, Hong Kong

STRUCTURAL GEOTECHNICAL:

wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

M&E SERVICES CONSULTANT:

wsp
7/F, One Kowloon
1 Wang Yuen Street
Kowloon Bay, Hong Kong

MAIN CONTRACTOR

中國海外房屋工程有限公司
CHINA OVERSEAS BUILDING CONSTRUCTION LIMITED
139, China Overseas Building, Hennessy Road
Wan Chai, Hong Kong

MVAC SUB-CONTRACTOR:

Sun Yu Chau Engineering Company Limited
12/F, Khuan Centre, No. 9 Hung To Road
Kwun Tong, Kowloon, Hong Kong
TEL : (852)2345 8500 FAX : (852)2797 0387

FIRE SERVICES CONTRACTOR:

開創工程有限公司
GRAND CREATIVE ENGINEERS LIMITED

PROJECT:

PROPOSED DEVELOPMENT AT BAILEY STREET & WING KWONG STREET, TO KWA WAN, KOWLOON
INLAND LOT NO. 11279
(URA PROJECT KC-009)

TITLE:

VAC LAYOUT PLAN AT 2/F
(SHEET 4 OF 4)

JOB NO.	SCALE	DATE	DRAWING BY
P42424	1:100 @A1	17/06/2026	CY
P42424/FSD/VAC/223		CHECKED BY	APPROVED BY
		KM	WW

REV. 0 A