

	OCCUPATIONAL HEALTH & SAFETY MANAGEMENT SYSTEM		Document Number: DIMO-LTD-CL-05
	CHECKLIST		Issue: 00
	FIRE EXTINGUISHER		Issue Date: 1 st January 2021

Project		Date of Inspection	
Contractor's Name		Frequency	
Date of first deployment		Checked by	
Type			

KNOW YOUR FIRE EXTINGUISHER COLOUR CODE

Water	Dry powder	Foam	CO ₂ Carbon dioxide	Wet Chemical
 For use on Wood, Paper, textiles etc.	 For use on - Wood, Paper, textiles etc. - Flammable liquids - Gaseous fires	 For use on - Wood, Paper, textiles etc. - Flammable liquids	 For use on - Flammable liquids - Live electrical equipment	 For use on - Wood, Paper, textiles etc. - Cooking oil fires
Do not use on - Flammable liquids - Live electrical equipment	Do not use on Live electrical equipment	Do not use on Live electrical equipment	Do not use in a confined space	

S/N	INSPECTION POINTS	YES	NO	N/A	REMARKS
01	Physical condition of the extinguisher is clean and tidy.				
02	Cylinder and other metal parts are free from corrosion				
03	Pressure gauge or indicator is in the operable range.				
04	Discharge nozzle is available and no physical damage.				
05	No cracks in the hose.				
06	The gauges indicator is in working condition.				
07	Inspection tag is available.				
08	Stored location is easy to access.				

Overall Observation	Accepted: Yes No	Remarks:
Removal of Equipment/Machine (If not acceptable)	Date:	Remarks:
If Corrective/Preventive action taken to rectify	Date:	Remarks:

Checked by	Name	Date	Signature
Contractor's Supervisor			
EHS Officer			
Site In charge/Manager			