


	OCCUPATIONAL HEALTH & SAFETY MANAGEMENT SYSTEM		Document Number: DIMO-LTD-CL-08
	CHECKLIST		Issue: 00
	GENERATOR		Issue Date: 1 st January 2021

Project		Date of Inspection	
Contractors Name		Frequency	
Date of first deployment		Checked by	
Type		Serial No	



S/N	INSPECTION POINTS	YES	NO	N/A	REMARKS
01	Guards are available for rotating parts and hot surfaces				
02	No oil leakage from any part of the machine				
03	Exhaust smoke pipe has faced upwards & outside from the generator shelter				
04	Dip trays are available for any oil leakage				
05	Presence of damage free operating switch, Voltage and temperature meter, circuit breaker, Oil level indicator and Emergency switch (If available)				
06	Body earthing has been provided with standard earth pit				
07	Presence of fire extinguisher				
08	Adequate ventilation is available for in case of indoor generator				

Overall Observation	Accepted: Yes No	Remarks:
Removal of Equipment/Machine (If not acceptable)	Date:	Remarks:
If Corrective/Preventive action taken to rectify	Date:	Remarks:

Checked by	Name	Date	Signature
Contractor's Supervisor			
EHS Officer			
Site In charge/Manager			