

	OCCUPATIONAL HEALTH & SAFETY MANAGEMENT SYSTEM	Document Number: DIMO-LTD-CL-28
	CHECKLIST	Issue: 00
	GAS CUTTER SET	Issue Date: 1st January 2021

Project		Date of Inspection	
Contractors Name		Frequency	
Date of first deployment		Checked by	
Type		Serial No	



S/N	INSPECTION POINTS	YES	NO	N/A	REMARKS
01	Hot work permit is available				
02	Hoses are free from damage and have been tightened with hose clamps.				
03	Double stage regulator for each cylinder must be used and pressure gauges are in working condition (Both cylinders)				
04	Flash back arrestors (FBA) are available for both cylinders (Acetylene & oxygen) as well as torch ends				
05	Protective valve cap firmly fixed for both cylinders				
06	Double stage regulators with pressure gauges available for both cylinders				
07	All flammable objects in the hot work area been covered or removed				
08	Adequate ventilation and lighting is available				
09	Presence of fire extinguisher/fire blanket				
10	Operator/Worker is competent/skilled and required PPEs available for the task				
11	Trolley/Cage is available and has been secured by chains.				

Overall Observation	Accepted: Yes No	Remarks:
Removal of Equipment/Machine (If not acceptable)	Date:	Remarks:
If Corrective/Preventive action taken to rectify	Date:	Remarks:

Checked by	Name	Date	Signature
Contractor's Supervisor			
EHS Officer			
Site In charge/Manager			