

	OCCUPATIONAL HEALTH & SAFETY MANAGEMENT SYSTEM	Document Number: DIMO-LTD-CL-31
	CHECKLIST	Issue: 00
	ELCB/RCCB	Issue Date: 1 st January 2021

Project		Date of Inspection	
Contractors Name		Frequency	
Date of first deployment		Checked by	
Type		Serial No	



S/N	INSPECTION POINTS	YES	NO	N/A	REMARKS
01	ELCB or RCCB with rating suitable for incoming power supply (30mA sensitivity)				
02	RCCB or ELCB tripped properly by pressing trip test button. ELCB to be tested quarterly for tripping value.				
03	All Connections are tight & robust.				

Overall Observation	Accepted: Yes No	Remarks:
Removal of Equipment/Machine (If not acceptable)	Date:	Remarks:
If Corrective/Preventive action taken to rectify	Date:	Remarks:

Checked by	Name	Date	Signature
Contractor's Supervisor			
EHS Officer			
Site In charge/Manager			