

BDD Chawls Redevelopment Project, Worli, Mumbai

Details

Data Entry

Report

Initial Vertical Load Test Report

Pile ID: TP-01 | Location: Building-3 Wing B

Test Date: 08 December 2025 | Test Method: IS 2911 (Part 4) - 2013

Test Result: PASSED

Net Settlement: 4.14mm (Limit: 12mm)

PASSED

TEST LOAD

1050.0 MT

2.5× Design Load

MAX SETTLEMENT

7.22 mm

At test load

ELASTIC REBOUND

3.08 mm

Recovery after unloading

NET SETTLEMENT

4.14 mm

Limit: 12mm (IS 2911)

SAFE LOAD ADOPTED

420.0 MT

Per design criterion

DESIGN LOAD

420.0 MT

Working load capacity

Pile Specifications

Pile ID

TP-01

Diameter

900 mm

Depth

11.51 m

Concrete Grade

M40

Ram Area

2551 cm²

Jack Name

-

Dial Gauge LC

0.01 mm

Method

IS 2911 (Part 4)

Load vs Settlement Curve

Loading

Hold

Unloading

Settlement (mm)

0

1

2

3

4

5

6

7

8

0

200

400

https://pile-test-pro.vercel.app/test

1/5

4.0 Results & Conclusion

 Generate Conclusion



No conclusion generated yet

Click "Generate Conclusion" to create an IS 2911-compliant conclusion using AI

Load Increment Summary

Phase	Date	Time	Load (MT)	Pressure	Avg Settlement	Remarks
LOADING	08/12/2025	11:59 PM	0.00	0 kg/cm ²	- mm	Start
LOADING	09/12/2025	12:00 AM	102.04	40 kg/cm ²	0.06 mm	-
LOADING	09/12/2025	12:15 AM	102.04	40 kg/cm ²	0.13 mm	-
LOADING	09/12/2025	12:30 AM	102.04	40 kg/cm ²	0.17 mm	-
LOADING	09/12/2025	12:45 AM	102.04	40 kg/cm ²	0.19 mm	-
LOADING	09/12/2025	01:00 AM	102.04	40 kg/cm ²	0.21 mm	-
LOADING	09/12/2025	01:01 AM	204.08	80 kg/cm ²	0.41 mm	-
LOADING	09/12/2025	01:15 AM	204.08	80 kg/cm ²	0.29 mm	-
LOADING	09/12/2025	01:30 AM	204.08	80 kg/cm ²	0.43 mm	-
LOADING	09/12/2025	01:45 AM	204.08	80 kg/cm ²	0.47 mm	-
LOADING	09/12/2025	02:00 AM	204.08	80 kg/cm ²	0.52 mm	-
LOADING	09/12/2025	02:01 AM	306.12	120 kg/cm ²	0.77 mm	-
LOADING	09/12/2025	02:15 AM	306.12	120 kg/cm ²	0.81 mm	-
LOADING	09/12/2025	02:30 AM	306.12	120 kg/cm ²	0.83 mm	-
LOADING	09/12/2025	02:45 AM	306.12	120 kg/cm ²	0.86 mm	-
LOADING	09/12/2025	03:00 AM	306.12	120 kg/cm ²	0.89 mm	-
LOADING	09/12/2025	03:01 AM	408.16	160 kg/cm ²	1.25 mm	-
LOADING	09/12/2025	03:15 AM	408.16	160 kg/cm ²	1.28 mm	-
LOADING	09/12/2025	03:30 AM	408.16	160 kg/cm ²	1.31 mm	-
LOADING	09/12/2025	03:45 AM	408.16	160 kg/cm ²	1.08 mm	-
LOADING	09/12/2025	04:00 AM	408.16	160 kg/cm ²	1.24 mm	override
LOADING	09/12/2025	04:01 AM	510.20	200 kg/cm ²	1.51 mm	-
LOADING	09/12/2025	04:15 AM	510.20	200 kg/cm ²	1.50 mm	-
LOADING	09/12/2025	04:30 AM	510.20	200 kg/cm ²	1.53 mm	-
LOADING	09/12/2025	04:45 AM	510.20	200 kg/cm ²	1.56 mm	-

Phase	Date	Time	Load (MT)	Pressure	Avg Settlement	Remarks
LOADING	09/12/2025	05:00 AM	510.20	200 kg/cm ²	1.59 mm	-
LOADING	09/12/2025	05:01 AM	612.24	240 kg/cm ²	2.08 mm	-
LOADING	09/12/2025	05:15 AM	612.24	240 kg/cm ²	2.11 mm	-
LOADING	09/12/2025	05:30 AM	612.24	240 kg/cm ²	2.13 mm	-
LOADING	09/12/2025	05:45 AM	612.24	240 kg/cm ²	2.13 mm	-
LOADING	09/12/2025	06:00 AM	612.24	240 kg/cm ²	2.16 mm	-
LOADING	09/12/2025	06:01 AM	714.28	280 kg/cm ²	2.66 mm	-
LOADING	09/12/2025	06:15 AM	714.28	280 kg/cm ²	2.66 mm	-
LOADING	09/12/2025	06:30 AM	714.28	280 kg/cm ²	2.67 mm	-
LOADING	09/12/2025	06:45 AM	714.28	280 kg/cm ²	2.68 mm	-
LOADING	09/12/2025	07:00 AM	714.28	280 kg/cm ²	2.68 mm	-
LOADING	09/12/2025	07:01 AM	816.32	320 kg/cm ²	3.30 mm	-
LOADING	09/12/2025	07:15 AM	816.32	320 kg/cm ²	3.33 mm	-
LOADING	09/12/2025	07:30 AM	816.32	320 kg/cm ²	3.35 mm	-
LOADING	09/12/2025	07:45 AM	816.32	320 kg/cm ²	3.38 mm	-
LOADING	09/12/2025	08:00 AM	816.32	320 kg/cm ²	3.40 mm	-
LOADING	09/12/2025	08:01 AM	918.36	360 kg/cm ²	4.18 mm	-
LOADING	09/12/2025	08:15 AM	918.36	360 kg/cm ²	4.20 mm	-
LOADING	09/12/2025	08:30 AM	918.36	360 kg/cm ²	4.23 mm	-
LOADING	09/12/2025	08:45 AM	918.36	360 kg/cm ²	4.27 mm	-
LOADING	09/12/2025	09:00 AM	918.36	360 kg/cm ²	4.30 mm	-
LOADING	09/12/2025	09:01 AM	1020.40	400 kg/cm ²	4.95 mm	-
LOADING	09/12/2025	09:15 AM	1020.40	400 kg/cm ²	5.00 mm	-
LOADING	09/12/2025	09:30 AM	1020.40	400 kg/cm ²	5.03 mm	-
LOADING	09/12/2025	09:45 AM	1020.40	400 kg/cm ²	5.06 mm	-
LOADING	09/12/2025	10:00 AM	1020.40	400 kg/cm ²	5.08 mm	-
LOADING	09/12/2025	10:01 AM	1071.42	420 kg/cm ²	5.36 mm	-
HOLDING	09/12/2025	11:00 AM	1071.42	420 kg/cm ²	5.40 mm	-
HOLDING	09/12/2025	12:00 PM	1071.42	420 kg/cm ²	5.44 mm	-
HOLDING	09/12/2025	01:00 PM	1071.42	420 kg/cm ²	5.50 mm	-
HOLDING	09/12/2025	02:00 PM	1071.42	420 kg/cm ²	5.53 mm	-
HOLDING	09/12/2025	03:00 PM	1071.42	420 kg/cm ²	5.58 mm	-

Phase	Date	Time	Load (MT)	Pressure	Avg Settlement	Remarks
HOLDING	09/12/2025	04:00 PM	1071.42	420 kg/cm ²	5.60 mm	-
HOLDING	09/12/2025	05:00 PM	1071.42	420 kg/cm ²	5.62 mm	-
HOLDING	09/12/2025	06:00 PM	1071.42	420 kg/cm ²	5.66 mm	-
HOLDING	09/12/2025	07:00 PM	1071.42	420 kg/cm ²	5.67 mm	-
HOLDING	09/12/2025	08:00 PM	1071.42	420 kg/cm ²	5.68 mm	-
HOLDING	09/12/2025	09:00 PM	1071.42	420 kg/cm ²	5.74 mm	-
HOLDING	09/12/2025	10:00 PM	1071.42	420 kg/cm ²	5.79 mm	-
HOLDING	09/12/2025	11:00 PM	1071.42	420 kg/cm ²	6.14 mm	-
HOLDING	10/12/2025	12:00 AM	1071.42	420 kg/cm ²	6.63 mm	-
HOLDING	10/12/2025	01:00 AM	1071.42	420 kg/cm ²	6.86 mm	-
HOLDING	10/12/2025	02:00 AM	1071.42	420 kg/cm ²	6.95 mm	-
HOLDING	10/12/2025	03:00 AM	1071.42	420 kg/cm ²	7.00 mm	-
HOLDING	10/12/2025	04:00 AM	1071.42	420 kg/cm ²	7.12 mm	-
HOLDING	10/12/2025	05:00 AM	1071.42	420 kg/cm ²	7.17 mm	-
HOLDING	10/12/2025	06:00 AM	1071.42	420 kg/cm ²	7.19 mm	-
HOLDING	10/12/2025	07:00 AM	1071.42	420 kg/cm ²	7.21 mm	-
HOLDING	10/12/2025	08:00 AM	1071.42	420 kg/cm ²	7.22 mm	-
HOLDING	10/12/2025	09:00 AM	1071.42	420 kg/cm ²	7.22 mm	-
HOLDING	10/12/2025	10:00 AM	1071.42	420 kg/cm ²	7.22 mm	-
UNLOADING	10/12/2025	10:01 AM	1020.40	400 kg/cm ²	7.18 mm	-
UNLOADING	10/12/2025	10:05 AM	1020.40	400 kg/cm ²	7.18 mm	-
UNLOADING	10/12/2025	10:15 AM	1020.40	400 kg/cm ²	7.19 mm	-
UNLOADING	10/12/2025	10:16 AM	918.36	360 kg/cm ²	7.10 mm	-
UNLOADING	10/12/2025	10:20 AM	918.36	360 kg/cm ²	7.06 mm	-
UNLOADING	10/12/2025	10:30 AM	918.36	360 kg/cm ²	7.04 mm	-
UNLOADING	10/12/2025	10:31 AM	816.32	320 kg/cm ²	6.87 mm	-
UNLOADING	10/12/2025	10:35 AM	816.32	320 kg/cm ²	6.85 mm	-
UNLOADING	10/12/2025	10:45 AM	816.32	320 kg/cm ²	6.85 mm	-
UNLOADING	10/12/2025	10:46 AM	714.24	280 kg/cm ²	6.66 mm	-
UNLOADING	10/12/2025	10:50 AM	714.24	280 kg/cm ²	6.64 mm	-
UNLOADING	10/12/2025	11:00 AM	714.24	280 kg/cm ²	6.63 mm	-
UNLOADING	10/12/2025	11:01 AM	612.24	240 kg/cm ²	6.42 mm	-

Phase	Date	Time	Load (MT)	Pressure	Avg Settlement	Remarks
UNLOADING	10/12/2025	11:05 AM	612.24	240 kg/cm ²	6.37 mm	-
UNLOADING	10/12/2025	11:15 AM	612.24	240 kg/cm ²	6.35 mm	-
UNLOADING	10/12/2025	11:16 AM	510.20	200 kg/cm ²	6.14 mm	-
UNLOADING	10/12/2025	11:20 AM	510.20	200 kg/cm ²	6.13 mm	-
UNLOADING	10/12/2025	11:30 AM	510.20	200 kg/cm ²	6.13 mm	-
UNLOADING	10/12/2025	11:31 AM	402.16	160 kg/cm ²	5.89 mm	-
UNLOADING	10/12/2025	11:35 AM	402.16	160 kg/cm ²	5.87 mm	-
UNLOADING	10/12/2025	11:45 AM	402.16	160 kg/cm ²	5.84 mm	-
UNLOADING	10/12/2025	11:46 AM	306.12	120 kg/cm ²	5.58 mm	-
UNLOADING	10/12/2025	11:50 AM	306.12	120 kg/cm ²	5.54 mm	-
UNLOADING	10/12/2025	12:00 PM	306.12	120 kg/cm ²	5.51 mm	-
UNLOADING	10/12/2025	12:01 PM	204.08	80 kg/cm ²	5.25 mm	-
UNLOADING	10/12/2025	12:05 PM	204.08	80 kg/cm ²	5.21 mm	-
UNLOADING	10/12/2025	12:15 PM	204.08	80 kg/cm ²	5.18 mm	-
UNLOADING	10/12/2025	12:16 PM	102.04	40 kg/cm ²	4.89 mm	-
UNLOADING	10/12/2025	12:20 PM	102.04	40 kg/cm ²	4.81 mm	-
UNLOADING	10/12/2025	12:30 PM	102.04	40 kg/cm ²	4.80 mm	-
UNLOADING	10/12/2025	12:31 PM	0.00	0 kg/cm ²	4.14 mm	-
UNLOADING	10/12/2025	12:35 PM	0.00	0 kg/cm ²	4.10 mm	-
UNLOADING	10/12/2025	12:45 PM	0.00	0 kg/cm ²	4.06 mm	-