

ZedGeo Systems Private Limited., Mumbai

RECORD OF PILE LOAD TEST NO.

PROJECT

LOCATION

CONTRACTOR

CLIENTS NAME

Improvement of sewage management
system in Marik City
Panchak STP 75 MLD
NMC

L.C. OF DIAL GAUGE

Type of Test

Design load on pile

Test Load

Mixed Design

Pile Diameter

INITIAL PILE LOAD TEST

0.01 mm
Static load test

147MT

367.5MT

M25

600mm

Ram Area

Date of Casting

Pile Depth

① 2551.17 cm²
15.08.2025
11.90 Meters

DATE	TIME (Hrs)	PRESSURE kg/cm ²	LOAD IN MT	Reading				Average settlement Test Pile	SIGNATURE		
				Reading 1	Reading 2	Reading 3	Reading 4		ZED	VEL	PMC
27/10/25		0	0	0	0	0	0	0			
	17.00	15	38.26	0.01	0.00	0.01	0.01	0.007			
	17.15			0.02	0.01	0.01	0.02	0.015			
	17.30			0.03	0.03	0.02	0.03	0.027			
	17.45			0.03	0.03	0.02	0.03	0.027			
	18.00			0.03	0.03	0.02	0.03	0.027			
	18.01	30	76.53	0.96	0.85	0.56	0.54	0.72			
	18.15			1.01	1.00	0.60	0.61	0.80			
	18.30			1.03	1.02	0.62	0.62	0.82			
	18.45			1.04	1.05	0.63	0.63	0.83			
	19.00			0.04	1.06	0.64	0.63	0.84			
	19.01	45	76.53	1.30	1.31	0.80	0.91	1.08			
	19.15			1.33	1.34	0.84	0.95	1.11			
	19.30			1.35	1.35	0.86	0.97	1.13			
	19.45			1.35	1.27	0.87	0.98	1.14			
	20.00			1.35	1.27	0.90	0.99	1.15			
	20.01	60	153.06	1.76	1.88	1.10	1.15	1.47			
	20.15			1.78	1.90	1.12	1.18				
	20.30			1.85	1.94	1.15	1.20				
	20.45			1.86	1.97	1.18	1.23				
	21.00			1.90	1.98	1.24	1.30	1.59			



ZedGeo Systems Private Limited., Mumbai

RECORD OF PILE LOAD TEST NO. -

L.C OF DIAL GAUGE :-
Type of Test :-

Ram Area :-
Date of Casting :-
Pile Depth :-

PROJECT -

LOCATION -

CONTRACTOR:-

CLIENTS NAME:-

Design load on pile:-
Test Load :-
Mixed Design :-
Pile Diameter :-

INITIAL PILE LOAD TEST

DATE	TIME	PRESSURE	LOAD IN MT	Reading					Average settlement	SIGNATURE			REMARK
		GAUGE READING kg/cm ²		Reading 1	Reading 2	Reading 3	Reading 4	Test Pile		ZED	NEL	PMC	
27/10/25													
	21.01	75	191.32	2.30	2.76	1.95	1.98	2.14					
	21.15			2.35	2.40	1.99	2.00	2.18					
	21.30			2.47	2.51	2.07	2.11	2.29					
	21.45			2.52	2.60	2.12	2.16	2.35					
	22.00			2.58	2.65	2.15	2.20	2.46					
	22.01	90	229.54	3.46	3.71	3.10	2.99	3.31					
	22.15		229.59	3.58	3.82	3.18	4.13	3.67					
	22.30			3.71	3.88	3.24	4.19	3.75					
	22.45			3.75	3.90	3.31	4.22	3.79					
	23.00			3.77	3.92	3.33	4.24	3.81					
	23.01	105	267.85	4.65	4.71	4.20	4.26	4.45					
	23.15			4.68	4.77	4.25	4.28	4.49					
	23.30			4.70	4.81	4.27	4.39	4.54					
	23.45			4.72	4.82	4.30	4.39	4.55					
28/10/25	00			4.72	4.83	4.34	4.39	4.57					
	1.01	120	306	5.57	5.76	5.61	5.77	5.67					
	1.15			5.60	5.80	5.65	5.82	5.71					
	1.30			5.62	5.84	5.67	5.85	5.74					
	1.45			5.65	5.86	5.70	5.88	5.77					
	2.00			5.66	5.88	5.72	5.90	5.79					

ZedGeo Systems Private Limited., Mumbai

RECORD OF PILE LOAD TEST NO. -

PROJECT -

LOCATION -

CONTRACTOR -

CLIENTS NAME -

L.C OF DIAL GAUGE :-
Type of Test :-

Design load on pile :-
Test Load :-
Mixed Design :-
Pile Diameter :-

Ham Area :-
Date of Casting :-
Pile Depth :-

Page ③

DATE	TIME	PRESSURE	LOAD IN MT	INITIAL PILE LOAD TEST					SIGNATURE			REMARK
				Reading				Average settlement	ZED	VEL	PMC	
	(Hrs)	GAUGE READING kg/cm2		Reading 1	Reading 2	Reading 3	Reading 4	Test Pile				
28/10/25	2.01	135	344.38	6.75	6.92	6.85	6.94	6.86				
	2.05			6.80	6.96	6.89	6.99	6.91				
	2.30			6.85	7.00	6.93	7.03	6.95				
	2.45			6.87	7.02	6.94	7.05	6.97				
	3.00			6.88	7.04	6.96	7.07	6.98				
	3.01	150	382.65	7.76	7.99	7.69	7.90	7.87				
	4.01			7.91	8.58	7.88	8.47	8.21				
	5.01			7.95	8.63	7.94	8.51	8.25				
	6.01			7.95	8.70	8.08	8.71	8.36				
	7.01			7.95	8.85	8.25	8.92	8.49				
	8.01			7.95	8.85	8.25	8.92	8.49				
	9.01			7.96	8.85	8.27	8.93	8.50				
	10.01			8.02	8.87	8.38	8.98	8.56				
	11.01			8.08	8.90	8.40	9.09	8.61				
	12.01			8.12	8.95	8.46	9.12	8.66				
	13.01			8.16	8.99	8.51	9.18	8.71				
	14.01			8.18	8.99	8.55	9.18	8.72				
	15.01			8.18	8.99	8.55	9.18	8.72				
	16.01			8.18	8.99	8.55	9.18	8.72				
	17.01			8.18	8.99	8.55	9.18	8.72				
	18.01			8.18	8.99	8.55	9.18	8.72				
	19.01			8.18	8.99	8.55	9.18	8.72				

ZedGeo Systems Private Limited., Mumbai

RECORD OF PILE LOAD TEST NO -

PROJECT -

LOCATION -

CONTRACTOR -

CLIENTS NAME -

L.C OF DIAL GAUGE -
Type of Test

Design load on pile -
Test Load -
Mixed Design -
Pile Diameter -

Ram Area -
Date of Casting -
Pile Depth -

Page

(4)

INITIAL PILE LOAD TEST

DATE	TIME	PRESSURE	LOAD IN MT	Reading				Average settlement	SIGNATURE			REMARK
		GAUGE READING kg/cm ²		Reading 1	Reading 2	Reading 3	Reading 4	Test Pile	ZED	VEL	PMC	
29/10/25	20.01			8.18	8.99	8.55	9.18	8.72	✗	Mal		
	21.01			8.18	8.99	8.55	9.18	8.72				
	22.01			8.18	8.99	8.55	9.18	8.72				
	23.01			8.18	8.99	8.55	9.18	8.72				
29/10/25	00.00			8.18	8.99	8.55	9.18	8.72				
	1.01			8.18	8.99	8.55	9.18	8.72	✗	Mal		
	2.01			8.18	8.99	8.55	9.18	8.72				
	3.01			8.18	8.99	8.55	9.18	8.72				
	3.00	135	344.30	8.18	8.99	8.55	9.18	8.72	✗	Mal		
	3.05			8.18	8.99	8.55	9.18	8.72				
	3.10			8.18	8.99	8.55	9.18	8.72				
	3.11	120	306.12	8.18	8.99	8.55	9.18	8.72	✗	Mal		
	3.15			8.18	8.99	8.55	9.18	8.72				
	3.20			8.18	8.99	8.55	9.18	8.72				
	3.21	105	267.85	8.15	8.89	8.54	9.17	8.68	✗	Mal		
	3.25			8.15	8.89	8.54	9.17	8.68				
	3.30			8.15	8.89	8.54	9.17	8.68				

ZedGeo Systems Private Limited., Mumbai

RECORD OF PILE LOAD TEST NO. -

L.C. OF DIAL GAUGE -
Type of Test

Ram Area -

Date of Casting -

Pile Depth -

PROJECT -

Design load on pile -

Test Load -

Mixed Design -

Pile Diameter -

LOCATION -

CONTRACTOR -

CLIENTS NAME -

INITIAL PILE LOAD TEST

DATE	TIME	PRESSURE	LOAD IN MT	Reading				Age Age settlement	SIGNATURE			REMARK
		GAUGE READING kg/cm2		Reading 1	Reading 2	Reading 3	Reading 4	Test Pile	ZED	VEL	PMC	
29/10/25												
	3:31	90	229.59	8.14	8.89	8.53	9.16	8.68				
	3:35			8.14	8.89	8.53	9.16	8.68				
	3:40			8.14	8.89	8.53	9.16	8.68				
	3:41	75	192.32	8.13	8.88	8.51	9.15	8.66				
	3:45			8.13	8.88	8.51	9.15	8.66				
	3:50			8.13	8.88	8.51	9.15	8.66				
	3:51	60	153.06	8.08	8.78	8.46	9.11	8.60				
	3:55			8.06	8.76	8.45	9.09	8.59				
	4:00			8.06	8.76	8.45	9.09	8.59				
	4:01	45	114.79	6.20	6.90	6.70	7.40	6.8				
	4:05			6.15	6.82	6.66	7.35	6.74				
	4:10			6.12	6.80	6.61	7.34	6.71				
	4:11	30	76.53	5.08	6.95	6.15	7.05	6.30				
	4:15			5.06	6.91	6.12	7.04	6.032				
	4:20			5.04	6.89	6.10	7.02	6.012				
	4:21	15	38.26	4.64	5.55	4.96	5.87	5.20				
	4:25			4.64	5.55	4.96	5.67	5.20				
	4:30			4.63	5.55	4.96	5.67	5.208				
	4:31	0	0	4.63	5.55	4.96	5.67	5.20				