

Disinfectant and Disinfectant By-products (DBPs) - Average and Range are listed. * Chlorine has a MDRL (Maximum Disinfectant Residual Level) and MDRLG (MDRL Goal) rather than an MCL and MCLG.

Chlorine Residual - Entry Pt	mg/L	4	4	0.85 (0.29-1.13)	1.15 (0.78- 1.38) 0.77 (0.46- 0.97)	Additive for control of microbes	Yes
Stage 2 DBPs Total THMs	ug/L	NA	80	49.25 ² (23-85)	(16-58) Max LRAA=46.5	Byproduct of water chlorination	Yes
Stage 2 DBPs Haloacetic Acids	ug/L	NA	60	15.50 ² (11-19)	(ND-22) Max LRAA=14.8	Byproduct of water chlorination	Yes
Alkalinity	Mg/l	NA	NA	NA	(87-89)	Naturally present in the environment	Yes
Lead and Copper - 90% of samples must be less than the Action Level (AL). The 90th Percentile and the number of samples exceeding the AL are listed.							
Copper (Customer Tap Samples) Sept. 2020	mg/L	1.3	AL=1.3	0.143 (None)	0.162 (None)	Corrosion of household plumbing	Yes
Lead (Customer Tap Samples) Sept. 2020	ug/l	0	AL=15	2.43 (None)	7.22 (Two)	Corrosion of household plumbing	Yes
UCMR4 (Fourth Unregulated Contaminant Monitoring Rule) In 2018, the Monroe County Water Authority was required to collect and analyze water samples for unregulated contaminants. Those detected are listed below. For more information, contact the Monroe County Water Authority (MCWA) at (585)621-2001.							
Total HAA5	Ug/L	60	NA	NA	(3.2-15)	Byproduct of water chlorination	NA